

governmentattic.org

"Rummaging in the government's attic"

24-February-2017

01-May-2017

01-May-2017

01-May-2017

26-November-2018

Description of document:

Nuclear Regulatory Commission (NRC) Materials on the following Communities of Practice Site on the NRC Knowledge Center (on Sharepoint/Intranet): Mitigation Strategies for Beyond-Design-Basis External Events and New Reactor Technical Reviews, 2007- 2013

Requested date:

Release 1 date: Release 2 date: Release 3 date:

Posted date:

Source of document:

FOIA Request U.S. Nuclear Regulatory Commission FOIA Officer Mailstop: T-2 F43 Washington, DC 20555-0001 Fax: 301-415-5130 Email: FOIA.resource@nrc.gov

The governmentattic.org web site ("the site") is noncommercial and free to the public. The site and materials made available on the site, such as this file, are for reference only. The governmentattic.org web site and its principals have made every effort to make this information as complete and as accurate as possible, however, there may be mistakes and omissions, both typographical and in content. The governmentattic.org web site and its principals shall have neither liability nor responsibility to any person or entity with respect to any loss or damage caused, or alleged to have been caused, directly or indirectly, by the information provided on the governmentattic.org web site or in this file. The public records published on the site were obtained from government agencies using proper legal channels. Each document is identified as to the source. Any concerns about the contents of the site should be directed to the agency originating the document in question. GovernmentAttic.org is not responsible for the contents of documents published on the website.

-- Web site design Copyright 2007 governmentattic.org --

From: Chidichimo, Gabriele <Gabriele.Chidichimo@nrc.gov> Sent: Thu, Aug 17, 2017 1:36 pm Subject: your FOIA request - 2017-0617 list of NRO records

Attached please find the list of NRO records you requested in order to narrow your scope.

Thank you again for all your help with this!

Gaby

Turbine Missiles - Explained

Lessons Learned from Flow-Induced Vibration to New Reactors

Digital I&C Operating Experience

Corrosion in Nuclear Power Plants

Graphite - Advanced Training

BWR Plant Startup and Shutdown

High Temperature Reactor Materials - Licensing and Regulatory Issue

Seismic Design of Small Modular Reactors

Regulating I&C Diversity for Advanced Reactors

SRP Section 3.9.4 - Control Rod Drive Systems

ASME Code - Explained

Confidence Interval on Estimate of Mean Value

Earthquake Effects on North Anna

Overview of ASME Section XI

PWR Startup and Shutdown

Insights on Performing SRP 6.2.1 Reviews

Containment ISI review and Action Plan

Containment Thermal-Hydraulic and Source Term Phenomena Station Blackout and Emergency Diesel Generator

Pumps and Valves Training Slides

Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

SRP Section 3.9.2 - Dynamic Testing and Analysis of Systems, Structures, and Components SRP Section 3.2.1 - Seismic Classification

High Temperature Metallic Materials in HTGR & VHTR Systems

High Temp Reactors - Construction Code Issues

Alternatives to ASME Code Section III and IEEE 603 Requirements

Leak before Break – History, Updates, and Future Plans

Surry EMD Diesel Failure, Notice of Enforcement Discretion, and Generic Implications Fundamentals of Pressurized Thermal Shock (PTS)

Reactor Vessel and Internals: History, Issues & Resolution

Commercial Grade Dedication of I&C Equipment Sodium-Cooled Fast Reactors and LWRs

Environmentally Assisted Fatigue

ABCs of Welding

Key principles of I&C System Architecture

NRC FORM 464 Part I	U.S. NUCLEAR REGULATORY COMMISSION	FOIA RESPONSE NUMBER			
(03-2017)	RESPONSE TO FREEDOM OF	2017-0617	1		
	INFORMATION ACT (FOIA) REQUEST		ERIM FINAL		
REQUESTER:		······	DATE:		
			AUG 2 8 2017		
DESCRIPTION OF REQUE	STED RECORDS:				
A copy of the material	s on the following Communities of Practice Site on the NF	C Knowledge Center	(on Sharepoint/		
(Intranet): Mitigation Strategies f	or Reyand-Design-Rasis External Events and New Pasata	r Technical Paviawa			
You have the right to see	PART I INFORMATION RELEASE k assistance from the NRC's FOIA Public Liaison. Contact inform	D nation for the NRC's FO	IA Public Liaison is		
available at <u>https://www.i</u>	nrc.gov/reading-rm/foia/contact-foia.html				
Agency records su NRC Public Docur	ubject to the request are already available on the Public NRC We ment Room.	bsite, in Public ADAMS	or on microfiche in the		
Agency records s	subject to the request are enclosed.				
Records subject t referred to that ag	to the request that contain information originated by or of interest gency (see comments section) for a disclosure determination and	to another Federal agen direct response to you.	icy have been		
✓ We are continuing	g to process your request.				
See Comments.					
	PART I.A FEES	NO FE	ES		
	You will be billed by NRC for the amount listed.	Minimum fee three	shold not met.		
\$0.00	You will receive a refund for the amount listed.	Due to our delayed	l response, you will		
*See Comments for details	Fees waived.	not be charged fee	IS.		
PA	ART I.B INFORMATION NOT LOCATED OR WITHHEL	D FROM DISCLOSUR	ξĒ		
We did not locate enforcement and r notification given t	any agency records responsive to your request. Note: Agencies national security records as not subject to the FOIA ("exclusions" to all requesters; it should not be taken to mean that any excluder	may treat three discrete (). 5 U.S.C. 552(c). This is d records do, or do not, e	categories of law s a standard exist.		
We have withheld	d certain information pursuant to the FOIA exemptions described,	and for the reasons stat	ed, in Part II.		
Because this is a appeal any of the	n interim response to your request, you may not appeal at this tir responses we have issued in response to your request when we	ne. We will notify you of issue our final determin	your right to ation.		
You may appeal t FOIA Officer, at U sure to include on NRC's Public Liais <u>https://ogis.archive</u>	his final determination within 90 calendar days of the date of this .S. Nuclear Regulatory Commission, Washington, D.C. 20555-00 your letter or email that it is a "FOIA Appeal." You have the righ son, or the Office of Government Information Services (OGIS). C es.gov/about-ogis/contact-information.htm	response by sending a le)01, or <u>FOIA.Resource@</u> t to seek dispute resolution ontact information for OC	etter or e-mail to the <u>Inrc.gov.</u> Please be on services from the GIS is available at		
PA	ART I.C COMMENTS (Use attached Comments continu	ation page if require) d)		
Please note: As discussed, you narr KM materials ONLY, (continued on next pag	rowed the scope of your request as follows: Indian Point records ONLY (NRR) and a list of 28 presen ge)	tations as specified (N	RO)		
Signature - Ereedom of lof	formation Act Officer or Designee				
Lap,	angel				
NRC Form 464 Part I (03-20		en reconnector	Page 2 of 3		

 $\cdots \cdots \otimes_{n \in \mathbb{N}} \cdots \cdots \otimes_{n \in \mathbb{N}} w$

NRC FORM 464 Part ((03-2017)

U.S. NUCLEAR REGULATORY COMMISSION FOIA

RESPONSE TO FREEDOM OF INFORMATION	l
ACT (FOIA) REQUEST Continued	

2017-0617 1 RESPONSE INTERIM FINAL

DATE:

RESPONSE NUMBER

AUG 2 8 2017

REQUESTER:

PART I.C COMMENTS (Continued)

Please note:

The following responsive records have been made publicly available in their entirety (NRR, related to Indian Point):

ML14251A227 ML12319A008 ML15149A140 ML13337A597 ML15069A028 ML13247A032 ML14251A227 ML13079A348 ML14251A227 ML14070A365 ML14070A365 ML130720080 ML12107A014 ML15246A119

Records with a ML Accession Number are publicly available in the NRC's Public Electronic Reading Room at http://www.nrc.gov/reading-rm.html. If you need assistance in obtaining these records, please contact the NRC's Public Documents Room (PDR) at 301-415-4737 or 1-800-397-4209, or by Email to PDR.Resource@nrc.gov.

NRC FORM 464 Part I	U.S. NUCLEAR REGULATORY COMMISSION	FOIA	RESPONSE NUMBER			
(03-2017)	RESPONSE TO FREEDOM OF	2017-0617	2			
	INFORMATION ACT (FOIA) REQUEST	RESPONSE INTE	FINAL			
REQUESTER:			DATE:			
-			UCT 2 5 2017			
DESCRIPTION OF REQUES	STED RECORDS:					
A copy of the materials	s on the following Communities of Practice Site on the NF	RC Knowledge Center	(on Sharepoint/			
Intranet): Mitigation Strategies fo	or Beyond-Design-Basis External Events and New Reacto	r Technical Reviews				
You have the right to seek available at <u>https://www.n</u>	k assistance from the NRC's FOIA Public Liaison. Contact infor <u>irc.gov/reading-rm/foia/contact-foia.html</u>	D mation for the NRC's FO	IA Public Liaison is			
Agency records sul	bject to the request are already available on the Public NRC We nent Room.	bsite, in Public ADAMS	or on microfiche in the			
✓ Agency records su	ubject to the request are enclosed.					
Records subject to referred to that age	o the request that contain information originated by or of interest ency (see comments section) for a disclosure determination and	to another Federal agen direct response to you.	cy have been			
We are continuing	to process your request.					
✓ See Comments.						
	PART I.A FEES	NO EE	ES			
AMOUNT*	You will be billed by NRC for the amount listed.	Minimum fee three	shold not met			
\$0.00	You will receive a refund for the amount listed.					
*See Comments for details	Fees waived.	not be charged fee	s.			
PAI	RT I.B INFORMATION NOT LOCATED OR WITHHEL	D FROM DISCLOSUR	E			
We did not locate a enforcement and na notification given to	any agency records responsive to your request. <i>Note</i> : Agencies ational security records as not subject to the FOIA ("exclusions" a all requesters; it should not be taken to mean that any excluded	may treat three discrete of). 5 U.S.C. 552(c). This is d records do, or do not, e	categories of law s a standard exist.			
✓ We have withheld	certain information pursuant to the FOIA exemptions described,	and for the reasons stat	ed, in Part II.			
Because this is an appeal any of the r	interim response to your request, you may not appeal at this tin responses we have issued in response to your request when we	ne. We will notify you of y issue our final determin	our right to ation.			
You may appeal thi FOIA Officer, at U.S sure to include on y NRC's Public Liaiso https://ogis.archives	You may appeal this final determination within 90 calendar days of the date of this response by sending a letter or e-mail to the FOIA Officer, at U.S. Nuclear Regulatory Commission, Washington, D.C. 2055-0001, or FOIA.Resource@nrc.gov. Please be sure to include on your letter or email that it is a "FOIA Appeal." You have the right to seek dispute resolution services from the NRC's Public Liaison, or the Office of Government Information Services (OGIS). Contact information for OGIS is available at https://ogis.archives.gov/about-ogis/contact-information.htm					
PAF	RT I.C COMMENTS (Use attached Comments continu	ation page if require	d)			
Please note: As discussed, you narro KM materials ONLY, In (continued on next page	owed the scope of your request as follows: ndian Point records ONLY (NRR) and a list of presentati e)	ons as specified (NRC))			
Signature - Freedom of Infe	rmation Act Officer or Decisions					
Signature - preedom of info						
DUPA						
NRC Form 464 Part I (03-2017	7) Add Continuation Page	Delete Continuation Pag	Page 2 of 3			

5 - 1

NRC FORM 464 Part I U.S. NUCLEAR REGULATORY COMMISSION	FOIA	RESPONSE NUMBER
	2017-0617	2
ACT (FOIA) REQUEST Continued		ERIM 🖌 FINAL
REQUESTER:		DATE:
		OCT 2 5 2017
PART I.C COMMENTS (Continued)	······································	
Please note:		
The NRC regrets to inform you that we are unable to locate the following record	s:	
BWR Plant Startup and Shutdown Unable to find presentation NRO has no record		
Insights on Performing SRP 6.2.1 Reviews Unable to find presentation No record found		
Containment ISI review and Action Plan Unable to find presentation No record found		
1		

(08-2013) (08-2013)	U.S. NUCLEAR REGULATO	RY COMMISSION	FOIA/PA 2017	7-0617	
F	RESPONSE TO FREEDOM OF INFORMATION ACT (FOIA) / PRIVACY ACT (PA) REQUEST		DATE OCT 2 5 2017		
	PART II.A APPLICABLE EXEMP	TIONS			
GROUP Records s X Exemption	ubject to the request that are contained in the specified group a No.(s) of the PA and/or the FOIA as indicated below (5 U.S.C.	re being withheld in 552a and/or 5 U.S	n their entirety or in pa S.C. 552(b)).	art under the	
Exemption 1: The with	held information is properly classified pursuant to Executive O	der 12958.			
Exemption 2: The with	nheld information relates solely to the internal personnel rules a	ind practices of NR	C.		
Exemption 3: The with	held information is specifically exempted from public disclosure	e by statute indicate	ed.		
Sections 141-14 2161-2165).	5 of the Atomic Energy Act, which prohibits the disclosure of Re	estricted Data or Fo	ormerly Restricted Dat	a (42 U.S.C.	
Section 147 of th	e Atomic Energy Act, which prohibits the disclosure of Unclass	ified Safeguards In	formation (42 U.S.C.	2167).	
41 U.S.C., Section person under second the proposal.	on 4702(b), prohibits the disclosure of contractor proposals in the time of the state of the sta	ne possession and ed into the contract	control of an executive between the agency a	e agency to any and the submitter	
Exemption 4: The with	held information is a trade secret or commercial or financial inf	ormation that is be	ing withheld for the re	ason(s) indicated.	
The information	is considered to be confidential business (proprietary) informati	on.			
The information accounting progr	is considered to be proprietary because it concerns a licensee's ram for special nuclear material pursuant to 10 CFR 2.390(d)(1	s o <mark>r applicant's phy</mark>).	sical protection or ma	terial control and	
The information	was submitted by a foreign source and received in confidence	oursuant to 10 CFF	R 2.390(d)(2).		
Disclosure will h	arm an identifiable private or governmental interest.				
Exemption 5: The with Applicat	held information consists of interagency or intraagency record: ole privileges:	s th at are not availa	able through discovery	during litigation.	
Deliberative proc deliberative proc There also are n predecisional pro	cess: Disclosure of predecisional information would tend to inh ess. Where records are withheld in their entirety, the facts are o reasonably segregable factual portions because the release pocess of the agency.	ibit the open and fra inextricably intertw of the facts would p	ank exchange of idea ined with the predecis permit an indirect inqui	s essential to the sional information. iry into the	
Attorney work-p	roduct privilege. (Documents prepared by an attorney in conten	mplation of litigation	ר)		
Attorney-client p	rivilege. (Confidential communications between an attorney an	d hi s/her client)			
Exemption 6: The with invasion	held information is exempted from public disclosure because in n of personal privacy.	s disclosure would	result in a clearly unv	varranted	
Exemption 7: The with	held information consists of records compiled for law enforcem	en <mark>t purp</mark> oses and i	is being withheld for th	ne reason(s) indicated	
(A) Disclosure of focus of enformer	ould reasonably be expected to interfere with an enforcement p procement efforts, and thus could possibly allow recipients to tak s from investigators).	proceeding (e.g., it a action to shield p	would reveal the scop otential wrong doing o	e, direction, and or a violation of NRC	
(C) Disclosure of	ould constitute an unwarranted invasion of personal privacy.				
(D) The informa identities of	tion consists of names of individuals and other information the confidential sources.	disclosure of which	could reasonably be	expected to reveal	
(E) Disclosure w reasonably l	rould reveal techniques and procedures for law enforcement in be expected to risk circumvention of the law.	vestigations or pros	secutions, or guideline	es that could	
(F) Disclosure c	ould reasonably be expected to endanger the life or physical sa	afety of an individua	al.		
OTHER (Specify)					
Pursuant to 10 CFR 9.25(g), 9.25(h), and/or 9.65(b) of the U.S. Nuclear Regulator	y Commission re	gulations, it has be	en determined	
hat the information withhel	d is exempt from production or disclosure, and that its	production or dis	closure is contrary	to the public	
lenials that may be appeal	ed to the Executive Director for Operations (EDO).	as denying onici			
DENYING OFFICIAL	TITLE/OFFICE	RECORD	S DENIED	APPELLATE OFFICIAL	
tephanie Blaney	FOIA/PA Officer	X	··· .		
phool must be meda in the					
ppearmust be made in wr I.S. Nuclear Regulatory Co learly state on the envelor	ning within 30 days of receipt of this response. Appeals ommission, Washington, DC 20555-0001, for action by e and letter that it is a "EQIA/PA Appeal."	s should be maile the appropriate a	ed to the FOIA/Prive ppellate official(s).	acy Act Officer, You should	
state on the envelop					

High Temperature Metallic Materials in HTGR & VHTR Systems

Presented at the NRC Tutorial on High Temperature Metallic Materials for HTGR and SFR Reactor Systems

William Corwin, Oak Ridge National Laboratory

Rockville, Maryland February 17, 2011





(V)HTRs Can Provide High Efficiency Electricity and High Quality Process Heat

Characteristics

- •He coolant
- •Up to 1000°C outlet temperature (long term, <850°C near term)
- •<600 MW_{th}
- •Solid graphite block or pebble bed core

Benefits

- •High thermal efficiency
- Process heat applications
- •High degree of passive safety



High Temperature, Gas-Cooled Reactor Experience Is Widespread

HTGR PROTOTYPE PLANTS

DEMONSTRATION PLANTS





PEACH





DRAGON (U.K.) 1963 - 76 AVR (FRG) 1967 - 1988 PEACH BOTTOM 1 (U.S.A.) 1967 - 1974 FORT ST. VRAIN (U.S.A.) 1976 - 1989 THTR (FRG) 1986 - 1989

LARGE HTGR PLANTS



HTGR TECHNOLOGY PROGRAM

MATERIALS COMPONENTS FUEL CORE PLANT TECHNOLOGY





Pebble Bed Reactor Experience

Major Projects	Power (MWt)	Status
AVR (Germany)	50	Being Decommissioned
THTR 300 (Germany)	750	Decommissioned
HTR 500 (Germany)	1390	Prel Design/Lic Review Archived
HTR 100 (Germany)	250	Prel Design/Lic Review Archived
HTR Modul (US, Germany)	y) 200 Prel Design/Lic Review Archived Safety Concept License Approve	
DPP 400 (South Africa)	400	Prel Design/Lic Review Archived – Major Components Canceled
HTR-10 (China)	10	Operating
PM-250 (China)	250	Construction Underway
PBMR-CG (NGNP)	250	Conceptual Design Underway

PBR conceived in US in '44; 1st patent filed in US in '59; 1st pebbles mfg by Union Carbide

from Sten Caspersson, Westinghouse Electric Co., PBMR Conceptual Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010

Two HTRs Are Currently Operating

- HTTR (prismatic core)
 - JAEA, Oarai, Japan
 - Up to 950°C ROT
 - 50MWth
 - Targeted IS hydrogen production
 - GTHTR300C (600MWth) to follow
- HTR-10 (pebble bed core)
 - Tsinghua University (INET), China
 - 750°C ROT
 - 10MWth
 - Steam generation
 - PM250 (2x250MWth) to follow



VHTRs & HTGRs Can Provide Energy for Many Applications beyond Electricity



(V)HTR Process Heat Generation Is Simple in Concept



components and the metallic core barrel

from Qin Zhenya, Tsinghua Univ. (INET), HTGR Reactor Devl. in Mainland China, Intl. Symp. for Gen IV Nucl. Reactors, Taipei, Apr. 2009

Possible NGNP Configurations Described by INL



- Courtesy of Lee Nelson, INL, Leader NGNP Design Activities for pebble bed variants of NGNP
 - 208-526-3093
 - Lee.Nelson@INL.gov
- Presented at INL, October 28, 2009, to NRC-RES staff and updated January 18, 2011
- Based primarily on completed preconceptual design studies by INL and multiple vendors through 2007, as modified by subsequent design studies

Preconceptual Designs (May, 2007) Targeted High Outlet Temperatures



	Recommended Operating Conditions and Plant Configuration					
ltem	Westinghouse	AREVA	General Atomics			
Power Level, MWth	500 MWth	565 MWth	550-600 MWth			
Reactor Outlet	950°C	900°C	Up to 950°C			
Temperature, °C						
Reactor Inlet	350°C	500°C	490°C			
Temperature, °C						
Cycle Configuration	Indirect – Series	Indirect – Parallel	Direct PCS (Brayton)			
	hydrogen process and	hydrogen process (He)	Parallel indirect hydrogen			
	power conversion	and power conversion	process (IHX with He)			
		(Helical Shell and Tube				
		IHX)				
Secondary Fluid	He	He – Nitrogen mixture to	Не			
		PCS				
		He to H-2 Process				
Power Conversion	100% of reactor power	100% of reactor power	100% of reactor power			
Power						
Hydrogen Plant Power	10% of reactor power	10% of reactor power	5 MWth – THE			
			60 MWth – S-I			
Reactor Core Design	Pebble Bed	Prismatic	Prismatic			

Preconceptual Designs (May, 2007) Targeted High Outlet Temps (cont)



	Recommended Operating Conditions and Plant Configuration					
ltem	Westinghouse	AREVA	General Atomics			
Fuel	TRISO UO ₂ 1 st and	TRISO UCO – 1^{st} and	TRISO UO ₂ 1^{st} core			
	subsequent cores	subsequent cores	Variable subsequent cores			
Graphite	PCEA & NBG-18	NGG-17 and NBG-18	IG-110 & NBG-18			
RPV Design	Exposed to the gas inlet	Exposed to the gas inlet	Exposed to the gas inlet			
	temperature	temperature; insulation and	temperature			
		vessel cooling options may				
		be pursued				
RPV Material	SA508/533	9Cr – 1 Mo	2-1/4 Cr – 1 Mo			
			9 Cr – 1 Mo			
ІНХ	2-Stage Printed Circuit	PCS – 3-Helical Coil Shell &	Process – single stage PCHE,			
	Heat Exchanger (PCHE), In	Tube, In 617	ln 617			
	617 material	Process – PCHE or Fin-Plate,				
		In 617				
Hydrogen Plant	Hybrid thermo-chemical	Initial-High Temperature	Initial-High Temperature			
	plus electrolysis	Electrolysis	Electrolysis			
		Longer Term – Sulfur-Iodine	Longer Term – Sulfur-Iodine			
Power Conversion	Rankine; standard fossil	Rankine; standard fossil	Direct gas turbine			
	power turbine generatior	power turbine generator	Option – Direct Combined			
	set	set	Cycle			

Prismatic Reactors Based on MHTGR (GA) with Cross Vessel and Steam Generator





MH GR ypical Plant P	'arameters
Thermal Power, MW(t)	600
Fuel Columns	102
Fuel Cycle	LEU/Natural U
Average Power Density, W/cm ³	6.6
Primary Side Pressure, MPa (psia)	7.07 (1025)
Induced Helium Flow rate	281 kg/s
Core Inlet Temperature, [°] C ([°] F)	288(550)
Core Outlet Temperature, ^o C (^o F)	704(1300)

Effect of Power Level on Reactor Vessel – GA (based on existing design information)



Reactor Parameter	350 MWth	450 MWth	550 MWth	600 MWth	
Reactor Vessel ID, m*	6.55	7.22	7.22	7.22	
RPV Thickness, m	0.133			0.216	
RPV Height, m*	22.0			24.0	
RPV Weight, t	728			1328	
Reactor Vessel Material	SA 508/533	SA508/533	2 ¼ Cr-1Mo or 9 Cr-1 Mo (with active vessel cooling would be SA508/533)	2 ¼ Cr-1Mo or 9 Cr-1 Mo (with active vessel cooling would be SA508/533)	

* Pebble Bed RPV for 500 MWth plant is 6.8m OD and height of 30m

Metallic Materials (GA) Function of ROT



Component	Temperature Conditions	750C	Mat'l Selection	850C	Mat'l Selection	950C	Mat'l Selection
Inner Control Rod	Normal Ops PCCD max DCCD Max	808 1164 1418	C-C or SiC- SiC	850 1174 1428	C-C or SiC- SiC	871 1179 1433	C-C or SiC- SiC
Outer Control Rod	Normal Ops PCCD max DCCD Max	440 929 980	C-C or SiC- SiC	482 939 990	C-C or SiC- SiC	526 1129 1000	C-C or SiC- SiC
CR and RSM Guide Tubes	Normal Ops PCCD max DCCD Max	346 933 418	Hastelloy X		C-C or SiC- SiC		C-C or SiC- SiC
UCR	Normal Ops PCCD max DCCD Max	346 1028 604	C-C or SiC- SiC	346 1038 614	C-C or SiC- SiC	346 1048 624	C-C or SiC- SiC
UPS T/B	Normal Ops PCCD max DCCD Max	318 877 455	Hastelloy X	318 887 465	Hastelloy X	318 897 475	Hastelloy X
MCS Load pads	Normal Ops PCCD max DCCD Max	653 653 653	Macor Glass Ceramic	730 730 730	Macor Glass Ceramic	807 807 807	Macor Glass Ceramic

PCCD = Pressurized Conduction Cool Down

DCCD = Depressurized Conduction Cool Down

RSM = Reserve Shutdown Material

UCR = Upper Control Rod

UPS T/B= Upper Plenum Shroud Thermal Barrier

MCS = Metallic Core Supports

Metallic Materials (GA) Function of ROT (cont)



Component	Temperature Conditions	750C	Mat'l Selection	850C	Mat'l Selection	950C	Mat'l Selection
Hot Duct T/	Normal Ops	749		848		948	
В	PCCD Max	786		837		986	C C or SiC
	DCCD Max	820	Hastelloy X	923	Hastelloy X	1022	
		749		848		948	310
		749		848		948	
LPS T/B	Normal	670		752		833	
	Operation	707		791		871	
	PCCD Max	742	800H	826	Hastelloy X	907	Hastelloy X
	DCCD Max	670		752		833	
		670		752		833	
SCS	Normal	653		729		806	
Entrance	Operation	690		768		844	
Tubes	PCCD Max	724	800H	804	Hastelloy X	880	Hastelloy X
	DCCD Max	653		729		806	
		653		729		806	
SCS T/B	Normal	350		350		350	
	Operation	350	8000	350	800H	350	800H
	PCCD max	350	00011	350	00011	350	00011
	DCCD Max						

LPS = Lower Plenum Shroud

SCS = Shutdown Cooling System

Layout of the Pebble Bed Reactor Unit Included SG and IHX(s) for Electricity and H₂ Generation





Helium Temperatures in Pebble Bed NGNP Piping Sections (950°C)



Piping Location	Temperature (°C)*			
Primary Heat Transport System				
RPV to IHX A	950			
IHX A to IHX B	760			
IHX B to Circulator	337			
Circulator to RPV	350			
Secondary Heat Transport System				
IHX A to PCHX	900			
IHX A to Mixing Chamber	900			
Mixing Chamber to SG	840			
PCHX to Mixing Chamber	659			
SG to Circulator	273			
Circulator to IHX B	287			
IHX B to IHX A	700			
*Initial studies indicate that transient temperatures are only very slightly higher than these.				

Helium Flow Path Configuration through the Pebble Bed Reactor





Comparison of PBMR DPP and NGNP Key Operational Parameters



Parameter	Normal Operation		DLOFC		PLOFC ^{b.c}	
r drameter	NGNP	DPP	NGNP ^d	DPP⁵	NGNP	DPP
RIT (°C)	350	500	-	-	-	-
ROT (°C)	950	900	-	-	-	-
Tmax, CB (°C)	350 ⁴	414 ^b	466-634	579 (48h)	565	482
Tmax, RPV (°C)	308 ^{.†}	324 ^b	328-452	419 (56h)	401 (56h)	3 7 3 (48h)
He Mass Flow (kg.s)	160	192	-	-	-	-
Thermal Power (MW)	500	400	-	-	-	-

^a 25% increase in power level, hence 25% higher flux level assumed for NGNP compared to DPP.

^b Based on Case 5, NGNP Special Study 20 2: Prototype Power Level Study, NGNP-20-RPT-002, 26-01-07 [1]

^c Indirect cycle NGNP design, hence operating pressure in system assumed to remain constant at 9 MPa

^d Reactor Parametric NGNP Special Study, NGNP-NHS 90 PAR, August 2008

Vertical Schematic Section through the Reactor Unit - PBR





Horizontal Section through the RU without the Core Inlet and Outlet Pipes





Control Rods for the PBMR NGNP



- Reactivity Control System (RCS) used to control reactivity in the core, to quickly shut the reactor down and to keep it in a shutdown mode
- RCS consists of 24 identical control rods.
 - > Control rods are one group of 12
 - > Shutdown rods are one group of 12
- Each rod has six segments containing absorber material (sintered B₄C rings between two coaxial cladding tubes separated by joints)
- DPP design uses Alloy 800H for cladding and joints
- Chain lowers and raises the control rods through segmented graphite liners in the Inner Side Reflector (ISR)
- During SCRAM event, control rods drop by gravity but are limited by the characteristics of the drive and the shock is absorbed by secondary shock absorber



Tentative PCDR Reactivity Control System Metallic Materials for the PBMR NGNP



Drive Motor Housing			Component	Materials	Applicable ASME Design Code	Qualification Approach
ROM Housing Shock Absorber	Rod Drive Mechanis	RCS Chain	SB-446 Alloy 625	Not applicable	Design by analysis, supported by appropriate test data	
		RCS Absorber Cladding Tubes	SB-407 Alloy 800H	Not applicable	Design by analysis, based on KTA 3221, supported by appropriate test data	
	Shock Absorber	RCS Shock Absorber	SB-408 Alloy 800H	Not applicable	Design by analysis, based on KTA 3221, supported by appropriate test data	
			RCS Guide Tubes	SA-182 F316H SA-312 Gr 316H	Section III, Subsection NG (Tubes)	Use NRC-accepted ASME Specification + EJEMA8 (Bellows)
				·		

Hot Gas Duct System Materials for the PBMR DPP





Component	Material	Applicable ASME Design Code	Qualification Approach
Core Outlet/CCS Inlet Pressure Pipe	SA-672 Grade J90 (Made from SA-533 Type B, CI 2 plate)	Section III, Subsection NC	Use NRC-accepted ASME Specification
Core Outlet/CCS Inlet Liner (950 C)	SB-409 Alloy 800H	Not applicable	Design by analysis, based on KTA 3221, supported by appropriate test data
Insulation	Al ₂ O ₃ and SiO ₂ (Saffil)	Not applicable	TBD

Steam Generator

Compact Heat Exchanger

Unit Cell – Plate-Fin Compact IHX

Candidate Materials: 230 800H 617 Hastelloy X

Concept of Compact IHX

By Sept. 2009, Reference Configurations Featured Much Lower ROTs and Included SGs, not Primary-Secondary IHXs

	Tentative Operating Conditions and Plant Configuration			
Item	[to be finalized during Conceptual Design]			
	Westinghouse	AREVA	General Atomics	
Power Level, MWth	200	625	350-600	
Reactor Outlet Temperature, °C	750°C	750°C	750°C	
Reactor Inlet Temperature, °C	280°C	325°C	322°C	
Cycle Configuration	Steam Generator in primary loop	Steam Generator in primary loop	Steam Generator in primary loop	
Secondary Fluid	Не	NA	NA	
Reactor Core Design	Pebble Bed (cylindrical)	Prismatic	Prismatic	

NHSS Layout – Builds on German HTR Modul Experience

Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010


NHSS Primary Loop Heat and Mass Balance

PBMR



from Sten Caspersson, Westinghouse Electric Co., PBMR Conceptual Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010





Pebble Bed Reactor Features

Passive Safety Features

Ceramic coated-particle fuel

 Maintains integrity during loss-of-coolant accident

Ceramic core with high heat capacity

- High temperature structural integrity
- Slow thermal response times

Passive heat transfer path

 Limits fuel temperature during loss-ofcoolant accident

Low power density

- Inert Helium Coolant

Negative Temperature Coefficient

Two diverse shutdown systems

Inserts under gravity when power is lost

Operating Features

On-line refueling

No refueling outages

High gas temperature

- Efficient power conversion cycles
- Process heat applications

from Sten Caspersson, Westinghouse Electric Co., PBMR Conceptual Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010



Coolant Flow Design



- The coolant flow path design needs to consider the following aspects:
 - cool the metallic structures where necessary
 - reduce bypass flows
 - provide a uniform temperature distribution
 - mix the bypass flows to lower the thermal stratification in the outlet gas

from Sten Caspersson, Westinghouse Electric Co., PBMR Conceptual Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010



Prismatic NGNP Primary System

 Modular Nuclear Heat Supply System (NHS)

> 350 MWt annular core Triso coated particle fuel Helium cooled Graphite moderated 750°C core outlet temp 540° C/17.3 MPa steam heat

 NHS Contained in 2 steel vessels, RV and SGV, interconnected by a cross vessel



Idaho National Laboratory

Main NHS Systems, Subsystems & Components

- Reactor System (RS) Fuel, graphite, CRs, CRD mechanisms, metallic internals, insulation
- Vessel System (VS) RV, SGV, XV, supports, pressure relief
- Heat Transport System (HTS) SG, main circulator, hot duct
- Shutdown Cooing System (SCS)
 SCS circulator, SCS heat exchanger
- Helium Service System (HSS) -He Purification, transport & storage
- Fuel Handling and Storage System (FHSS) - Refueling machine, transport cask, cask transporter
- Reactor Cavity Cooling System (RCCS)





Prismatic NHS Contained in Below Grade Silo

 Cylindrical silo with 2 main cavities:

> Reactor cavity Steam generator cavity

- Silo depth based on placing SG thermal center well below core
- Main advantages of below grade silo:

Sabotage/damage resistant Increased safety approach

- Decay heat can be dissipated to earth in the event of RCCS failure
- More resistant to damage from seismic events

Improved economics relative to above-grade installations



Passive Heat Transfer Path Description



from Sten Caspersson, Westinghouse Electric Co., PBMR Conceptual Design, VHTR R&D FY10 Technical Review Meeting, Denver, Apr 2010

Idaho National Laboratory



Prismatic NGNP Key Design Selections for CD

NGNP mission Reactor type Exclusion Area Boundary Off-site accident dose limits Occupational exposure limits Reactor power Reactor pressure vessel material Core Fuel particles Fuel compact matrix Fuel block Graphite grade – fuel elements Graphite grade – replaceable reflectors

Co-generation of process steam and electricity Modular Helium Reactor (1 module prototype) 425 m (commercial site requirement) PAGs (1 rem whole body; 5 rem thyroid) 10% of 10CFR20 350 MW(t) SA 508/SA 533 steel (LWR vessel material) Prismatic core LEU UCO (Single or Multiple enrichment) Thermosetting Resin matrix 10-row block (same as used in FSV) Near-isotropic, nuclear grade (having properties similar to H-451 TBD



Key Design Selections for Tech Dev Identification (cont)

Graphite grade – permanent coré structures	TBD
Number of primary coolant loops	Single primary loop, single secondary
Primary coolant	Helium
Hot duct material	Alloy 800H
Core inlet helium temperature	322° C
Core outlet helium temperature	750 °C
Energy transfer system	Primary to secondary transfer via steam generator in primary
Secondary working fluid	Water/steam
Steam generator inlet/outlet conditions	200°C, 19 MPa / 540°C, 17.3 MPa
Electricity generation	In secondary system via Rankine Cycle
Process steam generation	In tertiary system via steam-to-steam heat exchanger
Reactor Cavity Cooling System	Air-cooled RCCS
Containment	Vented Low-Pressure Containment

(V)HTRs Require Additional Qualification and/or Development of High-Temperature Materials

- Designs for near-term deployment include He-cooled reactors with outlet temperature of 750 to 800°C in service for 60 years
- Outlet temps for advanced VHTRs may exceed 950°C
- Primary challenges for VHTR structural materials are irradiationinduced and/or time-dependent failure and microstructural instability in the operating environments
- Additional materials issues related to fabrication, codes and standards, modeling, and design methods must be addressed
- Useful to consider structural materials in four categories
 - Graphite (e.g., core support structures, fuel matrix, etc.)
 - Very high temperature metals (e.g., IHX, SG, turbomachinery, etc.)
 - Medium high temperature metals (e.g., RPV, piping, IHX shell, etc.)
 - Ceramic & composites (e.g., core restraints, control rods, duct liners, etc.)

Metals in Very High Temperature Service Have Major Challenges

- High-temperature mechanical properties (e.g., tensile, creep, creep fatigue, stress rupture, high and low-cycle fatigue, creepfatigue crack growth, fracture toughness) in air and impure helium environments
- Environmental degradation processes from exposure to hightemperature helium with contaminants such as CO, CO₂, H₂, H₂O, and CH₄
- High-temperature metallurgical stability (thermal aging effects)
- Long-term irradiation-induced effects on core internals
- Extension of ASME and similar design Code approval for metallic materials for higher VHTR operating temperatures, longer service times, and complex loading conditions
- Validated methodologies for inelastic design analysis

Alloys 617, 230, Incoloy 800H & Hastelloy X(R) Are High Temperature Alloys for IHXs and SGs

- Temperatures up to 950°C
- Expected principal damage mechanism: creep-fatigue
- Only one alloy, 800H, is ASME Code qualified and only to 762°C
- Alloys 617, 230 & X(R) suitable but not in nuclear section of the ASME Code
- 2 1/4Cr-1Mo code qualified for lower SG temperatures
- Dissimilar metal welds remains an issue



(Courtesy Heatric)

Candidate Materials for IHX & SG Applications Must Have High-Temperature Strength & Corrosion Resistance

Wrought high-Ni creep resistant alloys (20-22 wt% Cr) are creep resistant and offer protection against oxidation up to about 900°C by formation of chromia scale

	Ni	Cr	Mn	Co	С	Fe	Ti	AI	W	Si	Мо
Inconel 617	base	22.0	0.40	12.0	0.10	2.0	0.40	1.2	-	0.40	9.0
Haynes 230	base	22.0	0.65	5.0	0.10	3.0	-	0.30	14.0	0.50	2.0
Alloy 800H	32.0	21.0	1.00	-	0.06	bal	0.40	0.40	-	0.60	-
Hastelloy X	base	22.0	1.00	1.50	0.10	18.5	0.15	0.50	0.60	1.00	9.0

None are fully qualified in ASME or similar codes for VHTR nuclear applications

Need to Model and Codify High-Nickel Alloy Creep Behavior



Typical Metal

Alloy 617

Thomas Lillo, INL

- Alloy 617 creep behavior
 - -Majority of life spent in tertiary creep regime, not in primary and secondary creep.
 - Need to determine amount of creep that can be tolerated before load carrying capability is significantly compromised

Need to Improve and Validate Creep-Fatigue Interaction Models for High-Nickel Alloys

- Better understanding of operative mechanisms
 - Fatigue-dominated regime
 - Creep-dominated regime
- Effect of hold time: saturation or continuous degradation
- Development of improved constitutive models
- Verification of creep-fatigue interaction diagram
- Incorporation into ASME Code



Aging and Environmental Effects Must Be Assessed for VHTRs



- There is no VHTR environment that is inert with respect to alloys
- Environmental-effects maps will help in specification of He impurity content of primary coolant for longterm stability of heat exchangers and steam generators (region II desirable)
- Even without environmental effects, long-term aging results in formation of new phases that can affect mechanical properties

Typical Surface of Alloy 617 Exposed in Air Develops Protective Oxide Layer Containing Islands of Co & Ni



Richard Wright, INL

Alloys Exposed to Oxidizing VHTR He at 1000°C Produce Slow Growing Protective Scales

Alloy 617 Exhibits Generally Similar Behavior as Air Exposure Alloy 230 Forms Thinner Oxide Layer and Less GB Oxidation. Internal WC precipitates visible



Richard Wright, INL

Neither Alloy Is Clearly Superior

Stability of Chromia in VHTR Coolants Is Primarily a Function of P(CO) at Low H₂O

1000



from Rouillard F., Cabet C. et al. Oxid Met 68 (2007) 133 data on Inconel 617 after W. J. Quadakkers, Werkstoffe und Korrosion 36 (1985) 335

Aging of 617 Results in Microstructural Instability and Loss of Ductility



- Aging under load results in carbide redistribution and cavitation
- Thermal aging can result in precipitation of additional phases that differ from those under load

Even with Reductions due to Aging Effects, Tensile Ductility of Aged Alloys Is Still Okay



- Un-aged material : 617 > 230 up to 700°C and 230 ~ 617 at T > 750°C
- 1000 hrs-aged 617 : Loss of ductility in the range [700-750°C]
- 1000 hrs-aged 230 : scattered data at T > 850°C

Richard Wright, INL, Alloys supplied by CEA

Control Rods Must Also Deal with Irradiation Effects



Lance Snead, ORNL

- Irradiation-induced embrittlement is a common feature for high-alloyed heatresistant materials
- Ni-based alloys are highly susceptible to embrittlement due to helium generation and phase instability during irradiation
- Alloy 800 exhibited the best irradiated ductility in material screening experiments for Japanese HTTR
- However, even Alloy 800 undergoes a major loss of ductility after ≈ 0.5 dpa irradiation at 400-600°C and an order of magnitude loss in creep life

VHTR Pressure Vessels Are the Components of Greatest Concern for Medium-Temperature Metallic Service

- Normal/off-normal service temperatures and vessel size dominate materials requirements
- With engineered cooling of the vessel, the use of LWR A508/533 steels may be acceptable
 - Limited to <<371°C operation and small, short excursions
 - Assessment still needed for short-time exposures at temperatures approaching or beyond 371°C
- Higher temperature operation of VHTR RPVs requires higher temperature alloys, e.g., 2.25Cr-1Mo(V) or 9Cr-1MoV
 - Very large vessel sizes (up to 30m high x 8-9m diameter) will require scale-up of ring forging & on-site joining technologies, plus Code modifications



Expected Irradiation Dose Low Enough to Avoid Embrittlement but Very Long Term Service May Produce Excessive Creep at Low Temperatures

Methods to Ensure High Emissivity of RPV Surfaces Must Be Qualified

- Accident conditions (PLOFC & DLOFC) require high RPV emissivity for passive rejection of decay heat
- Limited studies have shown emissivities from 0.3 for cleaned to 0.9 for oxidized surfaces
- Composition and long-term stability of corrosion products must be evaluated
- Evaluation of core barrel emissivity is also needed
- Additional surface treatments or coating may be needed



Improved Multi-Scale Modeling Is Needed to Support Inelastic Finite Element Design Analyses



GIF Activities Are Underway to Address VHTR Materials Issues

- The Generation IV International Forum is coordinating materials research on graphite, metals, and ceramics & composites performed in seven countries and the EU in direct support of VHTR system developments
- Active programs in China, Japan, Korea, France, Russia, and the U.S. are developing designs and materials requirements for gas cooled reactor systems
- DOE-NE is U.S. participant in VHTR Materials Project Arrangement that has been established to develop and share data among GIF signatories



PIRT Techniques Were Used to Identify Safety-Relevant Phenomena for NGNP*

- Materials degradation phenomena for major components and the materials comprising them were identified
- Phenomena were evaluated for their potential contribution to and pathway for off-site release
- Importance and state of knowledge used to prioritize phenomena
- 58 phenomena identified
 - 17 deemed to have high importance & low/medium state of knowledge on RPV, piping, control rods, internals and valves

*Reference: Next Generation Nuclear Plant Phenomena Identification and Ranking Tables (PIRTs), Volume 4: High-Temperature Materials PIRTs, NUREG/CR-6944, Vol. 4, ORNL/TM-2007/147, Vol. 4, March 2008

Recommended Update on NGNP High Temp Matls PIRT Completed in 2010*

- Considered new, lower temperature versions of NGNP
- Several high-priority phenomena on RPV, piping & HX lowered due to lower ROTs or elimination of HX
- 6 phenomena on SG added and 1 on control rods elevated to high priority; total of 10 high-priority items
- Document produced during IPA & presented to RES staff, but not peer reviewed externally
- PIRT update available for internal NRC use only and contains recommended R&D for phenomena

*Reference: "Recommendation for a High Temp Metals PIRT Update 02-27-10," sent to Shah Malik, NRC-RES, from Bill Corwin, ORNL, via email on March 29, 2010.

High Priority Phenomena in Update on NGNP High Temp Matls PIRT Include:

- Compromised RPV integrity and excessive fuel temperatures caused by inadequate heat transfer from RPV surface due to potential loss of desired surface layer properties and associated reduction of emissivity (#11)
- Breach to secondary system via SG tube failure from initiation & propagation of flaws due to creep crack growth, creep, creep-fatigue, aging (with or without load) & subcritical crack growth (#40a)
- Breach to secondary system via SG tube failure arising from primary boundary design methodology limitations for high-temperature structures (#40b)

High Priority Phenomena in Update on NGNP High Temp Matls PIRT Include: (cont)

- Breach to secondary system via SG tube failure from materials degradation from long-term aging (#40c)
- Breach to secondary system via tube failure from undetected initiation & propagation of flaws due to inadequacy of ISI for high-temperature SGs (#40d)
- Breach of primary to secondary system boundary resulting in water ingress & attack on graphite core structures due to higher secondary system pressures in SG (#40e)

High Priority Phenomena in Update on NGNP High Temp Matls PIRT Include: (cont)

- Inadequate heat transfer from through core barrel due to potential compromise of emissivity from loss of desired surface layer properties (#46)
- Inability to maintain core structure geometry due to potential excessive deformation from radiation-creep in metallic core barrel (#47)
- Two high-priority phenomena on insulation & core restraint failure for non-metallic materials (#s 52,53)

Contributions to this presentation are gratefully acknowledged

- Lee Nelson <lee.nelson@inl.gov>, Richard Wright <richard.wright@inl.gov> and Thomas Lillo
 <thomas.lillo@inl.gov> from the Idaho National Laboratory
- Lance Snead <sneadll@ornl.gov>, Sam Sham <shamt@ornl.gov>, Dane Wilson <wilsondf@ornl.gov> and Randy Nanstad <nanstadrk@ornl.gov from the Oak Ridge National Laboratory
- Bob Jetter <bjetter@sbcglobal.net>, Chair, ASME Subcommittee on Elevated Temperature Design
- Celine Cabet <celine.cabet@cea.fr> from CEA, Saclay
- Qin Zhenya <qinzhenya@tsinghua.edu.cn> from Tsinghua Univ.
- Kobus Smit <kobus.smit@pbmr.co.za> from PBMR
- Sten Caspersson <caspersa@westinghouse.com> from Westinghouse Electric Co.
- Arkal Shenoy <arkal.shenoy@ga.com> from General Atomics

High Temperature Reactors - Construction Code Issues

Sam Sham Oak Ridge National Laboratory

For Presentation at the Nuclear Regulatory Commission Meeting

February 17, 2011





SUBSECTION NH OVERVIEW AND KEY FEATURES

- Development initiated in late 60's in response to needs of LMR and HTGR
 - Continuous review and improvement since
 - Accelerated development in last few years after 10 – 15 year hiatus
- Implemented on FFTF and CRBR
 - Experience summarized in 4 volume set of WRC Bulletins
 - ACRS review identified concerns for CRBR licensing
 - Program plan for resolution identified and initiated - CRBR canceled prior to completion
- Failure modes addressed
 - NH addresses the rules for Class 1 nuclear components above the temperature limits of NB – 700F for ferritic and 800F for austenitic materials
 - Ductile rupture from short-term loadings

- Creep rupture from long-term loadings
- Creep-fatigue failure
- Gross distortion due to incremental collapse and ratcheting
- · Buckling due to short-term loadings
- Creep buckling due to long-term loadings
- Loss of function due to excessive deformation
- Scope of rules
 - Materials
 - Design
 - Fabrication and installation
 - Examination
 - Testing
 - Overpressure protection

ELEVATED TEMPERATURE CODE CASES

Section III, Div 1	Coverage
N-201-5	Class CS (Core Support) Components in Elevated Temperature Service.
N-290-1	Expansion Joints in Class 1, Liquid Metal Piping.
N-253-14	Construction of Class 2 or Class 3 Components for Elevated Temperature Service.
N-254	Fabrication and Installation of Elevated Temperature Components, Class 2 and 3.
N-257	Protection Against Overpressure of Elevated Temperature Components, Classes 2 and 3.
N-467	Testing of Elevated Temperature Components, Classes 2 and 3.
N-499-2	Use of SA-533 Grade B, Class 1 Plate and SA-508 Class 3 Forgings and their Weldments for Limited Elevated Temperature Service.

SOME RELEVANT NH KEY FEATURES

- Allowable primary stress (those determining required wall thickness) based on timedependent creep properties
- Degradation factors provided for effects of time at temperature (aging)
- Weld strength reduction factors (SRFs) provided as a function of time, temperature, process and weld metal
- Cyclic life assessed through strain limits and creep-fatigue
 - Strain limits reduced by a factor of two for welds to help insure that they are located in low stress areas
- Negligible creep criteria provided to permit application of NB rules for primary plus secondary stress limits
- Restricted material specifications to improve performance
 - Optional for 304SS and 316SS
- Cold work limitations and reheat-treatment requirements
- Severely restricted use of partial penetration welds
- Requires double volumetric examination of welds
 - Applies to category A, B, C and D welds in components greater than 4 in. diameter
MATERIALS

- Only 304 & 316 SS, 800H, 2¹/₄Cr-1Mo and, recently, 9Cr-1Mo-V are approved pressure boundary materials; 718 for bolting
 - All are in annealed condition for long term stability except 9Cr-1Mo-V & 718
 - N&T for 9Cr-1Mo-V for time independent allowables & minimize ratcheting
 - SA508 & 533 in Code Case 499 for limited cycles, time & temperature
- Reduction in yield and ultimate due to elevated temperature service addressed in NH-2160(*d*)
 - Off normal operation could reduce allowables for subsequent events, i.e. seismic
- Fatigue acceptance test for 304 & 316 SS
 - Creep-fatigue test at 1% strain and 1hr hold time

MATERIALS TIME & TEMPERATURE

NH code materials (other than bolting)	Maximum temperature		
	For stress allowables S ₀ , S _{mt} , S _t , S _r up to 300,000 hours ^a	For fatigue curves	
304 stainless steels (UNS S30400, S30409)	816°C	704°C	
316 stainless steel (UNS S31600, S31609)	816°C	704°C	
Alloy 800H (UNS N08810)	760°C	760°C	
2¼Cr 1Mo steel, annealed condition (UNS K21590)	593°C ^b	593°C	
Grade 91 steel (UNS K90901) ^c	649°C	538°C	

a. The primary stress limits are very low at 300,000 hours and the maximum temperature limit

b. Temperatures up to 649°C (1200°F) are allowed up to 1,000 hours

c. The specifications for Grade 91 steel covered by Subsection NH are SA-182 (forgings), SA-213 (small tube), SA-335 (small pipe), and SA-387 (plate). The forging size for SA-182 is not to exceed 4540 kg.

DESIGN – Load Controlled (Primary) Stresses

- NH applies above temperature limit for NB allowable stresses
 - 700F for ferritic materials and 800F for austenitic materials
- NB applies above temperature limits if creep effects demonstrated not significant
 - Documented in Stress Report and included in Design Spec. (NH-3211(c))
 - See also T-1324
 - Source for allowable stresses not defined
 - Presumably S_m from NH
 - Disconnect between temperature definition in NB and NH
 - Section average in NH vs. local maximum in NB for some cases

- NH Design Condition evaluation same as Section VIII. Div 1 with same allowables
 - Don't include short term loads in Design Conditions
- NH Service Condition allowable stress criteria same as NB for time independent Sm but different and more conservative than VIII. Div 1 for time dependent allowable S_t

VIII, Div 1

80% of min. or 67% of avg. creep rupture stress	67% of min. creep rupture stress
Avg. strain rate = 0.01% per 1000 hr	100% avg. stress to 1% strain
None	80% of min. stress to tertiary creep

NH

 Wall thickness probably governed by Service Conditions

- Evaluation of Design Conditions and all Service Conditions except Level D are based on a linear elastic material model.
 - Requires stress classification
 - Reference stress methodology under consideration
- Time fraction summations used to evaluated different stress, time and temperature conditions
 - Time fractions summed over all Service Conditions
 - Time fraction is time in a specific condition divided by allowable time at that condition
- Weld strength reduction factors are provided for permitted weld metal and properties
 - Analysis based on parent metal properties

DESIGN - Deformation Controlled Limits

- Acceptable Deformation Controlled Limits in Appendix T
 - Alternative criteria may be used subject to Owner's approval and incorporation in Design Specification
 - Covers strain limits/ratcheting (analogous to P + Q), creep-fatigue damage (analogous to P + Q + F), buckling and welds
- Strain Limits and Creep-Fatigue Damage rules can be satisfied using either elastic or inelastic analysis methods
 - Elastic analysis rules originally envisioned as simpler, more conservative and less costly screening method to satisfy strain limits and creep-fatigue
 - Actually considerably more complex than analogous 'low" temperature rules in NB
 - Inelastic rules envisioned as a more costly and time consuming "gold standard"
 - Conceptually simple but require sophisticated modeling of material behavior in creep regime
 - Requirements for material modeling only addressed in general terms/performance criteria
 - Didn't want to stifle development of improved methods

Creep-Fatigue

- Major source of conservatism in NH
 - Criteria: $\sum (n/N_d) + \sum (\Delta t/T_d) \le D$
 - *n*, number of cycles of a given strain range
 - *N_d*, allowable number of cycles at that strain range
 - Δt , time at a stress level calculated from average properties
 - T_d , allowable time at the calculated stress level divided by a factor, K' = 0.67 for inelastic analysis and 0.9 for elastic analysis, as determined from plot of min. stress to rupture vs. time to rupture
 - *D*, damage factor to account for combined effects of creep and fatigue
- Rationale for conservatism
 - *K*' = 0.67 is based on Eddystone piping failure and component test results
 - Recent reassessment based on elastic analysis led to K' = 0.9
 - *D* for 9Cr-Mo-V due in part to environmental effects and in part to evaluation methodology





- Currently under review in SG-ETD
- Result
 - Wall thickness may be limited by creepfatigue rather than load controlled stress criteria

Buckling

- Buckling charts for Section VIII, Div. 1 & Section 1 do not consider creep
 - Figures provided in NH to define time & temperature limits for applicability of charts
- A matrix of load factors is supplied in NH to address buckling and instability
 - Factors are a function of:
 - Source, load controlled or deformation controlled
 - Duration, time independent or time dependent
 - Service Level

• Welds

- Weld strength reduction factors
- Strain limits half that of parent material
- Creep-fatigue limits:
 - N_d , allowable number of cycles reduced by factor of two
 - Minimum parent metal creep rupture strength reduced by weld strength reduction factor
- Weld geometry
 - Worst case geometry used in analysis
 - » No upper limit on stress concentration factor implies ground welds
 - Confirmed by inspection

EXAMINATION

Dual weld exam required

- Radiography plus ultrasonic
- Radiography plus eddy current
- Radiography at two different angles

NH-5000 refers to NB-5000

- NB-5000 invokes Section V "Nondestructive Examination"
- Article 14 "Examination System Qualification"

Recommended Reading

- Chapter 12 of "Companion Guide to the ASME Boiler & Pressure Vessel Code" K. R. Rao, Editor, ASME Press
 - Background and discussion of Subsection NH rules and their implementation including relevant Code Cases

DOE/ASME GEN IV MATERIALS PROJECT

- Collaboration between DOE and ASME established in 2007 to address technical topics that were identified by DOE, ORNL, INL, and ASME to have particular value with respect to the ASME Code
- In support of an industrial stakeholder's application for licensing of a Gen IV nuclear reactor
 - Phase I
 - Tasks 1– 5 completed
 - 2007/2008
 - Phase II
 - Tasks 6-11 completed
 - 2009/2010

- Phase III
 - Proposed Tasks 13-14
 - Started in 2010, ongoing
 - Task 12 on NDE was funded by NRC

Task 1: Verification of Allowable Stresses in Section III, NH with Emphasis on Alloy 800H and Grade 91

- Rationale
 - Longer design lives at higher temperatures to support HTGR
 - Discrepancies in 800H allowable stresses and differences in allowables for Grade 91 between RCC-MR and NH/II-Part D in thick sections

Results

- Alloy 800H base metal values for Sy & SU established to 900 C, SRmin values to 600,000 hr and 900 C
 - 1 % strain controlled long time allowable stress at 850 and above, testing required
- Alloy 800H weldments require testing above 750 C for long times
- $-\,$ Grade 91 base metal data support allowable stresses to 600,000 hr and 650 C $\,$
- Grade 91 weldments should adopt Section II report on SRFs
- Next step
 - Use data in Task 13 for Code approved allowable stress values

Task 2: Regulatory Safety Issues in Subsection NH and for Very High Temperatures for VHTR & GEN IV

- Rationale
 - Avoid licensing delays due to unresolved concerns
 - NRC has not endorsed NH
- Results
 - Creep crack growth in weldments and notches, inelastic analysis, and environmental effects are primary issues identified in prior reviews
 - Time and temperature extension and additional concerns identified
 - How NH and Codes Cases address NRC issues was summarized
 - Materials behavior, creep-fatigue and environmental effects
 - · Structural integrity of welds
 - · Development and verification of simplified design analysis methods
 - Verification testing
- Next step
 - Used to identify follow-on tasks

Task 3: Improvement of Subsection NH Rules for Grade 91 Steel – (Negligible Creep and Creep Fatigue)

- Rationale
 - Current NH criteria for negligible creep and creep-fatigue damage in Grade 91 overly conservative and too restrictive for realistic design application
- Results
 - Negligible creep
 - Criteria for cyclically hardening materials, e.g. austenitic stainless steel, inappropriate for cyclically softening material, e.g. Grade 91
 - Detail modifications proposed & further testing
 - Creep-Fatigue
 - ASME design procedure is very conservative
 - Proposed modifications
 - Reduce safety factor for creep damage calculation with elastic analysis (k' = 0.9) Incorporated in 2008 Addenda
 - Additional modifications and testing
- Next step
 - Proposed modifications evaluated in Task Force on Creep-Fatigue &Task Force on Negligible Creep
 - Data & recommendations used in Task 10

Task 4: Updating of ASME Nuclear Code Case N-201 to Accommodate the Needs of the HTGR

- Rationale
 - CC N-201 (Elevated temperature core support structures) last updated prior to NH
 - Limited materials selection
 - HTGR core support structures expected to see very high temperatures

Results

- Questionnaire on metallic core support structure design and requirements
 - Normal and transient temperatures benign and current design methods applicable
 - Additional material needs
 - 316FR/316LN, 321 & 347, Grade 91 and Inconel 718
 - life extension to 60yr
- Comprehensive line by line review performed against NG and NH
 - CC N-201 revised to correct errors and omissions
- Next step
 - CC revisions approved in SG-ETD final edit in WG-CSS

Task 5: Collect and study Available Creep-Fatigue Data and Procedures for Grade 91 Steel and Hastelloy XR

- Rationale
 - Significant data on Grade 91 exists in Japan
 - Hastelloy XR used successfully in the Japanese HTGR
- Results
 - Grade 91
 - Numerous data collected
 - NH procedure significantly conservative compared to test data and RCC-MR and Japanese FBR procedures
 - Potential improvements to NH identified and evaluated
 - R&D needs identified
 - Hastelloy XR
 - Available data collected
 - Elevated temperature response characteristics similar to austenitic SS
 - Material models for inelastic analysis were developed for HGTR IHX
- Next step
 - Data and assessments used in Tasks 3 and 11

Task 6: Operating Condition Allowable Stress Levels

- Rationale
 - Minimum Stress to rupture values in NH not consistent with Section II, Part D

Results

- Inconsistencies confirmed for current NH materials except Alloy 800H
- Comprehensive data collection and evaluation for NH materials
 - Current data support 304H and 316H allowable stress values to 1200°F
 - Concern for low creep ductility
 - 800H data support extended stress values to 800 850°C
 - Grade 91 data support 500,000 hr below 600°C and 650°C up to 100,000 hr
 - Data for annealed 2.25Cr-1Mo support values to 1200°F
- Prioritized table of suggested action to revise allowable stress to accommodate HTGR needs

Next step

Implement recommended actions in follow-on task to develop allowable stresses for code committee action

Task 7: ASME Code Considerations for the Intermediate Heat Exchanger (IHX)

- Rationale
 - IHX exposed to full gas outlet temperature at primary to secondary interface
 - Potential use of compact micro channel heat exchangers with unique design features raises concerns
- Results
 - Conventional and compact experience reviewed
 - Tubular Helical Coil Heat Exchanger most mature
 - Compact HX less mature but potential cost and volume savings
 - 617 most promising material followed by 230, XR and 800H
 - Recommended Code approaches defined
 - IHX should be considered non-safety related component
 - Current C & S basically OK for shell and tube
 - Difficult ISI suggests periodic replacement of compact IHX
 - Extensive review of ASTM Standards development
- Next step
 - Implement recommendations in a draft code case

Task 8: Creep and Creep-Fatigue Crack Growth at Structural Discontinuities and Welds

- Rationale
 - Top NRC concern
 - NH has design factors and procedures for weldments and structural discontinuities but not a quantitative assessment of crack growth

Results

- Current crack growth methodologies assessed for applicability to design and IS
- UK R5 approach selected based on development status and current use
- Theoretical limitations identified
- Design procedure described
- Next step
 - Extensive discussion in SG-ETD
 - Recommended for use with ISI for inspection intervals and flaw evaluation
 - Applicability for HTGR materials and conditions needs to be established
 - Potential joint BPV SC-III & XI Task Force

Task 9: Update and Improve NH – Simplified Elastic and Inelastic Design Analysis Methods

- Rationale
 - Current NH rules based on 70's 80's technology
 - Advances in computing technology
 - Advances in understanding of creep behavior and failure mechanisms

Results

- Comprehensive review and comparison of elevated temp. design codes and fitness for service manuals
- Recommended improvements to NH
- Elastic analysis
- Reference stress methods
- Limit load, shakedown, and ratcheting analysis
- Recommended available benchmark problems and key feature tests

Next Step

- Recommended approaches currently under review in SG-ETD

Task 10: Update and Improve NH – Alternative Simplified Creep-Fatigue Design Methods

- Rationale
 - Phase | Tasks 3 & 5 identified a number of deficiencies in current methodologies
 - New methods have been developed
 - Identified as an NRC concern

Results

- Creep-fatigue methodologies including damage based, strain based, modified strain range partitioning and methods not separating creep and fatigue damage evaluated with Grade 91 data from Tasks 3 & 5
- All methods correlate reasonably with short term data, differences in long term extrapolation
- Near term: incorporate key features in current time fraction approach
- Generally currently deployable
- Long term: incorporate SMT methodology which requires signification test & validation

Next step

- Review and implementation in Task Force on Creep-Fatigue Criteria
- Apply methodology to assess other materials of interest

Task 11: New Materials for NH

Rationale

- Additional material options in NH & CC N-201 needed to address unique VHTR requirements, e. g. very high temperatures and environmental effects
- Results
 - Comprehensive review of prior design studies and operating conditions
 - Requirements for codification reviewed in detail
 - Candidate alloy characteristics discussed
 - 100,000 hr creep rupture strength for 7 candidate alloys plotted vs. temperature
 - In descending order at 800°C: 230, 617, 625, 556, NF 709, 120, X, 811, 810
 - Hastelloy XR covered in separate report
 - Though 617 is stronger in air than XR they are comparable in HTGR He which doesn't affect XR
 - Testing requirements and cost estimates based on review of NGNP IHX Materials R&D Plan for Alloy 800H and Alloy 617
- Next step
 - Primarily intended for project use

Task 13: Recommend allowable stress values

- Benefit
 - Extends the time and temperatures for which allowable stresses are provided to be compatible with NGNP/GEN IV needs.
 - Specific stakeholder interest in 800H
- Key Points
 - Develops draft code rules for extending 800H limits
 - Provides allowables at time (60yr) and temperature (850°C) compatible with NGNP/GEN IV needs for normal operation
 - Provides higher temperature, shorter time allowables for off normal events
 - Results in code formatted submittals to applicable committees
- Status
 - Ongoing

Task 14: Corrections to stainless steel allowable stresses

- Benefit
 - Corrects recently identified problems with allowable stress values that impact ongoing design studies.
- Key Points
 - Task 6 identified errors and potential limitations on current SS stress values in NH
 - Some heats of 304 & 316SS had creep rupture lives below current NH values, particularly above 1200F (650°C)
 - NIMS (post NH) data
 - Identify restrictions to preclude bad heats or
 - Delete impacted allowables
 - Results in code formatted submittals to applicable committees
- Status
 - Ongoing

DIVISION 5, CONSTRUCTION RULES FOR HIGH TEMPERATURE REACTORS

- Need
 - Renewed interest and acceptance of nuclear fission as a source of energy on a global level
 - High temperature reactors are being considered by various countries and companies for future reactor applications
 - Many efforts to collect and develop data for use in high temperature reactor applications and in the development of appropriate Codes and Standards
 - Some current rules have not been properly maintained and are out of date
 - Need a new Division to cover construction rules for components in high temperature reactors

DIVISION 5 SCOPE

The rules of Division 5 constitute the construction requirements associated with components and structures used in high temperature gas-cooled reactors and liquid metal reactors

DIVISION 5

Subsection HA — General Requirements

- Subpart A Metallic Materials (NCA)*
- Subpart B Graphite Materials (New)
- Subpart C Composite Materials (New)
- Subsection HB Class A Metallic Pressure Boundary Components
 - Subpart A Low Temperature Service (NB)
 - Subpart B Elevated Temperature Service (NH)
 Mandatory Appendix HBB-I (CC N-499)
- Subsection HC Class B Metallic Pressure Boundary Components
 - Subpart A Low Temperature Service (NC)
 - Subpart B Elevated Temperature Service (CC N-253)

Two Safety Classes – Class A and Class B ()* Code Basis

Subsection HF -- Class A and B Metallic Supports

- Subpart A Low Temperature Service (NF)
- Subsection HG Class A Metallic Core Support Structures
- Subpart A Low Temperature Service (NG)
- Subpart B Elevated Temperature Service (CC N-201)

Subsection HH — Class A Non-Metallic Core Support Structures

- Subpart A Graphite Materials (New)
- Subpart B Composite Materials (New)

SAFETY CLASSIFICATIONS

Class A - "safety-related" Class B - "non-safety related with special treatment"

- Reflect the risk-based approach derived from safety criteria established for high temperature reactor plants
- Remaining items not in these two classifications shall satisfy requirements of other appropriate non-nuclear codes and standards

FUTURE IMPROVEMENT OF DIVISION 5

- An Ad-Hoc project team within ASME BPV III, Working Group on Liquid Metal Reactors (LMRs) was formed to establish strategic goals, structure and scope, and execution plan for LMRs in Div 5
- Two white papers were drafted
- The purpose was to develop a consensus on the path forward to provide ASME Code rules for the construction of the next generation LMRs which also includes LMR-based advanced small modular reactors (SMRs)
- Near Term LMR White Paper focused on the 2011, 2013 and 2015 Code editions
- Long Term LMR White Paper focused on the 2017, 2019 and beyond editions

NEAR TERM LMR WHITE PAPER OVERVIEW

- '11, '13 & '15 Code Editions
 - Start approval cycle in 1 3 years
- Conventional scope

- Based on current, '11, Div 5 format
 - References other sections
 - Includes Code Cases
- Two classes of construction, A & B

Highest priority items	Next priority
mynest phonty items	Next priority
Correct and extend allowable stresses	Update and revise CC N-253 etc.
Resolve 2 vs 3 component classification issue	Add 316LN/FR
Inelastic analysis procedures and models	Incorporate creep-fatigue crack growth in Section XI, Div 3
Improvements to creep-fatigue and negligible creep • Emphasis on Mod9Cr	Add exemption rules for creep-fatigue evaluation
Add reference stress for wall sizing	Add exemption rules for creep-fatigue evaluation

LONG TERM LMR WHITE PAPER OVERVIEW

Develop specific recommendations for new, all temperature, stress classification free methodology	

TASK GROUP ON INELASTIC ANALYSIS METHODS

- Develop non-mandatory NH appendix on inelastic analysis methods for current NH materials
- Envision having draft code rules in place by end of 2013

Approach

- Use NE F9-5T, "Nuclear Standard, Guidelines and Procedures for Design of Class 1 Elevated Temperature Nuclear System Components" (developed by DOE for CRBR vendors) as guideline
- Use currently available state-of-the-art models
 - Models might not be perfect
 - New development will be kept to a minimum
- Use currently available specimen test data, to the extent possible
 - Experiments and testing by Task Group are out-of-scope
- Data source for material models
 - Literature
 - Contributions from vendors, international agencies, US national labs - all on the basis of supporting ASME code committee work
- Perform verification analyses, to the extent practical

Contents of non-mandatory appendix

- Part A
 - 3D unified viscoplastic constitutive equations for current NH materials
 - 304, 316 stainless steels, 9Cr-1Mo-V, 2¼ Cr-1Mo, Alloy 800H, Alloy 718 (bolting)
 - Material parameters for each material, covering NH temperature range, at every 50C
 - Will consider the inclusion of 1D equations, if a need is identified
 - Potential Issues
 - Could lead to a need for updating isochronous stress-strain curves for consistency
- Part B
 - Provide guidance on inelastic finite element analyses
 - Example problems on how to use results from inelastic finite element analyses to satisfy NH deformation limits



High Temperature Reactor Materials

Licensing and Regulatory Issues

February 17 , 2011

Saurin Majumdar, Ken Natesan Argonne National Laboratory

Summary of Licensing Issues for Clinch River Breeder Reactor

- NRC/ACRS conducted a licensing review (NUREG-0968) of a construction permit for CRBR in the 1980's
- Construction permit was supported with the stipulation that numerous technical issues be resolved prior to requesting an operating license
- The R&D program that was agreed to was not completed
 - Materials
 - Design analysis
 - Weldment integrity
 - Creep ratcheting
 - Creep cracking
 - Creep/creep-fatigue damage evaluation procedure



Major Concerns for CRBR Licensing: Background

- Up until now, the maximum temperature experienced by the LWR industry is ~350°C
 - Primary components designed by ASME Code Section III, Subsection NB
 - Section III, Subsection NB and Section XI have been approved by NRC
 - Time/temperature-dependent deformation and damage not major concerns
 - Significant industry experience in material/design/fabrication of LWR components
 - Significant industry experience in in-service inspection techniques
- Reactor outlet temperature for CRBR was 995°F (535°C)
 - Austenitic stainless steels and low-alloy ferritic steels
 - Time/temperature-dependent deformation cannot be ignored
 - Time/temperature-dependent damage cannot be ignored
- Based on the review of the material submitted by the applicant, NRC listed nine areas of concern


Major NRC Concerns for CRBR Licensing

- Weldment Cracking
- Notch weakening
- Material property representation for inelastic analysis
- Steam generator tubesheet evaluation
- Elevated temperature seismic effects
- Elastic follow-up in piping
- Creep-fatigue evaluation
- Plastic strain concentration factors
- Intermediate piping transition welds



NRC Concern - Weldment Cracking

- Identified as the most significant concern
- Early crack initiation in HAZ
- Variation of material properties within the weld creep damage
- Effect of cycle rate, hold time on propagation of long shallow cracks in HAZ
- Effect of enhanced creep in uncracked ligaments of cracks due to residual stress and thermal cycling on crack stability and creep crack growth
- These effects must be evaluated to determine the safety margins of weldments in elevated temperature service.
- Effect of long-term aging on creep-fatigue damage
- Effect of loading sequence on creep-fatigue behavior



NRC Concern - Notch Weakening

- Cracking at notches and other discontinuities due to stress-strain concentration effect and exhaustion of local ductility
 - Subsection NH (Code Case N47) ignores notches for load controlled stresses
 - They are considered for strain-controlled loading and creep-fatigue
- Main concern was that the creep-fatigue limits are set on the basis of tests on smooth specimens and, therefore, do not consider stress gradient near notches
- Also, concerned about loss of ductility due to long-term cyclic and monotonic loading.



NRC Concern - Material Property Representation for Inelastic Analysis

- NRC was concerned about lack of verification of computer programs used for conducting inelastic analyses
- Concerned about impact of new technology developments on safety
 - Safety margins that worked well with conservative simplified analyses may be eroded by the use of more accurate analysis techniques
 - Concerned with using average properties rather than minimum properties for inelastic analysis
 - Does the safety factors adequately cover departure from average behavior
 - Is creep rupture damage calculated conservatively in the presence of hardening due to cyclic loading or fabrication processes?



NRC Concern - SG Tubesheet Evaluation

- The major concern was the assurance of adequate tubesheet design life
 - Are the calculations adequate to account for the highly localized inelastic stresses in the outer row of ligaments due to thermal gradients between the perforated and unperforated regions?
 - The use of equivalent solid plate may not be applicable to tubesheets with large thermal gradients
 - Detailed inelastic analysis of mechanically and thermally interacting tubes, tubeholes and ligaments for evaluating ratcheting and creepfatigue damage is highly complex



NRC Concern - Elevated Temperature Seismic Effects

- Can creep strain accumulation or creep-fatigue damage be enhanced by seismic events?
 - Seismic events may change the residual stress field by short-term primary loading
 - Relaxation of high residual stresses following a seismic event may enhance accumulated creep strain (ratcheting) and creep-fatigue damage
 - Sequence effects may be important at elevated temperatures



NRC Concern - Elastic Follow-up in Piping

- The concern was related to categorizing thermal expansion stresses as secondary for evaluating hot leg piping
- Under creeping condition, relaxation of stresses in highly stressed areas may cause additional cyclic strain and strain accumulation due to elastic follow up.
 - Subsection NH recommends that thermal stresses with large elastic follow up be considered as primary, but does not define when elastic follow up is large



NRC Concern - Creep-Fatigue Evaluation

- CRBR project changed the Code damage calculation procedure for austenitic stainless steel non-safety components by considering compressive holds as less damaging than tensile holds
- Second concern was related to the extrapolation of high cycle fatigue curves in Code Case N47 beyond 10⁶ cycles using a slope of -0.12 for load controlled situations



NRC Concern - Plastic Strain Concentration Factors

- The concern was related to using the plastic strain concentration factor as unity for ranges of primary plus secondary stress intensity less than 3S_m, whereas plastic strain will occur when the locally concentrated stress range exceeds 2S_v
 - $-\,$ Also, the multiplier for strain concentration on the weaker side of a joint or interface was not included in the formulas for $K_{\rm e}$



NRC Concern - Intermediate Piping Transition Welds

- The IHX transition weld reference design was a tri-metalic joint of Type 316H stainless steel, Alloy 800H and 2-1/4Cr-1Mo steel
 - The concern was related to the variability of material properties between the different materials
 - Possible increase of creep rupture damage resulting from the higher yield properties produced by hardening in a multipass welding process.



Summary CRBR Licensing Review

Major NRC concerns were related to treatment of discontinuities

- Weldments
- Notches
- Tubesheets
- Areas where ASME Code treatment was lacking



Current Safety Issues for Structural Design of VHTR and Gen-IV Reactors

- Evaluate Materials and design bases in ASME Code Case N-47 (NUREG/CR-5955, 1993)
 - Identify issues that must be resolved in order to avoid creep rupture, creep-fatigue, creep ratcheting and creep buckling
 - Advanced LMRs, gas-cooled reactors and CANDU reactors
 - 23 issues were identified. Most important issues are
 - Lack of materials design allowable data for 60yr life
 - Degradation of properties long-term radiation, corrosion at high temperatures
 - Lack of validated thermal striping design methodology
 - Reliable creep-fatigue and ratcheting design rules
 - Lack of validated weldment design methodology
 - Lack of flaw assessment procedure
 - Lack of inelastic deign procedure for piping
 - Lack of validation of notch weakening effect



Current Safety Issues for Structural Design of VHTR and Gen-IV Reactors (Cont'd)

- Pre-application safety evaluation of power reactor innovative small module (PRISM) LMR (NUREG-1368,1994)
- NRC concerned primarily with
 - inelastic and limit analyses
 - Extrapolation of Code Case N47 design allowables from 34 to 60 yrs.
 - Environmental issues related to stress corrosion, flowing sodium effects and irradiation embrittlement
 - Weld between core support structure and the RV
 - Neutron Embrittlement for RV with 60 yr design life



Review and Assessment of Existing Design Codes for HTGRs (NUREG-CR/6816, 2003)

- Most of the materials needed for HTGR (Alloy 617, 9Cr-1Mo-V*, Hastelloy X) are not included Subsection NH
- The Code materials that are acceptable for HTGR need to have their upper temperature limit extended to 850°C
- Subsection NH rules are written for materials with classical creep curve (primary, secondary and tertiary). HTGR materials do not show such a behavior
- Advanced unified constitutive equations (no distinction between creep and plastic strain) are needed for the HTGR materials
- The effects of impure helium on fatigue and creep-fatigue properties are needed
- Draft Code Case for Alloy 617 needs to be completed
- Need a more suitable damage theory for creep-fatigue than linear damage rule



Materials Behavior in HTGR Environment (NUREG/CR-6824, 2003)

- Among the three materials for high temperature application in HTGR -Alloys 800H and 617 and Hastelloy X - only Alloy 800H is code certified up to 760°C and 34 yrs.
 - Substantial database exists for Alloys 800H and 617
 - Limited database for Hastelloy X
- Need data on effects of contaminated helium (at pressure) on properties
- Structural alloys can be corroded by gaseous impurities in helium



Design Features and Technology Uncertainties for NGNP (INEEL/EXT-04-01816, 2004)

- Few choices exist for metals for use in VHTR design conditions
- New materials such as, ODS alloys, refractory metals or ceramics need to be developed for long range application at ~1000°C
- For near-term applications, a maximum metal temperature of 900°C was recommended



Framework for Development of Risk-Informed Alternative to 10 CFR Part 50 (NUREG-1860, 2006)

- Report documents a technical basis to support the development of a riskinformed and performance-based process for licensing of future reactors
 - Provides broad guidance for safety review
 - Does not provide guidance for codes and standards
 - The evaluation approach relies heavily on PRA
 - Does not imply that structural design codes be based on PRA
 - Code assessment results should be in a form that allows PRA of individual components.



How Regulatory Issues are Addressed in ASME Code

- A new Division 5 of the ASME code has been established to handle HTGRs and LMRs (GEN IV Systems)
 - Materials creep behavior, creep-fatigue, environment effect
 - Improve structural analysis methods for cyclic loading at high temperatures
 - Negligible creep curves
 - Structural Integrity of Welds
 - Allowable life and ductility limits are reduced at welds
 - Need to account for material variability within the weld and HAZ
 - Development and verification of simplified design analysis methods
 - Need new validated methods for HTGR applications
 - Verification testing
 - Will need component testing to validate VHTR designs



ASME Code - In-Service Inspection Issues

- A special Working Group has been set up to look at ISI issues (T. Lupold is a member)
 - Developing requirements for HTGRs
 - Reliability Integrity Management program (RIM)
 - risk based program combined with some deterministic inspection requirements
 - the designer/owner of the plant has to establish reliability requirements for the systems/components
 - ISI established to meet those requirements
 - The idea is to change the design during the design phase if the reliability requirements cannot be met by the available inspection techniques
 - RIM is still in a developmental stage
 - Preliminary version is available in ADAMS



Research Needed to Address Regulatory Issues for VHTR

- Material creep behavior, creep-fatigue and environmental effects
- Structural Integrity of Welds
- Development/verification of simplified analysis methods
- Verification testing of components
- Development of ISI techniques









History of LBB

Early application of LBB in regulatory environment

Updates in technology since original SRP 3.6.3

Effects of active degradation (PWSCC) on LBB – Technical and regulatory

xLPR(extremely low probability of rupture) summary and Regulatory plan for LBB





Generally, LBB is the demonstration that a postulated flaw will leak and be detected, before catastrophic failure

or....

Specifically, LBB is the application of fracture mechanics technology to demonstrate that high energy fluid piping is very unlikely to experience doubleended ruptures or their equivalent as longitudinal or diagonal splits

10/11/2012

History of LBB



- Earliest approach by Irwin in 1961 for an axial flaw in pipe or pressure vessel
- Linear elastic
- Crack driving force in radial direction is greater than axial direction for 2a>2B

 $K_{1s} \ge \sigma_{ys} \sqrt{\pi (B + r_p^*)}.$ By taking $r_p^* = \sigma^2 a/2\pi \sigma_{ys}^2$ with a = B, and $\sigma = \sigma_{ys}$, it follows that: $K_{1c}^2 \ge (\pi + \frac{1}{2})B\sigma_{ys}^2 \quad \text{or} \quad \frac{K_{1c}^2}{B\sigma_{ys}^2} \ge \pi + \frac{1}{2}.$

History of LBB



Battelle work by Duffy, Eiber, Kiefner and Maxey assumed ductile fracture behavior of axial thin-wall gas pipelines (1960's), then nuclear pipe for USAEC (late 1960's and early 1970's)



Early Application



The U.S. Code of Federal Regulations (10CFR50) states that systems and structures shall be designed to accommodate accidents and postulated ruptures

Pipe-whip restraints, jet impingement shield barriers are needed

General Design Criterion 4 (GDC-4) allows the use of analyses, approved by the NRC, to demonstrate extremely low probability of pipe rupture for removal of protective hardware

In 1984, leak-before-break (LBB) was accepted as an analytical procedure for demonstrating extremely low probability of rupture events

10/11/2012





In 1984, a five volume report was published on a review of the NRC requirements in the area of nuclear piping

Volume 3 of this document reviews the evaluation of potential to pipe breaks

Gives recommendation for application of LBB in the NRC licensing process

The conclusions and recommendations from this volume were implemented into Standard Review Plan on LBB (3.6.3) in 1987

SRP 3.6.3



The SRP is applicable to Class 1 piping with the following caveats:

Must be applied to entire system

<u>Cannot be used for piping susceptible to SCC</u>, erosion-corrosion, creep, etc. (i.e., no degradation mechanisms that can cause long surface cracks)

Pipes with weld overlays cannot be considered (removed in later version)

Systems with a history of fatigue cracking cannot be considered

Pipe with likely water hammer are not considered

Piping systems with possible brittle fracture are not considered

Indirect failure must be shown not to cause rupture

SRP 3.6.3 was revised in 2007 to include Alloy 690/52/152 and overlays

"Alloy 690/52/152 material is not currently considered

Steps in SRP 3.6.3

vg*





Defense in Depth



ECCS is designed to handle break in the largest piping in RCS

ASME Section III and screening criteria in SRP3.6.3 provide assurance of extremely low probability events

LBB analyses provide defense in depth against rupture or large break opening to ensure confidence that the probability of pipe rupture is extremely low

US Accepted LBB



Accepted LBB applications in U.S. (All PWRs)

<u>SYSTEM</u>

NUMBER OF APPROVALS

Primary Coolant Loop (Hot & Cold Legs)

7**6**

Pressurizer Surge Lines

14

Safety Injection Accumulator Lines

11

Residual Heat Reversed Susceptibility to IGSCC Not Adequately Addressed Few requests for LBB Safety Injection Charging Lines

Recent Research Since Original SRP 3.6.3



Factors that affect leakage size cracks

Crack morphology

Restraint of pressure-induced bending

Welding residual stress

Material Issues

Cyclic Effects Dynamic Strain aging PWSCC testing – Alloy 82/182 and Alloy 52/152



Recent Research Since Original SRP 3.6.3



Factors that affect leakage size cracks

Crack morphology

Restraint of pressure-induced bending

Welding residual stress

Material Issues

Cyclic Effects Dynamic Strain aging PWSCC testing – Alloy 82/182 and Alloy 52/152



Crack Morphology Parameters

Using ISCCC or PWSCC morphology, leaking crack length at same leak rate can by 89% longer than when air fatigue is assumed



S.NRC

200

225

250

lea king Length of 0 Ω 25 50 75 100125150 175 Air fatigue crack SCC Alloy 82/182 crack Length of leaking air-fatigue crack, mm Current leak rate analyses have limited validation with SCC and thus have large uncertainties

Welding Residual Stress



Through thickness welding residual stresses can affect the crack opening area

> Crack-face closure due to the through -wall bending residual stresses (thinwall pipes),

Non-elliptical opening (assumed in many leak-rate calculations), and

Through-wall residual stress distribution being a function of weld preparation geometry, total number of passes, start-stop locations, and the bulk heat input.



Dissimilar Metal Welds



Most stability calculation for cracks in weld were developed for base metal

DM weld connects stainless and carbon steel with nickel-based welds

Modification of analyses needed

Used FE analyses for development

Used experiments for validation

10/11/2012




LBB Regulation Guide



Technical basis for LBB Regulatory Guide (NUREG/CR-6765) was published in May 2002 Suggested tiered approach to LBB Draft Regulation guide followed

With the occurrence of PWSCC in previously approved LBB lines, LBB Regulation Guide was put on hold

10/11/2012

PWSCC and LBB



SRP 3.6.3 stipulates that no active degradation is allowed

LBB analyses assumes idealized through-wall crack for leakage and stability calculations – Flaws could grow non-idealized

Current LBB analyses may be non-conservative for this type of behavior

10/11/2012



PWSCC Experiments





On average Alloy 52/152 crack growth is ~ 100 times slower than Alloy 82/182 Testing of Alloy 52/152 still underway!

10/11/2012

Regulatory Impact



ent reques

Due to PWSCC in susceptible butt welds, the industry developed and released MRP-139, which described the mitigation and inspection efforts to mitigate PWSCC

NRR released RIS2008-25, which stated that MRP-139 provided adequate protection of public health and safety for addressing PWSCC in butt welds for the *near term*

NRR released RIS2010-07, which reminded licensees that a weld overlay in a piping system approved for LBB may affect the design basis of the plant and may

Long Term



For the near term, PWSCC in LBB lines with mitigation and augmented inspection are acceptable

For the long term, quantitatively assess compliance with 10CFR50App-A GDC-4. Include the effects of active degradation, mitigation, inspection, leak detection, uncertainty, etc.

RES is developing the xLPR modular probabilistic fracture mechanics code in cooperation with EPRI through an addendum to the Memorandum of Understanding

xLPR Timeline





xLPR Technical Flow



Loads



Benefits of xLPR



Quantified solution to LBB issue

Regulation guide

Update to SRP3.6.3

Fully QA'ed modular probabilistic fracture mechanics code for reactor pressure boundary integrity

LBB including evaluation of mitigation for DM welds

Research tool for prioritization

- TBS 50.46a
- Risk informed ISI
- GSI 191

Easily adaptable to other applications

CRDM ejection probabilities

RPV

Path Forward



e for LBB

Version 2.0 Development underway

Ongoing meetings ACRS meeting - March 2012 (yearly updates to subcommittee) NRC and EPRI Management (as needed) External reviews (annually) Internal reviews (bi-annually)

Version 2.0 release – End 2013

Technical basis and Regulator

Questions?







Objectives



- In this presentation, you will learn:
 - What is fatigue?
 - How is fatigue measured?
 - What is environmentally assisted fatigue (EAF)?
 - Why is the NRC interested in EAF?
 - Background where did EAF requirements come from and why?
 - Methodology for EAF assessment
 - Current NRC requirements
 - License Renewal
 - New Reactors
 - Future NRC Requirements
 - What is the ASME Code doing on EAF?
 - Other questions

What is Fatigue?



- ASTM Specification No. E 1823-09a definition*:
 - "The process of progressive localized permanent structural change occurring in a material subjected to conditions that produce fluctuating stresses and strains at some point or points and that may culminate in cracks or complete fracture after a sufficient number of fluctuations."
- There is controversy associated with the definition of fatigue with respect to nuclear power plant design
 - Does "fatigue failure" mean crack initiation? If so, how deep is the "initiated crack"?
 - Or, does "fatigue failure" mean through-wall a crack that leaks?
 - Etc.
- NRC position:
 - "Based on the results of the majority of the test data evaluated, fatigue life is defined as the number of cycles of a specified character that a given specimen sustains before the formation of a specified size crack (i.e., an "engineering crack"). A fatigue cumulative usage factor (CUF) less than unity provides reasonable assurance that no crack has been formed, and that the probability of forming a crack is low."
 - NRC defines an "engineering crack" as an initiated fatigue crack with a depth of ~3 mm.

* A simple and commonly understood example of a repeatedly bending a paper clip.

ved by

How is Fatigue Measured?



 For nuclear plant design, fatigue is "measured" (calculated) using a variable called "cumulative usage factor," or CUF:

$$CUF = \sum_{i} \frac{n}{N}$$

where: n is the applied number of cycles for load i N is the allowable number of cycles for the stress associated with load i

- N is a function of the alternating stress, S_a, applied to a component, and is material dependent (i.e., it is a material property)
- S-N curves ("fatigue curves") are given in Mandatory Appendix I to Section III of the ASME Code for different materials:



What is Environmentally Assisted Fatigue (EAF)?

the AIR design curve.



- The fatigue curves in Section III of the ASME Code were developed from laboratory test data from specimens tested in <u>AIR</u>
- The <u>AIR</u> test data were used to develop design fatigue curves suitable for design:
 - Develop best fit log-log curves for the <u>AIR</u> data for each material type
 - Adjust the best fit curves to account for worst-case mean stress effects using the Modified Goodman relationship
 - Apply factors* of 2 on stress (S_a) or 20 on cycles (N), whichever is more conservative, to develop <u>AIR</u> design curves for each material
- 10.01 More recent laboratory testing of Low-Alloy Steel Δ Ó specimens tested in WATER 200 - 250-250 Temp. (°C). < 150 F_{a} (%) 0.05-1.0 ×0.2 DO√com). ≤0.05 indicated that the AIR design <0.01 Rate (%/s) ≥0.4 0.001 ≥0.005 ±0.005 S (wt %). ≥0.005 curves may not adequately define Strain Amplitude. ASME Code 1000 അറ്റ Mean Curve fatigue life for materials exposed to RT Ar WATER environments: ASME Design Curve Note how some of the points 0.1 for tests in WATER fall below

101

 10^2 10^2 10^4 Fatigue Life (Cycles)

 Factors to account for data scatter, size effects (i, large power plant components), surface finish, a 10⁶

 10^{5}

cimens vs

Why is the NRC interested in EAF?



- Around 1990, the NRC initiated a Fatigue Action Plan:
 - Focus on operating plant fatigue to address several outstanding technical concerns
 - Arose from early license renewal activities in the 1980s that uncovered potential technical issues for all operating plants
 - Four basic issues identified:
 - Older vintage plants
 - Environmental effects on fatigue curves
 - Generic Issue 78, "Monitoring of Design Basis Transient Fatigue Limits for Reactor Coolant Systems"
 - To determine whether transient cycle monitoring is necessary at operating plants
 - Actions when CUF exceeds 1.0
 - No current regulatory position
 - Flaw tolerance analysis

Why is the NRC interested in EAF? (cont'd)



- Completion of Fatigue Action Plan (SECY-95-245):
 - Simplistic cycle counting not a good measure of CUF
 - Required no immediate action by nuclear plant operators to address environmental effects
 - Concurred that essentially all locations could be qualified by monitoring or alternate analysis
 - Alternate risk studies were performed by Nuclear Regulatory Research (NUREG/CR-6674, "Fatigue Analysis of Components for 60-Year Plant Life," June 2000)
 - Showed that a fatigue failure of piping systems is not a significant contributor to core damage frequency
 - Leakage probability increased significantly after 40 years of operation
 - Based on these conclusions, the U.S. NRC could not justify requiring backfit of environmental data to operating plants

Why is the NRC interested in EAF? (cont'd)



- Completion of Fatigue Action Plan (SECY-95-245): (cont'd)
 - However, effects would have to be considered for some components for license renewal to address leakage concerns
 - Documented as Generic Safety Issue (GSI) 166, "Adequacy of Fatigue Life of Metal Components"
 - "The staff will consider, as part of the resolution of GSI-166, ...the need to evaluate a sample of components with high fatigue usage, using the latest available environmental fatigue data.."
 - Renumbered to GSI-190, "Fatigue Evaluation of Metal Components for 60-Year Plant Life" for license renewal
 - Renumbered to eliminate 40-year issue and only focus on 60-year issue



Methodology for EAF Assessment



- Initially, the NRC reviewed two methods for incorporating LWR effects; the second method was adopted:
 - 1. Develop new environmental fatigue curves
 - 2. Use of an environmental correction factor, $\rm F_{en}$
- F_{en} is defined as the ratio of fatigue life in air at room temperature to the fatigue life in water <u>at the service temperature</u>:

$$F_{en} = N_{air}/N_{water}$$

• F_{en} is multiplicative to the calculated fatigue usage in air:

$$U_{en} = U_1 F_{en,1} + U_2 F_{en,2} \dots U_n F_{en,n}$$



Methodology for EAF Assessment (cont'd)



- Carbon steels:
- Low-alloy steels:

 $-S^* = 0.001$

 $S^* = 0.015$

 $S^* = S$

 $- T^* = 0$

 $- 0^* = 0$

 $F_{en} = \exp(0.702 - 0.101 \text{ S}^{*}\text{T}^{*}\text{O}^{*}\text{R}^{*})$ $(S \le 0.001 \text{ wt.}\%)$ $(S \le 0.015 \text{ wt.}\%)$ (S > 0.015 wt.%) $(T < 150^{\circ}C)$ $T^* = (T - 150)$ $(150 < T \le 350^{\circ}C)$ $(DO \le 0.04 \text{ ppm})$ $(0.04 < DO \le 0.5 ppm)$ $O^* = \ln (DO/0.04)$ $O^* = \ln(12.5)$ (DO > 0.5 ppm)

 $F_{en} = \exp(0.632 - 0.101 \text{ S}^{*}\text{T}^{*}\text{O}^{*}\text{R}^{*})$

- $R^* = 0$ (R > 1%/s) $R^* = ln(R)$ $(0.001 \le R \le 1\%/s)$ $R^* = \ln (0.001)$ (R < 0.001%/s)
- Note that there is an F_{en} of ≈ 2 even at temperatures below 150°C as very high strain rates; this seems inconsistent with any meetad proposed for environmental fatigue

Methodology for EAF Assessment (cont'd)



- $F_{en} = \exp(0.734 T' O' R')$ Stainless steels: $(T < 150^{\circ}C)$ - T' = 0T' = (T - 150)/175 $(150 < T \le 325^{\circ}C)$ T' = 1 $(T \ge 325^{\circ}C)$ (all DO levels) - O' = 0.281 - R' = 0(R > 0.4%/s) $(0.001 \le R \le 0.4\%/s)$ R' = ln (R/0.4)R' = ln (0.001)(R < 0.001%/s)
- Again, an F_{en} of ≈ 2 even at temperatures below 150°C and very high strain rates seems inconsistent with any mechanism proposed for environmental fatigue



Methodology for EAF Assessment (cont'd)



- Ni-Cr-Fe steels:
 - T' = T/325 T' = 1
 - O' = 0.09 O' = 0.16
 - R' = 0
 R' = ln (R/5.0)
 R' = ln (0.0004/5.0)

 $F_{en} = \exp(-T' O' R')$ (T < 325°C) (T ≥ 325°C) (NWC BWR water) (PWR or HWC BWR water) (R > 5.0%/s) (0.0004 ≤ R ≤ 5.0%/s) (R < 0.0004%/s)



Current NRC Requirements – License Renewal



- GALL Report (NUREG-1801, Chapter X.M1)
- NUREG/CR-5704 for stainless steels and NUREG/CR-6583 for ferritic steels

(may also use new reactor requirements – next slide)



Current NRC Requirements – New Reactors



14

- Regulatory Guide 1.207
- Supporting technical basis documented in NUREG/CR-6909





Future NRC Requirements



- Revision to RG 1.207 and NUREG/CR-6909 currently underway:
 - Will apply to both operating and new reactors
 - Based on 2010-2013 NRC research activities
 - Dual User Need
 NRR-2010-019/NRO-2010-006
 - Both documents expected to go out for public comment in December 2013

	NURL GRUR-19409 Rev 1 ANE -12.60
Effect of LWR Coola on the Fatigue Life o	nt Environments f Reactor Materials
Anna an Comates Generiter (24) Weiter (1996) - 261	
Porphesipe Porphesipe State Cally Record of Algorithm Record Data State (2010 State Charles General) Algorithm – 2000 Office Algorithm Record State State (1919 Record Record State) – 2000 State State (1919 Record Record State)	ar en 19 - 1966.
pary stevens. No permet Manager	
Prepared for Division of Engineering Office of Nuclear Regulatory Research US Nuclear Regulatory Commission Mathington, (CC 20055-000) Mathington, (CC 20055-000) NRC, 2005 Code Mitzhit	
¥.	

What is the ASME Code doing on EAF?



- ASME has been struggling with this issue for more than 10 years
- From Section III, NB-3121, "Corrosion":
 - Material subject to thinning by corrosion, erosion, mechanical abrasion, or other environmental effects shall have provision made for these effects during the design or specified life of the component by a suitable increase in or addition to the thickness of the base metal over that determined by the design formulas. Material added or included for these purposes need not be of the same thickness for all areas of the component if different rates of attack are expected for the various areas. It should be noted that the tests on which the design fatigue curves (Figs. I-9.0) are based did not include tests in the presence of corrosive environments which might accelerate fatigue failure.

What is the ASME Code doing on EAF? (cont'd)



- ASME Section III has published recommended methods for addressing environmental effects in two Code Cases:
 - Code Case N-761:
 - New fatigue design curves for LWR environments
 - Code Case N-792
 - Environmental fatigue correction factor F_{en} method
- NRC has not formally endorsed either Code Case
- Two other Section III Code Cases are under development:
 - Flaw Damage Code Case
 - Similar to ASME Code, Section XI, Nonmandatory Appendix L
 - Strain Rate Code Case
 - Provides methods for determining strain rate for the F_{en} Code Case

Other questions



- 30+ years of industry experience and no thermal fatigue issues*.
 What's the big deal? Why are we imposing this stringent criteria on the industry?
- Is it true that the NRC is not imposing this environmental impact on fatigue uniformly to new reactors?
- Does EAF apply to the RCPB only?
- Is there a difference between BWR and PWR environments? Is it a bounding calculation?



Questions?





7

Containment Review

Thermal-Hydraulic and Source Term Issues



November 10, 2011





NRC regulations for containment - examples:

1. General Design Criterion (GDC) 16 - preserving containment integrity under conditions imposed by postulated LOCAs.

2. GDC 50 - accommodate the calculated P/T without exceeding the design leakage rate

3. GDC 38 – rapid reduction of containment P/T following any LOCA.

4. 10 CFR 50.34(f)(3)(v)(A)(1) - maintain containment integrity assuming H2 burning, as generated from a 100-percent fuel clad metal-water reaction.

5. 10 CFR 52.47(b)(1) – requires a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC)





Large dry: -single or double shell -subatmopheric

Typical PWR designs





FIG. II-2. Vertical section through the main building of an RBMK unit, including the localization zone. [Numbers refer to itemization of equipment and components in Table II-II. Dimensions are given in metres.]


Typical VVER-440



ESBWR Long Term Containment Cooling



SWR 1000 Passive Safety Concept





m**Power**

Traditional PWR versus B&W mPower Reactor



B&W mPower Reactor



7

© 2011 The Babcock & Wicox Company. All rights reserved.



٠

vacuum between Rx and containment

MOIY

α

STOP WILVE

11.04.25

ጷ

FW ACC. (1 OF 2)

- WFW

SPARGER (1 OF 2)

AFW VALVE (1 OF 2)

RX VENT

VALVE 11 OF 2)

- CONDENSATE

SUMP

VALVE (1 OF 2)

SCREEN (1 OF 2)

CONDENCATE





Various vents concepts

PCV Hard Vent

D/W Vent small bore valve

AO

Instrument air (before accident)

Suppression Pool

D/W Vent large

bore valve S-C Veni small bore valve

AO 🛛 🖉

AO



Stock

normal vehiliration duct

excitation-open

PCV Vent Valve

Эмо

S/C Vent large bore valve

Compression As Cylinder bottle

MO D

Stand-by Gas Treatment System

Rupture Disk

Bold Represents

Hardened Vent Line



Containment behavior:

Containment integrity challenged by excessive P / T

Mass and Energy released during an accident THE leading factor

Flow distribution affected by multi-compartmentalization

Long(-er) term effects: ESF heat removal and heat structures

Steam condensation major means for decrease of P / T:

- Suppression pools [hydrodynamic loads] and sprays

Passive feature (b)(4) (need active "help" after "peak" pressure at 72 hours)

Containment thermodynamics (and –hydraulics) involve complex phenomena; requires experimental data to support (semi-)empirical models

Traditional conservative approach: 1-node, Tagami / Uchida correlations - acceptable for active system, may not for passive and/or other advanced designs



Complex Dynamic System Models



Using control volume elements, dynamic response models of complex systems can be developed

•

- Containment
- Reactor vessel
- Core internals
- Steam generators...
- Specialized physics modules account for special features
 - Core heatup
 - Zr oxidation and H₂
 - Fission product release
 - H₂ Burn models
 - Many more













. Кирана А.) – Карала од Геней циру фар соли унимал наринурацију урм ун раконулар (рамира) у урман даруб за Нариј Кар







momentum

Typical sub-compartment analysis

- figure of merit: pressure difference across a structure









MECHANISMS OF CONDENSING HEAT TRANSFER

NOTE: in reality there is some condensation in the atmosphere

Realistic approach: multi-node, BE condensation HTC

Historical conservative approach: single node, Tagami/Uchida, X% revaporization, minimum heat conductors

T / U condensation models based on Sagawa data (1960's)

steady-state (140x300 mm, vertical plate)
LOCA (300, 600, 900 mm cylinder),
problem with interpretation
became known as Uchida and Tagami
(Slaughterback paper, 1970's)

Tagami – "inconvenient", requires iteration (time of Pmax)

Uchida – depends ONLY on air/steam ratio, produces highest peak P, BUT does not apply to superheated conditions

[+]	۲. ۲	Total Heat Transfer Coefficient (W/m ² K)	
		(b)(4)	

| | -| -

1

•

.

۰.

-

SPRAYS

Spray [and suppression pool] most effective ESFs

Results in a rapid pressure decrease

Volume coverage depends on headers / nozzles arrangements

Spray drop size distribution depends on nozzle type [needs test data]

Residence time must be greater than "relaxation time" [i.e. time to reach thermal equilibrium]

Large spray droplet size [e.g. 1000 microns] is a conservative assumption



answer e.g. "Elements of Cloud Physics" H. R. Byers, p. 122 Univ. of Chicago Press Regulatory flow rate based spray condensation model: e.g. NUREG-0772 Page 0198 of 1020

Withheld pursuant to exemption

(b)(4)

of the Freedom of Information and Privacy Act



BWR:

DW similar to PWR

WW very different. Important phenomena:

- Vent clearing
- Pool swell
- Condensation oscillation, chugging
- Associated hydrodynamic loads
- NO established analytical model
- Approval based on various experiments

Hydrodynamic loads

Notes on BWR-related thermal-hydraulic DBA analysis

GE methodology – GESSAR (NUREG-0979):

- basic BWR (MKI, II and III) test data (like PSTF)
- MKIII specific test data (HVT)
- basic models: NUREG-0808 (MKII), and NEDO-20533 (MKIII)
- specific application requires combination of test data and scaling analysis
- -- direct application of MKII/III models inadequate
- -- PSAM (NEDO-21061) for H/D loads (approved based on GE/JAERI test data)
- -- PICSM code with additional correlation for uneven pool slug rise
- -- subscale (2.5) and partial full scale (full scale vents with 2 horizontal) tests
- Containment P/T:
 - -- GESSAR methodology (M3CPT code for MKIII)
 - -- being replaced by TRACG (ESBWR) with vent clearing correction
 - -- for sub-compartment: SCAM code
- 2. NRC independent evaluation based on
- ABWR approved using CONTEMPT-LT28
- currently use of MELCOR, based on CONTAIN models
- CONTAIN qualification report on BWR DBA analysis
- COMPARE / CONTAIN for sub-compartment => MELCOR
- 3. Industry approach (STP)
 - use of GOTHIC, benchmarked on other model and/or available test data





Schematic of the Pool Swell Phenomenon

Important parameters for review:

Timing of vent clearing

Pool swell height

Pool surface velocity

Condensation oscillation loads

Chugging loads

SRV / quencher loads

Page 0207 of 1020

Withheld pursuant to exemption

(b)(4)

of the Freedom of Information and Privacy Act


Review of testing data base AND it's applicability to a given design is **CRUCIAL** for licensing approval of hydrodynamic loads

(b)(4)

(b)(4)

Beyond DBA Challenges

Beyond DBA Challenges

Phases of Beyond Design Basis Accident

- -More that one failure: single failure criteria
- -Loss of coolant => core uncovery
- -Core heat-up => rapid clad oxidation
- -Loss of core coolability => core relocation
- -Challenge to plant integrity: RX, containment, and beyond...

Phenomena relevant to containment:

- until core heat-up similar to DBA
- hydrogen generation leads to deflagration/detonation
- core relocation leads to
- -- steam explosion (in- or ex-vessel)
- -- direct containment heating: dispersion of molten corium
- -- molten core interaction with concrete basemat
- -- vessel missile
- NOTE: for SA phenomena see Dr. Fuller seminar/workshop

Steam Oxidation of Cladding in Fuel Assemblies



$$\frac{dT}{dt} = \frac{1}{mC_p} \left[Q_{ox}(T) - Q_{loss}(T) \right]$$
 heatup rate

- Steam oxidation actually more studied
- Overall behavior quite similar top air oxidation, except...
- Hydrogen is produced in steam oxidation
- Reaction heat reduced compared to air

Core Debris Penetration of the Reactor Vessel Leads to Ex-vessel Releases of Radionuclides

- High Pressure Melt Ejection from Vessel
- Ex-vessel Steam Explosions
- Melt interactions with concrete







Steam Explosion Experiment



THE STEAM EXPLOSION PROCESS



MELT ENTRY INTO WATER TIME: 0



MIXING OF MELT AND WATER TIME 0.15 (s)



INITIATION OF EXPLOSION TIME 0.20 (s)



EXPANSION OF PRODUCTS TIME -0.25 (s)

Direct Containment Heating (DCH) Issues



 Is sufficient melt entrained as vessel depressurizes?

•

Does sufficient heat
transfer, oxidation,
and/or hydrogen
combustion occur to
threaten containment
integrity?

Large-scale High Temperature Melt Interactions with Calcareous Concrete





MCCI modeling

- Corium assumed to be well mixed (default)
- Enhanced effective corium thermal conductivity (10x)
 - produces 1 to 5 MW/m² heat flux
 - Accounts for cracks and fissures
 - Consistent with MACE tests

VANESA MCCI model



Containment Phenomena



Fission Products Release and Transport

[Source Term Analysis]





Elements of Source Analysis

- Release from the Fuel
 - Gap release
 - Fuel degradation release
 - Ex-vessel release
- Transport to the containment
 - Aerosols
 - Vapors
- Behavior within the containment
 - Aerosol physics
 - lodine chemistry
- Revaporization
- Engineered Safety Features

Core Heatup and Fission Product Release



Release from the Fuel

- In-vessel Release
 - Coolant release
 - Gap release
 - Fuel degradation release
 - Air ingression following vessel failure
- Ex-vessel Release
 - High pressure melt ejection
 - Melt interactions with concrete
 - Steam Explosions





Release Phase Timing Definitions – Tie to Calculated MELCOR Results



Figure 1 Models of ART for Transport Behavior of Gaseous Fission Products and Aerosol





Source Term (ST) Definition

amount, timing and composition of FP release

TID-14844: instantaneous of release FP – mostly gaseous iodine

NUREGs -1150 / -1465: Alternative Source Term (AST) - time dependent release of FP; mostly aerosols

Mechanistic Source Term (MST): to be defined (as of 2011)

realistic, scenario-based and design-dependent
 FP release models

The lodine Problem

- Iodine removed from containment by sprays or water pools can partition back into the containment atmosphere I₂(water) ↔ I₂(gas)
- Complicated chemistry involving radiation dose to water
- Can be suppressed by making sumps basic (pH > 7)



Forms of iodine:

Volatile: I₂, CH₃I, Cs₂MoO₄ (gas) Aerosol: CsI (soluble) CsOH (hygroscopic) IO_x (nano)

Volatile iodine removal based on regulatory guidance

Note: PHEBUS experiments show CONSTANT presence of airborne lodine (few percent)

Aerosols removal mechanisms



[CHEMICAL ENGLHEERING, NAV 20, 1968, P.149]



BASIC EQUATION: SMOLUCHOWSKI [1916] [EQUATION FROM NUREG/CR-6189]

Aerosol Dynamic Equation

When the homogeneous aerosol assumption has been made, the aerosol dynamic equation is:

$$\frac{\partial n(v,t)}{\partial t} = \frac{1}{2} \int_0^V K[U,v-U] \ n(U,t) \ n(v-U,t) dU - n(v,t) \int_0^\infty K[U,v] \ n(U,t) \ dU + \frac{S(v,t)}{V} - \frac{R(v,t) \ n(v,t)}{V} - \frac{\partial I(v,t) \ n(v,t)/V}{\partial v}$$

where:

n(v,t) = number concentration of particles having volumes of v to v + dv,

K[U,v+U] n(U,t) n(v-U,t) dU = the rate of formation of particles of volume v to v + dvby coagulation of smaller particles,

$$n(v,t) \int_{0}^{v} K[U,v] n(v,t) dU =$$
 the rate of coagulation of particles of volume v to $v + dv$ to form larger particles.

- K[U,v] = coagulation "kernel" for particles of volume v with particles of volume U.
- S(v,t) = rate at which particles of volume v to v + dv are supplied.

V = containment volume,

$$R(v,t) n(v,t) =$$
 rate of removal of particles from the containment by any of a variety of mechanisms.

 $\frac{dI(v,t) n(v,t)}{\partial v} = \text{rate of growth by condensation of particles from the volume interval of v to v + dv.}$



(b)

Modes of Particle Collection : (a) Impaction and Interception (b) Diffusion

TRANSPORT PHENOMENA IN PIPE



- 1. Gravity
- 2. Turbulence
- 3. Brownian Motion

1

- 4. Thermophoretic
- 5. Vapor Deposition
- 6. inertia(Bends)
- 7. Irregularities
- 8. Re-entrainment

Aerosol depletion mechanisms

* GRAVITATIONAL SETTLING: STOKES VELOCITY

 $C_{u} = C_{unninGHAM} \leq Lip$ $C_{u} = C_{unninGHAM} \leq Lip$ $C_{u} = C_{unninGHAM} \leq Lip$ $C_{u} = C_{unninGM} \Rightarrow f(K_{u})$ $K_{u} = K_{unosen} \Rightarrow f(K_{u})$ $K_{u} = K_{unosen} \Rightarrow f(K_{u})$ Aerosol size distribution $SHMPE = \left[\frac{n_{ENN}}{R_{ADIHS}} \right]$ Aerosol size distribution Assumed aerosol density*** BROWNIAN DIFFUSION**

* DIFFUSIOPHORESIS

PROCESS ASSOCIATED WITH MOLAR STEAM FLUX TOWARDS CONDENSING SURFACE.

* THERMOPHORESIS

PROCESS ASSOCIATED WITH TEMPERATURE GRADIENT. PARTICLES TEND TO MIGRATE FROM HOTTER TO COLDER REGION.

ENGINEERED SAFETY FEATURES

- * SPRAY
- * SUPPRESSION POOL
- * FILTERS

Assumed aerosol density

Condensation rate AND steam density for (DhP) (based on total - NOT partial pressure)

Convective heat flux ONLY (ThP)

Spray drop size

Suppression pool DF

Filter DF

Ā ₫ :-: Particle Settling in Still Air Perry's handbook Time to settle 5 feet by unit density spheres. $0.5 \,\mu m$ $10 \,\mu m$ $100 \,\mu m$ lμm 3 µm 41 hours 12 hours 1.5 hours 8.2 minutes Aerodynamic diameter definition. diameter of a unit density sphere that 5.8 seconds settles at the same velocity as the particle in question CU= CUNNINGHAM SLIP $V_{\rm b}$ = CORRECTIONS f(Kn) Kn=KNHOSEN NHMAER P.P.B. 1.1 Cu SHIPE TEAN FREE PATH FACTOR Parameter to review: particle density 1 1 1 1 1 1 1 1

• • • • • •



HYGROSCOPIC CORRECTION







Whirljet Droplet Size Distribution





Pool scrubbing



Growth or decay of dispersed bubble or droplet in the steam of continuous phase (liquid or gas)


Uncertainty analysis ESSENTIAL



Figure 2 Decontamination coefficient: 5%/95%, mean value and ERI-predicted values.

"Engineering is the art of modeling materials we do not wholly understand, into shapes we cannot precisely analyze so as to withstand forces we cannot properly assess, in such a way that the public has no reason to suspect the extend of our ignorance."

Dr A.R. Dykes, British Institution of Structural Engineers, 1976





and HOW we get there is a mystery...



Somewhere, something went terribly wrong





"IT MAY NOT BE A PERFECT WHEEL, BUT IT'S A STATE OF THE ART WHEEL, BUT IT'S

Corrosion in Nuclear Power Plants

Joel Jenkins NRO/DE/CIB June 20, 2012

Faces of Corrosion



Rusty Chain

Faces of Corrosion



Chemical tank with SCC

Source: National Transportation Safety Board Accident Brief NTSB/HZB-0401

What is Corrosion?

Degradation of a metal due to electrochemical interaction with its environment

Corrosion Mechanisms

- General Corrosion
- Pitting
- Crevice Corrosion
- Intergranular Attack

Corrosion Mechanisms

Galvanic Corrosion

Flow Accelerated Corrosion

Stress Corrosion Cracking (SCC) includes but not limited to

- PWSCC (Primary Water SCC)
- IGSCC (Inter-Granular SCC)
- IASCC (Irradiation-Assisted SCC)

SCC Factors

Stress



SCC Factors

Problem Material-Environment Combinations Steel and caustic solutions

Stainless steel and halogen salt solutions

Alloy 600 and reactor primary water

Design Considerations

Is corrosion of the component likely considering material and operating conditions?

If corrosion is likely, at what point is it detrimental to operation?

What methods can be used to detect presence and extent of corrosion?

Corrosion in the Nuclear Power Plant

Boric Acid Corrosion (BAC)

- Responsible for corrosion of bolts and/or vessel head (e.g. Davis Besse 2002)
- Flow Accelerated Corrosion (FAC)
 - A synergistic wear/corrosion mechanism responsible for failure of pipe (e.g Surry 1986)

Stress Corrosion Cracking (SCC)

• A common corrosion problem for nickel alloys and stainless steel. Can happen in primary and nonprimary systems. Sometimes aggravated by neutron radiation.

Case Study: SCC at Pallisades

(IGSCC of Service Water Pumps)



SWPs at Pallisades

Service Water Pumps (SWPs)

Major components: motor, hollow casing, rotating shaft, impeller

Originally designed with carbon steel shaft couplings

Flow

Redesigned in 2007 to use corrosion resistant stainless steel couplings (Type 416)

Pallisades-2009

Redesigned stainless steel coupling failed in 2009

Cursory evaluation found hardness to be out-of-spec

Failed coupling replaced with like material, and back to operation

Susceptibility of design to further IGSCC not considered

Pallisades-2011

Stainless steel coupling fails during operation, disabling one of the three SWPs

Per tech specs, failure of a single pump activates an LCO action (fix in 72h or shut down)

Utility performs root cause analysis and links failure to IGSCC

Failed Coupling, Pallisades-2011



Source: Entergy Operations, Pallisades (ADAMS ML12006A049)

Failure Analysis, Pallisades-2011

Material was found to be improperly heat treated and thus susceptible to IGSCC

Sufficient tensile stress in shaft assembly to initiate SCC in couplings

Chlorination of lake water and concentration of ions due to wet/dry cycles increased corrosiveness of environment

Failure Analysis, Pallisades-2011 Evaluation of Unbroken Coupling



Source: Entergy Operations, Pallisades (ADAMS ML12006A049)

Solving the Corrosion Problem at Pallisades

How did Pallisades solve the problem?

Was the Pallisades solution the only option?

Are type 410 and 416 stainless steel "bad" materials?

Solving the Corrosion Problem in General

Preventing Problems through Good Design (the best solution!)

Effective Inspection at Proper Intervals

Learning Lessons from Operating Experience

Where to Get More Info

- Subject Matter Experts
- Training
 - NACE General Corrosion Course
 - NRC Course E116 (Corrosion and Corrosion Control in LWRs)
 - NRC Effects of Corrosion Web-Based (basically a short discussion of Davis Besse)

For Official Use Only



Digital I&C Operating Experience Insights

NRC Office of Research: How Things Fail Seminar Series

Daniel Santos David Garmon

"The only source of knowledge is experience" - Albert Einstein



Purpose and Agenda

- Challenges
- Operating Experience (OpE)
 - Selected Industry Reports
 - Specific Events
- Agency Efforts
 - Domestic
 - International

Digital System OpE Knowledge Management



Why is Digital System OpE Important?

- Effect on Plant Safety
- Increasing Integration of Plant Systems
 - Operating Plants
 - New Reactors

Learn from Our Experience





Non-Nuclear Events



For Official Use Only



Challenges to OpE Collection

- Small event population

 Novelty of digital safety systems
- Reporting and analysis quality
 - Improve quality
 - Consider standardization



Industry Reports

- Electric Power Research Institute (EPRI)
 - Operating Experience Insights on Common-Cause Failures in Digital Instrumentation and Control Systems (2008)
- Institute of Nuclear Power Operations (INPO)
 - Topical Report (TR) 8-63 Software Events (2008)
 - TR 8-64 Microprocessor-Based Digital-Hardware-Related Events (2008)





- Study Objective
 - Identify potential digital I&C related common cause failures
- Approach
 - Primary distinction between safety and nonsafety events

For Official Use Only





EPRI Study: Selected conclusions

- Number of events increases with installations
- Systemic Failures
 - Inadequate
 - Requirements definition
 - Testing programs
 - Vendor oversight
 - Design compatibility, etc
- Software based changes to address nonsoftware problems



INPO: TR 8-63 and TR 8-64

- Objective
 - Analyze digital hardware/software related events and their impact on power production.
- Approach
 - Significant Events Evaluation and Information Network (SEE-IN)
 - Equipment Performance and Information Exchange System (EPIX)
 - Plant Events Database (PED)
 - Licensee Event Reports, 10 CFR 50.73 (LER)
 - International events (World Association of Nuclear Events, WANO)



TR 8-64: Hardware Data

- 55 Domestic events (2003-2007)
 - SCRAMS (24), power reductions (20), misc impact on production (11)
 - Most Prevalent System
 - Balance of Plant systems (37)
 - Most Prevalent Causes
 - Circuit cards, power supplies failures and component "design deficiencies" (39)




- Inadequate system designs
 - Inadequate design compatibility
 - Insufficient annunciation of internal failures
- Unique attributes of digital systems
 Sensitivity to EMI and signal noise
- Inadequate preventive maintenance
 - Aging and environmental effects not monitored



TR 8-63: Software Events

Software Events Reported —— Worldwide Events. - International ____



- Complexity of software requirements definition
- Organic skill set
- V&V issues are common
- Consideration of effects of software upgrades
- Vendor control issues



TR 8-63: Software Event Contributors

Software Event Causes

Inadequate Verification and Vendor Involvement Validation

Design Deficiency

Inadequate Configuration Control

Programming Errors

Incompatible Design **Modification**





- Verification and Validation (V&V)
- Software Design
- Software Modifications/Upgrades/ Configuration Control



Recap of Studies

- Number of events follow increases in installations
- Design issues (software and hardware)
- Verification and Validation
- Configuration control programs
- Software used as workaround for hardware failures

For Official Use Only



🥈 Start 🕐 HQ – E Reik XeisApp Phu.

http://nrr10.nrc.gov/ope-info-gateway/index.html

- 🛪 🔿 🗄 🐻 12 08 AM



Plant Events

- 2005 Palo Verde 1 Reactor Trip due to Incorrect Operation of DFWCS
- 2007 Perry Reactor Scram due to Failure of DFWCS Power Supplies
- 2009 Columbia Reactor Scram with Complications



Human Performance (2005, Palo Verde 1)

- Operator "not comfortable" with DFWCS shifted from manual to automatic feed control and overfed the S/G resulting in reactor trip
- Operator consideration as part of implementation program (V&V, training, qualifications program etc.)
- Refs:

– IFR 2008-06; SIT Report ML080280499





- Reactor trip due to loss of feedwater
 - Complications associated with level control
- Insufficient reliability of power supplies compounded by insufficient error annunciation
- Refs

- IFR 2008-06; SIT Report ML080280499



For Official Use Only **Inadequate Software V&V** (2009, Columbia)

- Fault on electrical bus results in reactor trip
- During generator load reject a digital electrohydraulic control system failure results in generator bypass valves being held open
- Following the trip a feedwater control system failure results in low suction pressure trips of each feedpump
- Insufficient design review and testing
- Refs
 - IFR 2010-04 (and attachments); SIT Report ML093280158



Recap of Individual Event Review

- Weakness in V&V programs
 - Not including operators
 - Not fully testing system
- Preventive maintenance
 - May not be a priority
- Quality of hardware and software
 - Remains at the foundation of system performance and plant safety.

Learning from Our Experience Depends on Quality of Reporting



Agency Efforts

- Office of Research
 - NRC DI&C System Research Plan FY 2010-2014
 - COMPSIS Cooperation
- NRR
 - Update NEI 01-01
 - ISG-6
 - IN 2010-10
- NRO
 - Design Acceptance Criteria/Inspection, Tests, Analysis and Acceptance Criteria Procedures



Takeaways

- Systemic failures
- Latent Defects
 - No event too small to be considered
- Improve event documentation
- Need a well established KM effort

Operating Experience Supports Technical Basis for Regulations



Questions?



For Official Use Only



Preventive Maintenance (2007, North Anna 2)

- Spurious safety injection due to protection system circuit card failure
 - Signal could not be immediately reset
 - PORVs lifted
 - Rupture of relief tank rupture discs
- Running circuit cards to failure vice program to replace based on age.
- Refs
 - IFR 2007-030; SIT Report <u>ML072410359</u>; INPO <u>SEN268</u>





Notes Page: Do Not Delete





Notes Page: Do Not Delete



Manas Chakravorty Sunwoo Park

Structural Engineering Branch 2



United States Nuclear Regulatory Commission

Protecting People and the Environment

Outline

- Basics of the earthquake
- Recorded ground motions
- Seismic impact to the plant
- NRC inspection findings
- Licensee short-term and long-term actions



The 2011 Mineral, VA Earthquake

- Magnitude : 5.8
- Depth: 6 km
- 11 miles SE from NAPS
- Fault types: reverse
- Largest recorded quake east of the Rocky Mountains since 1897
- Widely-felt earthquake in U.S/Canada (Alabama to Canada and the East Coast to Illinois), according to USGS



Main Shock and Aftershocks



Impact on Local Community

- More than 900 homes damaged
- Pre-Civil War house in the county was damaged (foundations, chimneys)
- 2 of 6 public schools in the county suffered structural damage
- Estimated costs for repairs in Louisa County exceed \$18 million, including damage to public buildings and roadways



Ten Nuclear Power Plants Declared "Unusual Event"

Seabrook Pilgrim iilstone 2/3 anna 1/2 sade Davis Oyster Creek m 1/2 Bottom 2/3 Vert Cliffs I/2 on Anna 1/2 Sdrry 1/2 McGuire 1/2/ conee Brunswick 1/2 Summer A Robinson Vogtle⁻¹/2 Hatch 1/2

North Anna Nuclear Power Station



Impact to North Anna Nuclear Power Plant

- > Epicenter was ~18km (11mi) from the plant
- PGA estimated at the site is ~0.26g
 - 13:51:00 Earthquake occurs with both units at 100% power
 - 13:51:11 Reactor Trip Breakers open for both reactors on negative flux rate trip. All control rods inserted
 - 13:51:12 Loss of offsite power due to sudden pressure trips on offsite power transformers
 - 13:51:20 All four diesel generators and the SBO DG start



Impact to North Anna Nuclear Power Plant (cont'd)

- 14:03:00 An Alert was declared based on judgment because LOOP prevented the seismic panel from reporting the earthquake
- 14:40:00 2H EDG was tripped due to coolant leak.
 Subsequently, SBO DG was aligned to 2H bus
- 22:58:00 Offsite power was restored
- On August 30, NRC Implemented AIT to assess the total LOOP and dual unit trip, failure of 2H EDG, and other equipment issues following the seismic event

Seismic Design at North Anna Nuclear Power Plant

The North Anna Plant has two Safe Shutdown Earthquake ground motions (SSE),

- for structures, systems, and components (SSCs) located on top of <u>rock</u>, it anchored at a peak horizontal ground acceleration (PGA) of 0.12 g
- for SSCs located on top of <u>soil</u>, it anchored at a PGA of 0.18 g



OBE and DBE (SSE) – Peak Ground Accelerations



(From a Dominion Presentation)

Response Spectra Comparison (Horizontal, Rock Site)

Kinemetrics Data for Containment Basemat - Horizontal Direction



Response Spectra Comparison (Vertical, Rock Site)



Recorded Motion at North Anna Plant from the Mineral, Virginia Earthquake (M5.8)



Protecting People and the Environment

Main Control Room Seismic Instrumentation Panel



Kinemetrics Triaxial Accelerometers



Engdahl Scratch Plates (Response Spectrum Recorder)


U2 Turbine Building

Powdex Demineralizer Tanks Base Pedestal (nonsafety related)





Turbine Building Hallway

٩,



Crack In Unreinforced Non–Safety Related Block Wall



Unit 1 Containment





Surface Hairline Crack In Interior Containment Wall

ISFSI - Dry Cask Storage Pad #1 (TN-32 Units)



All radiology and temperatures normal

25 of 27 TN-32 vertical casks moved between 1 and 4 1/2 inches



ISFSI - Dry Cask Storage Pad #2 (NUHOMS HD System)



NuHoms horizontal modules had small gaps and corners cracked



Augmented Inspection Findings

- Operators responded properly
- Ground motion exceeded licensing design basis
- No significant plant damage
- Safety systems functioned properly
- Some equipment issues were revealed (seismic monitoring equipment performance, failure of 2H EDG, etc)
- The event did not adversely impact the health and safety





Short-Term Actions

- ✓ Installed Temporary Free Field Seismic Monitor
- ✓ Installed Qualified UPS to Seismic Monitoring Panel in Main Control Room
- Revised Abnormal
 Operating Procedure
- ✓ Complete Start-Up Surveillances

(From a Dominion Presentation)

- NRC performed readiness restart inspections from 10/5/11 – 11/7/11.
- NRC determined licensee performed adequate inspections, walkdowns and testing to ensure that SSCs were not adversely affected by the earthquake.
- NRC approved restart on 11/11/11.



Long-Term Actions

- Install permanent free-field seismic monitoring
 instrumentation
- Permanently re-power seismic monitoring panel in the main control room
- Re-evaluate safe shutdown equipment (components with identified lower margins)
- Perform seismic analysis of recorded event consistent with EPRI guidance
- Maintain seismic margins in future modifications
- Revise the North Anna Safety Analysis Report
- Coordinate update of seismic design and licensing basis with GI-199 resolution effort

Summary

- Significant beyond DBE occurred
- RG 1.167 and EPRI NP-6695 were used by licensee and staff
- No significant damage to SSCs necessary for operation
- NRC staff are reviewing lessons learned

(More information at: http://www.nrc.gov/aboutnrc/emerg-preparedness/virginia-quake-info.html)

Thank you!



NUREG-0800 U.S. NUCLEAR REGULATORY COMMISSION Standard Review Section 3.10

SEISMIC AND DYNAMIC QUALIFICATION OF MECHANICAL AND ELECTRICAL EQUIPMENT



Regulation

- 10 CFR Part 50, Appendix A, General Design Criterion
 1, "Quality Standards and Records."
- 2. 10 CFR Part 50, Appendix A, General Design Criterion
 2, "Design Bases for Protection Against Natural Phenomena."
- 3. 10 CFR Part 50, Appendix A, General Design Criterion4, "Environmental and Dynamic Effects Design Bases."
- 4. 10 CFR Part 50, Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants."
- 5. 10 CFR Part 52, "Licenses, Certification, and Approval for Nuclear Power Plants."
- 6. 10 CFR Part 100, Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power Plants."



Guidance Documents

- SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs," April 2, 1993; Staff Requirements Memorandum 93-087 issued on July 21, 1993.
- 2. NRC Regulatory Guide 1.100, Revision 3, "Seismic Qualification of Electric and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants."
- 3. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," Section 3.10.
- 4. Interim Staff Guidance COL/DC-ISG-1, "Interim Staff Guidance on Seismic Issues Associated with High Frequency Ground Motion in Design Certification and Combined License Applications.
- 5. NRC Regulatory Guide 1.60, Revision 1, "Design Response Spectra for Seismic Design of Nuclear Power Plants."
- 6. NRC Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."



Industry Standards

- IEEE Std 344-1987, "IEEE Recommended Practice for Seismic Qualification of Class IE Equipment for Nuclear Power Generating Stations," Institute of Electrical and Electronics Engineers.
- IEEE Std. 344-2004, "IEEE Recommended Practice for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations."
- IEEE Std. 323-2003, "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations."
- 3. ASME QME-1-2007, "Qualification of Active Mechanical Equipment Used in Nuclear Power Plants."



ISG (Internal Staff Guideline)

 DC/COL-ISG-1, Internal Staff Guidance on Seismic Issues of High Frequency Ground Motion.



AREAS OF REVIEW

- Seismic and dynamic qualification criteria
- Methods and procedures for qualifying electrical equipment, instrumentation, and mechanical components
- Methods and procedures for qualifying supports of electrical equipment, instrumentation, and mechanical components
- Documentation
- COL Action Items



Information Reviewed

- Deciding factors for choosing between tests or analyses.
- Considerations in defining the seismic and other relevant dynamic load input motions.
- Demonstration of adequacy of the qualification program
- Methods and Procedures used to ensure structural integrity and the functionality of Equipment in the event of a SSE after a number of OBEs.
- Methods and Procedures of analysis or testing of supports for equipment.
- Seismic qualification report or similar equipment data documentation.







High-frequency Exceedance





Protecting People and the Environment

Staff Concern on Industry's Approach for Case I





Resolution



Using IEEE Std 344 Annex D

to compute equivalent peak stress cycles



Protecting People and the Environment





Protecting People and the Environment

Interim Staff Guidance on HF issues for DC/COL (ISG-1)





Staff Guidance

Staff Requirements Memorandum of SECY-93-087:

For nuclear power plants that were designed and/or licensed with the elimination of the OBE (plants with OBE defined as equal or less than 1/3 of SSE), electric and mechanical equipment qualified by testing should be qualified with

 $5 \times OBE + 1 \times SSE$

 $5 x \frac{1}{2}SSE + 1 x SSE$



Response Spectrum (an example)

Response Spectrum (soft, medium, hard)



Frequency



ABC's Of Welding

John Honcharik Office of New Reactors

June 12, 2013

Agenda

- What is a weld and where is it used.
- Welding processes.
- Weld joint design.
- Weld Procedures.
- Welder Qualification.
- · Issues with welds.
 - Steels
 - Stainless steels
 - Weld defects
 - Dissimilar metal weld degradation
 - Weld residual stresses

Welding

- A weld:
 - A localized coalescence of metals or nonmetals produced by heating the materials to the welding temperature, with or without the application of pressure, or by the application of pressure alone and with or without the use of filler metal.
- Is it an art, or is it science?
- A bit of both (automation tries to take out some of the art/skill)

Welding

- Welding versus brazing/soldering
 - An atomic bond between the atoms at that interface is predominant, and the process that produces that joint is called welding.
 - Brazing or Soldering
 - A mechanical bond is predominant at the interface created by the process (brazing, soldering and thermal spraying)

Weld Joint Brazed Joint



Where do you use welding?



- Pressure vessels
- Piping
- Components
 - CRD
 - Pumps
 - Valves
 - Internals
 - Core supports
- Just about everywhere you do not use mechanical joints (bolting)

Weld-Integral Part of Components



Weld - Reactor to Structural



Vergtle Unit 3 reactor wessel is transported as front of Unit 4 containment vessel bottom head May 2018 2014 Design Friver Company 6, right-mensed

Modular Construction

Steel composite structures increases the amount of welding which was once predominately reinforced concrete. 12:49 2012/3/20

Welding Processes

 Processes most commonly used in the nuclear industry is Arc welding.

American Welding Society Master Chart of Welding and Allied Processes

Annex D

 (This guide is not a part of ANSI Z49 1.1999). Safet: In Wilkings, Chillings and Allieu Processer, Fitt is uncluded for information purposes only.)



Welding Processes

- Shielded Metal Arc Welding (SMAW)
- Gas Metal Arc Welding/Flux Cored Arc Welding (GMAW/FCAW)
- Gas Tungsten Arc Welding (GTAW)
- Plasma Arc Welding (PAW)
- Submerged Arc Welding (SAW)
- Electroslag Welding (ES)
- Stud welding (SW)
- Friction Welding (FRW)
- Laser Beam Welding (LBW)
Welding Process - SMAW

- Shielded Metal Arc Welding
 - Welding arc produced by completing electrical circuit
 - Uses flux to shield arc and weld metal from contaminants and oxidization



Welding Process - SMAW

- Flux can also add alloying elements to weld
- Filler metal designation example : E7018 (E-electrode, 70 minimum tensile strength, 1-position (all), 8 usability (DCEP, low hydrogen –iron powder flux)





Welding Process-GMAW/FCAW Gas Metal Arc Welding/ Flux Cored Arc Welding

- Uses inert gas to shield arc and weld metal from contaminants and oxidizing
- FCAW uses flux (in core of wire) and sometimes inert gas shielding also



 Semi-automatic (auto wire feeder)

Welding Process-GMAW/FCAW Different Modes of Weld Transfer



- SC 75Ar/25CO₂
- Globular CO₂
- Spray 95Ar/5CO₂ and higher voltage/amps



Wire

Molten

 Pulsed –power source pulses (smaller weld puddle-more control)

Welding Process – GTAW (Gas Tungsten Arc Welding)



Welding Process – PAW (Plasma Arc Welding)



- Similar to GTAW but uses additional gas to concentrate the arc.
- Can be used for hardfacing.



Welding Process - SAW Submerged Arc Welding



Welding Process - SAW





Welding Process - SAW

Strip cladding – form of SAW with different shape filler metal (primarily for cladding).



Welding Process - Electroslag

- Such high deposition rates that it is similar to casting material
- Can affect material properties based on orientation of solidified weld metal
- Metal crystal solidification with dendritic growth from weld sides to center of weld having an acute angle results in stronger centerline bond (RG 1.34).



Welding Process – Stud Welding



- Stud welding used in structural applications (temporary or permanent).
- Mostly mechanized (Stud welding gun).

Friction Welding

- Uses nonconsumable tool to melt material due to pressure.
- No addition of filler metal.



Downward force to maintain contact

Laser Beam Welding

- Uses laser to melt material in lieu electrical arc.
- Higher cost.
- Better quality.
- Piping inlays.

5

6

7...

Ŗ

10

9

2

3.



Welding – Why Different **Processes**? 100

- Productivity (related to deposition rate) is major (I/I) reason. Quality Access

- Training/skill
- Type of weld joint
- Position



Weld Joint Design

- •Different Joint types depends on:
 - •Access
 - Efficiency/Strength
 - Ease of welding
 - Ease of machining
 - Welding process
 - Thickness
 - Distortion



DOUBLE "J" GROOVE WELD

Weld Joint Design



- Simple to Complex
- Balance quality and productivity
- Narrow groove weld uses less weld metal therefore faster welding (however, must be used with automated process)











Weld Procedures

- Common/essential parameters (variables)
 - Depends on weld process and applicable code used
 - Typical parameters:
 - Amps/polarity
 - Volts
 - Travel speed
 - Wire speed
 - Base metal/filler metal
 - Base metal thickness
 - Joint (backing ring, EB ring)
 - Shielding
 - Preheat/interpass



Weld Procedures

- Preheat the minimum temperature in the section of the previously deposited weld metal, immediately prior to welding
- Interpass temperature the highest temperature in the weld joint immediately prior to welding, or in the case of multiple pass welds, the highest temperature in the section of the previously deposited weld metal, immediately before the next pass is started
- Preheat and interpass
 - Prevent unwanted material phase/properties microstructure
 - Untempered martensite
 - Carbide precipitation
 - Cracking, stresses
 - Good toughness
 - Typically, increase in strength will decrease toughness (brittle vs. ductile)
 - Need balance for each application

Weld Procedures

- Changes to essential parameters (variables) require requalification of procedure
- Changes to supplemental variables may require partial requalification
- Changes to non-essential variables do not require requalification
- Weld procedures are qualified in accordance with the applicable code and documented in a procedure qualification record (PQR).
- Note specific codes only provide requirements on qualifying weld procedures and welders (does not state how to weld).

Procedure Qualification Record

- Base material are assigned to groupings (Pnumbers) to group similar metals (properties) to reduce amount of procedure qualifications.
- Filler metals are also assigned to groupings (Fnumbers) based on compatibility with base material characteristics.
- Joint designs, such as full penetration (groove welds- backing rings, double sided, EB ring), partial penetration (fillet welds).
- Base material thickness
- Preheat and interpass temperature

Procedure Qualification Record

- Positions.
- Shielding (flux and/or shielding gas)
- Electrical Characteristics (volts, amps, current, etc.)
- Technique and other requirements
 - Stringer vs. weave bead
 - Travel speed
 - Multipass to single pass, etc.
 - Cleaning
- Typically, NDE and tensile and bend tests performed on test assemblies to determine acceptability.

FLEET WELDS

Positions

- Groove qualifies fillet
- Plate qualifies pipe

GROOVE WELDS



For Plate

QUALIFICATION POSITION RANGE FOR THE SINGLE VEE GROOVE WEL

Groove Test Position	Welding Positions Qualified For	
Groove Position	Groove Positions	Fillet Positions
FLAT IG	F	F, H
HORIZONTAL 2G	F.H	F. H
VERTICAL 3G	F, H, V	F. H. V
OVERHEAD 4G	F, H. OH	F. H. OH
3G AND 4G	ALL	ALL

NOTE Also Qualifies for pipe over 24" diameter.

if backing is used qualification is with backing

Welder Qualification

- Typically, a base material and filler metal combination using a given process is used to qualify a weld procedure for that specific material combination and process.
- Base material and filler metal combinations for welder qualifications are broader.
- Generally, welders qualify based on:
 - Filler material
 - Thickness
 - Process
 - Position

Welder Qualification



- Bend tests or volumetric examines are performed on welder qualification test assemblies
- Generally, a groove weld qualifies also qualifies fillet welds.
- However, this does not mean welders are not trained for different joint types, material combinations (welder qual. tests may use only one type of material), access, etc.

Issues With Welding

- Changes in microstructure
- Changes in material properties
- Introduce defects
- Introduce stresses

Issues With Welding-Steels

- Steels are affected by welding causing
 - Hydrogen cracking
 - Brittle/hard heat affected zones (i.e., Martensite)
 - Increase stresses (residual) during cooling
- Methods to minimize these effects (i.e., tempered martensite):
 - Preheating base metal before welding minimizes these effects
 - Post weld heat treatment also minimizes these effects (i.e., tempered martensite).
 - Temper bead welding

Issues With Welding-Steels

Depending on composition and heat treatment can change material microstructure/phase.
Change material

•Change material properties



Issues With Welding-Steels

- Different microstructure affects toughness
- Verify toughness of welds/adjacent base metal by Charpy impact tests



Issues With Welding-Steels

Underbead cracking/hydrogen cracking



Stress induced/improper post weld heat treatment



Issues with Welding-SS

- Sensitization (800°F to 1500°F.
- Cr carbides precipitate out depleting the grain boundary areas of Cr making SS susceptible to SCC.
- Methods to minimize sensitization (RG 1.44):
 - Material composition(low carbon)
 - Heat treatment
 - Weld heat input
 - Interpass temperature



Issues With Welding-Defects

- Welding defects affect the integrity of the weld and mechanical properties.
- Some defects (depending on size) are acceptable, while others are never acceptable.



Issues With Welding-Dissimilar Metal Welds

- Design use different materials for various components (due to conditions/environment), and eventually these components need to be connected.
- Welding different material can create totally new alloys/microstructure (dilution) and affect material properties or resistance to aging degradation.



Issues With Welding-Dissimilar Metal Welds

- Develop materials with similar properties (strength, thermal expansion, etc.) and still be weldable.
- Some alloys can be welded only in a particular way
 - Weld Ni based alloy to stainless steel, but can not weld stainless steel onto Ni based alloy.
- New degradation mechanism may occur
 - Primary stress corrosion cracking (PWSCC)
 - Ni based alloy (600) in PWR water previously was thought immune to SCC
- Need to develop new alloys and how to weld them.

Issues with Welding – Crack Growth

- New alloys or welding processes
- Learn from past experiences

iemat allo**y 52/69**0 HAZE

 Tests to simulate aging degradation in evaluating long term integrity

> **Me**lt boundary **(determined from Optical image)**

Issues with Welding - Residual Stresses

•Stresses can lead to long term issues/aging degradation (i.e., SCC)

Hoop stresses before and after repair weld





Repair weld

Summary

- Welding improves productivity but can change material properties or microstructure of material being welded.
- Need balance of productivity, cost and level of quality.
- Weld procedures are qualified by the fabricator to specific codes (each code may have different requirements).
- Welders are trained and qualified to the specific codes.
- Codes used to qualify weld procedures and welder; does not provide instructions on how to weld.
- Issues with welding including long term degradation have to be taken into account.
Application of Lessons Learned from Flow-Induced Vibration to New Reactors

Thomas G. Scarbrough Component Integrity, Performance, and Testing Branch 2 Division of Engineering Office of New Reactors U.S. Nuclear Regulatory Commission

May 18, 2010

Introduction

- Some operating nuclear power plants have experienced failure of safety-related and non-safety related components from flow-induced vibration (FIV).
- FIV significance caused by acoustic resonance was not recognized during previous Design Certifications.
- Lessons learned from FIV operating experience is currently being considered during design, qualification, and surveillance planning for new reactors.
- NRC staff reviewing potential FIV in Design Certification and Combined Operating License (COL) applications.

FIV Safety Significance

- Severe hydrodynamic and acoustic resonance loads can cause failure of safety-related and non-safety related components in reactor, steam, and feedwater systems.
- Failure of safety-related or non-safety related components might cause sudden reactor transient.
- Inoperability of safety-related components (such as safety relief valves) might not be revealed until component is signaled to perform its safety function.
- Failure of non-safety related components can cause small pieces to interfere with plant operation, or safe shutdown.
- High steam moisture content from steam dryer failure could damage reactor turbine if shutdown not initiated.

FIV Operating Experience

- Quad Cities Unit 2: Steam Dryer (June 2002/June 2003)
- Quad Cities Unit 1: Steam Dryer (November 2003)
- Quad Cities Unit 2: Steam Dryer (March 2004)
- Quad Cities Units 1 and 2: Relief Valves (January 2006)
- Palo Verde Unit 1: Shutdown Cooling Piping (Dec. 2005)
- Waterford Unit 3: Steam Generator Internals (April 2005)

Boiling Water Reactor Pressure Vessel



Quad Cities Unit 2 Power Uprate

- Quad Cities Unit 2 June 2002
 - After 90 days of Extended Power Uprate (EPU) operation, steam dryer cover plate fails with pieces found on steam separators and in main steam line (MSL).
- Quad Cities Unit 2 June 2003
 - After additional 300 days of EPU operation, steam dryer experiences failure of hood, internal braces, and tie bars.



Quad Cities Unit 1 Power Uprate

- Quad Cities Unit 1 November 2003:
 - After about 1 year of EPU operation, steam dryer hood experiences significant cracking with 6x9 inch piece of outer bank vertical plate missing.
 - Damage also found to
 - Main steam electromatic relief valve (ERV)
 - Steam line supports, and
 - High Pressure Coolant Injection (HPCI) steam supply motoroperated valve.

QC1 Steam Dryer Failure November 2003







Outer bank vertical plate 6x9 inch hole

Quad Cities Unit 2 Power Uprate

- Quad Cities Unit 2 March 2004
 - After about 8 months of EPU operation, numerous steam dryer indications identified during refueling outage inspection including
 - Cracking near gussets installed in 2003,
 - Broken tie bar welds, and
 - Damaged stiffener plate weld.



Quad Cities and Dresden Steam Dryer Replacement

- Replacement steam dryers for Quad Cities and Dresden are stronger and more streamlined than their previous dryers.
- Exelon replaced Quad Cities steam dryers in Spring 2005.
- Exelon installed pressure, strain, and acceleration instrumentation directly on Unit 2 steam dryer to determine steam dryer loading and to calibrate acoustic circuit analysis.
- Exelon installed strain gages on main steam lines to measure pressure fluctuations as input to acoustic circuit analysis to calculate steam dryer loading for QC1 and other plants.
- Exelon replaced steam dryer in Dresden Unit 3 in 2006, and Unit 2 in 2007.





ERV Damage at Quad Cities

- In late 2005, Exelon identified intermittent short circuiting of safety-related Electromatic Relief Valve (ERV) at Quad Cities Unit 2.
- Exelon reduced power in QC2 to inspect ERV actuator and found broken internal parts.
- Exelon shut down QC2 and found damage to other ERVs, and performed repairs.
- Exelon shut down QC1 in early January 2006 and found damage to its ERVs, and performed repairs.
- If ERV short circuiting had not occurred, both Quad Cities units might have operated with multiple ERVs inoperable or experienced spurious ERV opening.

Electromatic Relief Valve



Palo Verde Unit 1 FIV

- Long history of vibration and leakage of shutdown cooling (SDC) valve and piping at Palo Verde Unit 1.
- Vibration cause hypothesized as pressure pulsations in suction line from coupling between fundamental frequency of SDC suction line and vortex shedding due to RCS flow over SDC suction line.
- Licensee initially attempted an SDC nozzle modification but obtained unacceptable results.
- Licensee subsequently relocated SDC valve to increase acoustic frequency away from vortex shedding modes.
- Acceptable vibration results obtained.

Waterford Unit 3 FIV

- Failure of batwing supports in Steam Generator (SG) #2 internals found during inspection in April 2005.
- Most probable cause determined to be fatigue due to FIV.
- Nov. 2006 inspection found additional batwing damage in SG #2, but no damage in SG #1.
- Batwing weld repairs performed and selected SG tubes plugged to mitigate potential impact of SG tube vibration.

Acoustic Resonance FIV Cause

- MSL flow creates vortices when passing over branch lines.
- At specific flow velocities, vortices couple with acoustic mode of branch lines.
- Pressure fluctuations in MSLs can cause significant pressure loading on steam dryer.
- Severe vibration can occur in MSL piping and components, including relief valves.
- Acoustic resonance is difficult to predict and quantify prior to its occurrence.

Singing Safety-Relief Valve





MSL Strain Gage Readings for Quad Cities and Vermont Yankee



Quad Cities Modifications

- In spring 2006, Exelon modified branch lines to 8 main steam safety valves and 4 ERVs in each QC unit by installing Acoustic Side Branch (ASB) consisting of 6-inch diameter pipe filled with screen mesh.
- ASB increases effective length of branch line that decreases frequency of acoustic standing wave, and lowers steam velocity at which vortex shedding will excite acoustic standing wave.
- ASB screen mesh dampens pressure fluctuation.
- MSL strain gate data collected after modification reveal pressure fluctuations and vibrations reduced to pre-EPU levels.



QC2 Spring 2006 MSL B Strain Gage Data compared to pre-ASB Data

MSL B Lower



QC2 Spring 2006 3E ERV Accelerometer Data compared to pre-ASB Data

Q2R18 Accelerometer Trends 3E ERV Inlet Flange - X



Page 9 of 24

Industry Response

- Scale model testing and acoustic analysis methodology developed to evaluate acoustic resonance in MSLs.
- GE updated its steam dryer inspection guidance (SIL 644).
- BWR Vessel Internals Project prepared generic guidance:
 - BWRVIP-139 on steam dryer inspections
 - BWRVIP-182 on demonstrating steam dryer integrity
 - BWRVIP-194 on methodologies for demonstrating dryer integrity
- BWR Owners Group prepared lessons learned report on power uprates.
- GEH developing Plant Based Load Evaluation (PBLE) Methodology for evaluation of acoustic load on ESBWR steam dryers.

Operating Plant FIV Status

- Vermont Yankee Power Uprate (March 2006): MSL data collected during power uprate ascension without significant FIV. Inspected dryer following power uprate and found Intergranular Stress Corrosion Cracking (IGSCC).
- Susquehanna 1 and 2 Power Uprate (Jan. 2008): Steam dryers replaced with upgraded design. Dryer data collected without significant FIV. Unit 1 dryer inspection found IGSCC after 2-year power uprate operation.
- Hope Creek Power Uprate (May 2008): Steam dryer upgraded prior to initial startup. MSL data collected without significant FIV.
- Browns Ferry, Monticello, and NMP2 Power Uprates: under review

NRC Staff Response

- Information Notices 2002-26 (S1 and 2) and 2004-06 on Quad Cities and Dresden FIV events.
- Evaluation of Exelon activities on QC and Dresden FIV events including plant inspections and observation of replacement steam dryers, MSL modifications, small scale testing, and EPU restart monitoring with support from Argonne National Laboratory, Penn State, and McMaster University.
- SRP Sections 3.9.2 and 3.9.5 and RG 1.20 updated to incorporate FIV lessons learned for BWRs and PWRs.
- Evaluation of generic industry FIV guidance.
- Power uprate safety evaluations with monitoring of power ascension for acoustic resonance and FIV.

Power Ascension Program

- License condition provides slow and deliberate power ascension with lengthy hold points and data evaluation.
- Monitor and trend data (e.g., pressure transducers, strain gages and accelerometers) hourly with 96-hour hold point for data evaluation and walkdown every 5% power when approaching full power.
- If data exceed limit curve, return to acceptable power level, re-evaluate dryer loads, re-establish limit curve, and perform assessment before continuing power ascension.
- Power ascension report to be submitted within 60 days.
- Conduct visual dryer inspection of all accessible, susceptible locations at first 3 RFOs, then long-term BWRVIP-139 plan.

NRO Activities

- Monitoring FIV operating experience for lessons learned applicable to new reactor review.
- Reviewing Design Certification applications for evaluation of potential adverse flow effects.
- Reviewing COL applications (e.g., STP Units 3 and 4) for consideration of potential FIV in design, testing, and monitoring programs.
- Assisting in planning ITAAC inspections for design, quality assurance, fabrication, and testing of plant components that can be adversely affected by FIV.

Summary

- Acoustic resonance in reactor and steam systems has led to failure of safety-related and non-safety related components at BWR and PWR nuclear power plants.
- Potential for severe hydrodynamic and acoustic resonance loads was not recognized during previous Design Certification reviews.
- Nuclear industry addressing FIV for new reactor designs, new reactor license applications, and operating reactors requesting power uprate.
- NRO staff evaluating FIV in Design Certification and COL applications to ensure lessons learned addressed in reactor design, testing, and monitoring.

Surry EMD Diesel Failure, Notice of Enforcement Discretion, and Generic Implications

Contents

- Surry diesel wrist pin bearing failure
- Notice of Enforcement Discretion
- Industry OE
- Generic Implications
- Lessons Learned

Surry EMD 645 Emergency Diesel Generators












Wrist Pin Bearing Failure Timeline

Date	Time	Event
8/9/2012	14:26	EDG slow started for beginning of PMTs.
8/9/2012	19:08	After ~2hr loaded run, EDG load reject test performed. An oil sample taken during loaded run showed silver level as less than the detectable threshold (0.1 ppm)
8/9/2012	23:43	EDG fast start test (minimum starting air pressure and fuel rack held closed during first crank cycle). EDG was shutdown 15 min later with out being loaded.
8/10/2012	00:05	A second fast start was performed and the EDG was loaded.
8/10/2012	01:46	The oil sample tube fell into sump during sample attempt. When lube oil samples obtained, 0.23 ppm silver. EDG continues to run loaded for ~ 2 hrs.
8/10/2012	11:46	Silver flakes found on bottom of oil sump after it was drained to retrieve sample tube.
8/11/2012	09:45	Cylinder #5 wrist pin bearing found damaged with silver material blocking the oil hole.







Cylinder #8



Wrist Pin Bearing Oil Grooves

Cylinder #5 Wrist Pin Bearing



Cylinder #5 Wrist Pin



nundunuhunuh. 3





Wrist Pin Oil Feed Hole

P-Pipe Port Discharge

SAVE



NOED

- EDG #2 maintenance package started on 08/06, damage identified on 08/11
- Surry EDG Tech Spec allowed outage time is 7 days
- All power packs must be replaced
- NOED discussions begin
- Several internal calls were held
- NOED granted verbally on 08/12 for additional 7 days AOT with comp measures in place

Operational Experience

- 1986 ANO crankcase explosion (unknown cause)
- 2000 Point Beach EDG wrist pin failure (FME)
- 2001 Sequoyah EDG wrist pin failures (FME)
- 2001 Surry #1 and #3 EDG wrist pin failures (oil change?)
- 2012 Surry #2 EDG wrist pin failure (design)
- 2012 Laguna Verde crankcase explosion (unknown cause)
- 2012 Point Beach elevated silver

Generic Implications

- EMD diesels may be susceptible to excessive startup wear in nuclear service
- OE may not support current industry practice
- Oil analysis not necessarily a predictive tool
 - EMD OG action level of 0.3 ppm not sufficient to predict bearing failure
 - Most silver ends up on the bottom of the crankcase and not in oil
- Lead wire readings not a definitive diagnostic procedure either
- Internal engine component inconsistency

Lessons Learned

- Even supposedly well proven equipment can have unexpected failures
- Closely following licensee activities will pay dividends
- NRC engagement with licensee and collaboration across offices enhances industry safety
 - Contact HQ and other regions/residents with any information that may have generic implications
- Use of Confirmatory Action Letter for one licensee allows NRC to push other licensee to take early measures
 - R2 CAL gave R3 leverage with Point Beach

"New" Bronze Style Bearing



"New" Rocking Style Pin





United States Nuclear Regulatory Commission

Protecting People and the Environment

Key Principles of I&C Systems Architecture



Objective

 To inform staff on the key principles of I&C systems architecture to ensure that plant safety is maintained and to provide lessons learned from recent I&C systems reviews.



I&C Systems and Their Purpose

- Monitoring of plant parameters
- Control of plant processes
- Protection of the plant during and following any anticipated operational occurrences or postulated accidents
- Auxiliary functions (e.g. control of HVAC systems)



Key Principles of I&C Systems Design

- Redundancy
- Independence
- Diversity
- Determinism
- Simplicity



Redundancy

- Redundancy in I&C safety systems can be used to achieve system reliability goals.
- I&C safety systems should have sufficient redundancy to meet the single failure criterion and provide for maintenance and testability.
- Redundancy should not be compromised through a dependency or interference.



Independence

- Independence between redundant portions of safety I&C system and between safety system and non-safety I&C systems
 - Physical Separation
 - Electrical Isolation
 - Functional Independence
 - Communications Independence





- Diversity is the use of different means including function, design, principles of operation, and organizational and development strategies to compensate for failures within a safety system.
- Diversity is used to address common cause failures (CCFs) of the safety system.
- To mitigate against CCFs, diversity can be provided within the safety system or it can be provided through a diverse back up system.



Determinism

- Safety systems should be designed to operate deterministically.
 - Predictable: having a known system output at any time in which a given set of input signals will always produce the same output signals.
 - Repeatable: having the output of a system being consistently achieved given the same input and system properties.





- Simplicity is considered to be a cross-cutting principle that affects the fundamental design principles.
- Simplicity of I&C systems design supports demonstration of conformance to other key principles such as independence and defense-indepth.
- Given several design options on how to implement a function, the more simple design options are those that accomplish the function and address potential hazards with the most confidence and clarity.



- New failure modes in digital I&C systems may challenge defense in depth measures.
- Some digital I&C systems designs are highly integrated and unnecessarily complex, making demonstration of compliance to key principles difficult.



Lessons Learned From Recent Digital I&C Systems Reviews

- Several applications had highly integrated systems without an understanding of the potential adverse effects on safety due to this integration.
- Applicants did not provide adequate justification for including additional functionality in I&C systems that are not necessary to perform the safety function but may challenge plant safety.
- Not all digital I&C failure modes were addressed by the applicant.
 - Control systems failures that can adversely impact safety.
 - Communications failures and functional dependencies were often not adequately addressed.
- Applicants often times provided claims of safety but did not provide sufficient evidence to support these claims.



Summary

- Safety I&C systems should be as simple as possible to ensure that failures within safety systems and of connected systems do not adversely impact the safety system's ability to perform the safety function.
 - Unnecessary functions should be avoided so that failure of such functions do not adversely impact the safety system.
- Sufficient diversity should exist either within the safety I&C system or between the safety I&C system and the diverse backup system to address the potential for common cause failures.
- Designers of digital I&C systems should be cognizant of the new failure modes introduced by such systems.

High Level Presentation to DE and DSRA

Sodium-cooled Fast Reactors (SFRs) and LWRs

September 24, 2013

Imtiaz K. Madni Sr. Reactor Systems Engineer NRO/DSRA/SCVB



Why Sodium-Cooled Fast Reactors (SFRs)?

- SFRs can be used for breeding or transmutation of transuranic waste products (minimizing need for permanent repositories)
- Fast spectrum reactors need to be compact to minimize moderation of fast neutrons, require higher fuel enrichment, hence high power density
- Places significant heat transfer requirement on reactor coolant
- This and other requirements have been met by the use of liquid sodium



SFR Experience in the US

EBR-I	Idaho	R&D	1951-1963	1.4 / 0.2	Pool	NaK
Fermi 1	Michigan	Power	1963-1972	200 / 61	Loop	Na
EBR-II	Idaho	Test	1963-1994	62.5 / 20	Pool	Na
SEFOR	Arkansas	Test	1969-1972	20 / 0		Na
FFTF	Washington	Test	1980-1992	400 / 0	Loop	Na

(CRBR, SAFR, PRISM, 4S designed, not constructed)

- Five facilities have operated from 1951 to 1994. Combined over 30 years operating experience
- The first electrical power production was generated by EBR-I, which fed into the power system for Arco, Idaho
- Most of the initial designs were intended to support development of breeder reactors


Neutronics: Thermal and Fast Spectrum Impacts



Selected Properties of Sodium and Water

	Sodium	Water
Atomic Weight	22.997	18
Optical Properties	Opaque	Transparent
Melting Point (°C)	97.8	0
Boiling Point (°C)	>892	100
Density (kg/m3)	880	713
Specific Heat (J/kg-K)	1300	5600
Thermal Conductivity (W/m-K)	76	0.54
Viscosity (cP)	0.34	0.1
Values at STP. Italic = Evaluated at ~300°C (and 2000 psi for water)		



High BP of Sodium Provides Large Margin to Boiling

	PWR (2200 psi)	SFR
Inlet Temperature (°C)	300	355
Core DT (°C)	30	155
Outlet Temperature (°C)	330	510
Boiling Temperature (°C)	345	>892
Margin to Boiling (°C)	15	>380

- Some nucleate boiling in a PWR is allowable under accident conditions, & margin to boiling is not real limit. Limit is defined by departure from nucleate boiling, which can result in clad burnout
- Boiling in an SFR significantly impairs heat transfer and must be avoided.



- High BP of Sodium allows Operation at Low System Pressure (near atmospheric)
- Impact on Design Features
 - Vessel thickness: PWR ~ 10-12 inches, SFR ~ 1-2 inches
 - No need for pressurization of SFR fuel pins
- Safety Advantages of low system pressure
 - Minimal pressure loading on coolant boundary
 - Coolant leaks are unlikely to propagate to a large-scale failure
 - In comparison, in a high-pressure system, coolant pipe breaks are a concern
 - No need for high pressure injection or ECCS.



- In an LWR, water acts as both a coolant and a moderator. An optimal P/D ratio is adjusted so that
 - 1. Adequate moderation is obtained
 - 2. Generated nuclear heat is affectively removed by the coolant
- In an LMR, no moderation is needed. Sodium acts only as a coolant. Because of excellent cooling properties of sodium, fuel pins can be placed much closer on a triangular pitch









Typical PWR Assembly (289 pin locations) Pin Diameter = 9.4 mm Pin Pitch = 12.5 mm

"**Typical**" **SFR Assembly** (271 pins) Pin Diameter = 7.4 mm Pin Pitch = 8.9 mm



Impact of Coolant: Sodium Interactions

Sodium is inherently compatible with stainless steel

- Does not corrode structural materials
- Experience with EBR-II after 30 years of operation
- Fuel-coolant interactions are benign for metallic fuel
 Many fission products are soluble in sodium, hence
 - can be filtered out in the cold trap, this contributes to scrubbing

Sodium Reaction with Air

- Characterized by small flames at interface, formation of Na₂O on surface, and vigorous emission of oxide fumes
- Hence sodium systems need sealed guard vessels and inert cover gas (Argon)

Sodium Reaction with Water

Vigorous, exothermic, and releases hydrogen

²³Na Activation

Results in radioactive isotope ²⁴Na circulating in primary system



Impact of Coolant: SFR needs an Intermediate Coolant Loop



- Na activation and reaction with water
- Requires separation of high-pressure steam cycle from radioactive primary system; hence intermediate heat transfer system (IHTS) used
- Two design choices: Pool and Loop





SFR Safety Issues: Neutronics

- Power variation across core due to neutron leakage at core boundaries plus high power density
 - Need to use ducted assemblies to control location of fuel and core temperatures (lesson learned from EBR-I)
 - Flow rate in each ducted assembly is adjusted via adjusted nozzle openings in order to have uniform outlet temp from the core
 - Core reactivity is very sensitive to core geometry
- Core sodium void worth is typically positive in center of larger reactor cores (e.g. +ve for PRISM, -ve for 4S)
 - With proper design, overall core void could be made negative. How?
 - High leakage cores
 - Large L/D
- Fuel is not in most neutronically reactive configuration in reactor core
 - Relocation of fuel has the potential to significantly increase reactivity, including exceeding prompt critical conditions







- Na allowed to enter at bottom & fill tube when pumps are operating
- GEM's designed to lower core power level if main coolant pumps malfunction
- Helium pressure causes Na level in pins to drop & allow more neutrons to leak out of core
- Lower number of neutrons causes fewer fissions to occur and power level drops

- In event of a leak from Na-containing systems/components
 - Na may emerge as a jet (and impinge on other structures) or may spill
- If air is available
 - Leaking sodium will react with air. This can lead to:
 - Spray fire (starts at 120 °C, high burning rate, high aerosol production) or
 - Pool fire (starts at 250 °C, low burning rate, low aerosol production)
 - Na fires produce aerosols (NaO and Na₂O) which react with air to produce NaOH (in a few sec) and Na₂CO₃ (in several min)
 - Aerosol generation may increase thermal loading and raise gas pressure
 - Aerosols deposit on floor, walls, and ceiling, can cause equipment damage (electrical, instrumentation)



- Significant Na Leaks
 - BN-600, October 7,1993, Na leak on pipeline for cold trap. 800 kg escaped. May 1994, leak from secondary, 30 kg burned.
 - Monju (spill and burn of several hundred kg of secondary Na, December 8, 1995)
 - Super Phenix (Na leak from used fuel storage tank. Inerted GV, hence no fire, no casualties.) Led to shutdown in July 1996, too expensive.
 - No reported adverse effects to plant personnel or surrounding environment



Prevention

- Surround sodium pipes/vessels with inert-gas filled and sealed guard pipes/guard vessels (not including intermediate piping) so any Na leakage enters an inert volume (multiple barriers).
- Steel-lined confinement cells to contain secondary Na from a leak and avoid core-concrete reactions. (Also, concrete selection to minimize interactions).
- Direct leaking Na through catch pan systems into a oxygen starved recovery tank to avoid pool fire.



- Detection
 - Objective is to prevent large leaks, corrosion, and fires by early detection
- Mitigation
 - Fire extinguishing powders for quick and effective extinction of Na fire
 - Limit duration of fires (~15 min) to avoid serious damage to structures
 - Preclude pressurization of cells by relief valve openings or rupture disks
 - Limit drop height of spray fire by arranging catch pans every few meters vertically – makes spray fire into pool fire.
 - Special filters in ventilation to remove Na aerosols from containment atmosphere



SFR Safety Issues: Na Reactivity with Water

- SG tubes are boundary between sodium in IHTS & HP steam
- SG tube leaks have occurred in many SFRs (e.g. PFR, Phenix, BN-600) and are an important safety issue with new designs
 - IHX is designed to withstand full steam pressure if a tube leak occurs
 - However, contact of water with sodium leads to exothermic reaction that could rapidly pressurize IHTS piping or IHX (2nd safety barrier)
 - Need to develop and qualify early leak detection systems to prevent propagation of tube leaks and ruptures
 - In PRISM, both large Na leak into air and steam generator tube rupture are included by GE as bounding events to be considered in the design for licensing



SFR Safety Issues: Na Reactivity with Water

- Design options
 - Use successful approach used in EBR-II, Toshiba 4S designs i.e. use double-walled SG tubes
 - EBR-II experience: No tube leaks occurred during 30 years of operation, Na and water never came in contact during operating lifetime of plant
 - Use better SG tube materials, or new tertiary fluid, or a new fluid in IHTS
- Should SG tube leaks be considered as DBAs?
 - Not settled yet, because no final application has been submitted



Commercial Grade Item Dedication and 10CFR21: Application to Digital I&C Systems and Software

> Milton Concepcion, MSc (Eng) Sr. Digital I&C Engineer NRO/DE/ICE2

DISCLAIMER

This presentation is intended for information purposes only and does not replace independent professional judgment. Statements of fact and opinions expressed are those of the presenter individually and, unless expressly stated to the contrary, are not the opinion or position of the NRC, EPRI, or ASME NQA-1 Committee. The presenter assumes no responsibility for the content, accuracy or completeness of the information presented.

Agenda

- Commercial-grade item (CGI) dedication process requirements & guidance
- CGI dedication of digital I&C equipment
- Latest developments affecting CGI dedication of software

CGI Dedication References

- 10 CFR Part 21
- · Generic Letter 89-02
- Generic Letter 91-05
- EPRI NP-5652, "Guideline for the Utilization of Commercial Grade Items in Nuclear Safety Related Applications (1988)."

Additional Inspection Guidance

- Inspection Procedure 38703 (issued 1993)
- New Inspection Procedure 43004 (issued October 2007)

CGI Dedication Process_(cont'd)

- Commercial-grade dedication is an acceptance process by which a CGI is designated for use as a basic component.
- This acceptance process is undertaken to provide reasonable assurance that a CGI to be used as a basic component will perform its intended safety function and, in this respect, is deemed equivalent to an item designed and manufactured under a 10 CFR Part 50, Appendix B, quality assurance program.

CGI Dedication Process

- An acceptable dedication program involves:
 - Review for suitability of application per Criterion III, "Design Control," of Appendix B

 \cdot (i.e., Technical Evaluation)

Acceptance controls per Criterion VII,
 "Control of Purchased Material,
 Equipment, and Services," of Appendix B

• (i.e., Four Acceptance Methods)

CGI Dedication Process (cont'd)

Technical Evaluations

- Determine item's safety function and service conditions
- Functional classification of items and components
- Review of vendor's technical/development data
- Identification and selection of item's critical characteristics
- Determine appropriate acceptance criteria

Acceptance Process

- Method 1: Special tests and inspections
- Method 2: Commercialgrade survey of supplier
- Method 3: Source verifications
- Method 4: Acceptable supplier/item performance record

Software Used in Nuclear Industry

- Process Control (Digital I&C Equipment)
- Design & Analysis
- Operations (Management/Administration)
 Not addressed in this presentation

CGI Dedication of Digital I&C Equipment

- NRC conditionally accepted of the following EPRI Guidance Documents for Dedication of Digital I&C including Programmable Logic Controllers (PLC):
 - EPRI TR-106439, "Guideline on Evaluation and Acceptance of Commercial Grade Digital Equipment for Nuclear Safety Applications," October 1996
 - EPRI TR-107330, "Generic Requirements Specification for Qualifying a Commercially Available PLC for Safety-Related Applications in Nuclear Power Plants," December 1996

CGI Dedication of Digital I&C Equipment(cont'd)

- Digital I&C equipment introduces additional challenges
 - Complexity of the device including its internal architecture, external interfaces, communication links, etc.
 - Access to detailed information/documentation (design, development, testing, verification/validation, configuration control)
 - Proper identification and verification of critical characteristics
 - Hardware+software (operating/application)
 - · Extent/thoroughness of Critical Design Review (CDR)*
 - Use of software tools
 - Cybersecurity

•

•

- Crediting relevant operating history
- Engineering judgment
- Not all commercial digital I&C equipment can be successfully dedicated*

Implementation and Examples

(with the invaluable collaboration from Rossnyev Alvarado -- NRR)

- HFC-6000 platform
- · SPINLINE 3 platform

•

•

- Review of the OS software QA program was limited to assessment of the process, plans, and procedures as they relate to maintaining the commercially dedicated system
 - Verification of the critical characteristics Methods 1, 2 and 4

Note Method 3 would require the licensee to observe FAT for a purchased system

- NQA-1-2008/NQA-1a-2009 changes
 - Reaffirmed endorsement in RG 1.28, Rev. 4 June 2010
 - Subpart 2.14, "Quality Assurance Requirements for Commercial Grade Items and Services."
 - \cdot Provides amplified requirements for CGI Dedication
 - Subpart 2.7, Section 302
 - For acquisition of software that has not been previously approved under a program consistent with NQA-1 for use in its intended application
 - Changed from an "evaluation" (i.a.w. SP 2.7) to a dedication process (i.a.w. Part I, Req. VII and SP 2.14)
 - Application in the context of SP 2.7 includes ALL software (e.g., process control, design & analysis)

- EPRI 1025243, "Plant Engineering: Guideline for the Acceptance of Commercial-Grade Design and Analysis Computer Programs Used in Nuclear Safety-Related Applications."
 - Generic technical evaluation process overview
 - Functional safety classification of computer programs
 - Acceptance of commercial-grade computer programs using the dedication process
 - Currently under review by NRC QA staff potential RG endorsement
 - Impact of EPRI report on IEEE 7-4.3.2 guidance related to software tools?

• IEEE 7-4.3.2 and software tools

- At this time, there is no direct relationship between EPRI-1025243 and IEEE Std. 7-4.3.2.
- It is worth noting that IEEE 7-4.3.2-2010 added CGI dedication (Clause 5.17) as an alternative to establish suitability of software tools for use in safety related systems.
- Although the scope of EPRI-1025243 does not directly address software tools used to support the development of operating and/or application software in digital I&C systems, the dedication guidance provided in EPRI-1025243 may be considered by an applicant/licensee.

Embedded digital devices

- Register Notice on Embedded Digital Device RIS (requesting public comment) issued May 20, 2013.
- Commercial-grade replacement products containing embedded digital devices that include software, softwaredeveloped firmware, or software-developed logic that may not have been developed in accordance with guidance and acceptable industry standards.
- Requirements to identify the use of embedded digital devices and sufficiently document the quality of the embedded digital devices to support commercial-grade item dedication.

10CFR21 rulemaking efforts

- Part 21 and the philosophy of dedication apply to all safetyrelated items and services, including software. However, Part 21 and its associated guidance do not provide contemporary requirements for software dedication.
- While the staff notes that software can be safety-related and can be dedicated, some stakeholders have interpreted Part 21 to the contrary. Part 21 provides an area for potential improvement in defining the requirements for software dedication.
- A regulatory guide to address commercial grade dedication will be essential in providing clear expectations to Part 21 stakeholders. The regulatory guide would include implementation guidance for software.

Summary

- Licensees/vendors must know, define, and control CGI dedication process
 - Establish and maintain product/design suitability (hardware+software)
 - Determine safety function(s)
 - Identify and select critical characteristics
 - Utilize defined acceptance methods
- Licensees/vendors must establish and maintain complete documentation/records
 - Evaluations
 - Acceptance tests & inspections
 - Supplier controls

Questions/Comments

Graphite: Properties and Behavior

Tim Burchell

Materials Science & Technology Division

Presented to

US Nuclear Regulatory Commission

January 12th 2011




Overview of Presentation

- Manufacture
- Structure
 - Single crystal and polycrystalline synthetic graphite
- Porosity and texture
- Physical Properties
 - Thermal
 - Electrical
- Mechanical Properties
 - Elastic constants
 - Strength and fracture
- Applications
- Summary

Graphite Single Crystal Structure



- •Strong, stiff covalent bond in-plane
- •Weak bonds of attraction between graphene planes
- •ABA repeat stacking (can get ABC...)
- •Crystal unit cell size:
- •<a> = 0.246 nm
- •<c> = 0.670 nm
- •Coherence lengths, I_a and I_c are measures of crystal size

Synthetic Graphite Manufacture



•Petroleum coke from calcination of heavy oil distillates

•Pitch coke from calcination of coal -tar pitch

•Coke filler particle morphology and green artifact forming method affect texture and properties

•First bake is a critical stage, controlled binder pyrolysis

•Acheson or longitudinal graphitization

•Long cycle times ~ 9 months

Manufacture – Baking and Graphitizing



Slow heating and cooling during baking allows escape of pyrolysis gasses and minimizes thermal gradients

Manufacture - Baking



Modern car bottom carbon/graphite baking furnace Green bodies packed in coke and placed in steel saggers

Manufacture – Acheson Graphitization



Baked artifacts surrounded by a coke pack and covered with sand to exclude air. Electric current flow through the coke-pack & artifacts

Manufacture – Longitudinal Graphitization



Furnace covered with sand to exclude air, current flows though the baked artifact

Carbon atoms migrate to thermodynamically more stable graphitic lattice structure and 3D ordering achieved (degree of ordering depends on feedstock type)

Manufacture - Purification



Post graphitization halogen gas process

Can be performed with solid fluoride additives to Acheson graphitization furnace or solid fluoride additives to formulation

Manufacture - Purification

Unpurified graphite

Thermally purified graphite

Chlorine purified graphite

Fluorine Purification

Crystallites & Optical Domain



Sciences of Carbon Materials, Marsh & Reinoso

Synthetic Graphite Structure

Nuclear graphite XRD crystal parameters

Graphite grade	Coke type	<c> (A)</c>	lc (A)	<a> (A)	la (A)
HOPG	n/a	3.345	424	1.229	138
H-451	Petroleum	3.353	269	1.230	300
IG-430	Pitch	3.361	218	1.231	298
BAN	Petroleum	3.365	250	1.231	322
NBG-17	Pitch	3.364	186	1.231	286
IG-110	Petroleum	3.366	190	1.231	256
PCEA	Petroleum	3.367	238	1.231	250
NBG-18	Pitch	3.370	191	1.232	294

Crystallites & Optical Domain



Sciences of Carbon Materials, Marsh & Reinoso

Coke Particles



Shape Indicates Domain Orientation

Optical Domain- Coke Particle



Needle 500x Isotropic

Optical Domain



Individual Particle 500 X



Manufactured Graphite 400 X

Porosity in Graphite

Graphite single crystal density = 2.26 g/cc Synthetic graphite bulk density = 1.6-1.9 g/cc Most graphite contains ~>20% porosity > 60% of porosity is open

Three classes of porosity may be identified in synthetic graphite:

1. Those formed by incomplete filling of voids in the green body by the impregnant pitch, the voids originally occur during mixing and forming;

2.Gas entrapment pores formed from binder phase pyrolysis gases during the baking stage of manufacture;

3.Thermal cracks formed by the anisotropic shrinkage of the crystals in the filler coke and binder.

Graphite Structural Features

Lattice (a= 2.45 A, c= 6.7 Å)

Crystallite "Coherent Domain"

Micro-crack (between planes, about the size of crystallite) Optical Domain (extended orientation of crystallites)

Grain Size

Pore Size



Grade AGOT graphite microstructure (viewed under polarized light)



Grade PGA graphite (with-grain) microstructure (viewed under polarized light)



Grade NBG-18 graphite (with-grain) microstructure (viewed under polarized light)



Grade IG-110 graphite microstructure (viewed under polarized light)



Grade IG-110 graphite microstructure (viewed under polarized light)

2020 Graphite

Grade 2020 graphite microstructure (viewed under polarized light)



Grade 2020 graphite microstructure (viewed under polarized light)



Grade IM1-24 graphite microstructure (viewed under polarized light)

Synthetic Graphite Texture

Texture in synthetic graphite arises because of:

- •Crystal anisotropy, coke and binder domain size
- •Filler cokes and binder cracks
- •Size and shape distribution of filler particle
- •Filler coke type
- Recycle fraction and morphology
- Porosity

•Forming method (preferential orientation of filler coke and binder porosity)

Texture imparts anisotropy!



<u>Filler Materials:</u> Calcined Coke, (Raw Coke) Recycle Graphite <u>Sizing:</u> Designed Combination of Discrete Fractions 10-1,000 microns

Binder: Pitch (20-45 parts/hundred)

"Remix" "Additives"















Charge Mixer










Graphite Production - Extrusion



Graphite Production - Extrusion











← Grain Direction →



← Grain Direction →

Graphite Production - Vibration Molding







Mix Agglomerates are Milled to Produce Molding Powder



Mill

Molding Powder

Storage





Place Bag in Tooling



Storage





Seal Rubber Bag



Place Tooling in Autoclave



Seal Autoclave



Pressurize





Slight Grain Direction

Remove & Strip Bag From Billet







Graphite Properties and Behavior

Physical Properties

Synthetic graphite properties

	Graphite Grade and Manufacturer						
Typical Properties	AXF-5Q	IG-43	2020	ATJ	NBG-18	AGR	
	POCO	Toyo-Tanso	Mercen	GTI	SGL Carbon	GTI	
Forming Method	Isomolded	Isomolded	Isomolded	lsomolded	vibro-molded	Extruded	
Maximum Particle Size, µm	5	10 (mean)	15	25 (mean)	1 600	3000	
Bulk Density, g/cm ³	1.8	1.82	1.77	1.76	1.88	1.6	
Thermal Conductivity, W/m.K	05	140	85	125(WG)	156 (WG)	152 (WG)	
(Measured at ambient temperature)	00	140		112 (AG)	150 (AG)	107 (AG)	
	7 /	10	1.2 (20	3.0 (WG)	4.5 (WG)	2.1 (WG)	
Coefficient of Thermal Expansion, 10 %	7.4 (20.500°C)	4.0 (250 450°C)	4.3 (20 500°C)	3.6 (AG)	4.7 (AG)	3.2 (AG)	
(over given temperature range)	(20-000-0)	(350-450 C)	-500 C)	(@500°C)	(20-200°C)	(@500°C)	
Electrical Besistivity, 110 m	14	9.2	15.5	10.1 (WG)	8.9 (WG)	8.5 (WG)	
Electrical Resistanty, p				11.7 (AG)	9.0 (AG)	12.1 (AG)	
Young's Modulus, GBs	11	10.8	9.3	9.7 (WG)	11.2 (WG)	6.9 (WG)	
Toung s modulus, gra				9.7 (AG)	11.0 (AG)	4.1 (AG)	
Tensile Strength, MPa	65	37	30	27.2 (WG)	21.5 (WG)	4.9 (WG)	
				23.1 (AG)	20.5 (AG)	4.3 (AG)	
Compressive Strength, MPa	145	90	80	66.4 (WG)	72 (WG)	19.8(WG)	
				67.4 (AG)	72.5 (AG)	19.3 (AG)	
Elevural Strength MPa	90	54	45	30.8 (WG)	28 (WG)	8.9 (WG)	
riexulai Suenyui, mra				27.9 (AG)	26(AG)	6.9 (AG)	

WG-with grain, AG-against grain

Temperature Dependence of Specific Heat



Calculated from ASTM C781

Single crystal thermal expansion behavior

Hexagonal graphite lattice has two principal thermal expansion coefficients; α_c , the thermal expansion coefficient parallel to the hexagonal <c>-axis and α_a , the thermal expansion coefficient of the crystal parallel to the basal plane (<a>-axis). The thermal expansion coefficient in any direction at an angle φ to the <c> axis of the crystal given by:

$$\alpha(\varphi) = \alpha_c \cos^2 \varphi + \alpha_a \sin^2 \varphi$$

- α_c varies linearly with temperature from ~25 \times 10⁻⁶K⁻¹ at 300K to ~35 \times 10⁻⁶ K⁻¹ at 2500K.
- α_a is much smaller and increases rapidly from -1.5 \times 10⁻⁶ K⁻¹ at ~300K to approximately 1 \times 10⁻⁶ K⁻¹ at 1000K, and remains relatively constant at temperatures up to 2500K.

Temperature Dependence of Thermal Expansion



Thermal closure of aligned porosity

Temperature Dependence of Coefficient of Thermal Expansion



Thermal closure of aligned porosity

Temperature Dependence of the Thermal Conductivity



Phonon scattering, effect of intrinsic defects

Temperature Dependence of the Thermal Conductivity



Anisotropy in extruded thermal conductivity

Temperature Dependence of the Electrical Resistivity



Electron transport mechanism

Graphite Properties and Behavior

Elastic Behavior

Elastic constants of single crystal graphite (Kelly)

Elas	stic moduli, GPa	Elastic	c compliances, 10 ⁻¹³ Pa ⁻¹
C ₁₁	1060 ± 20	S ₁₁	9.8 ± 0.3
C ₁₂	180 ± 20	S ₁₂	-1.6 ± 0.6
C ₁₃	15 ± 5	S ₁₃	-3.3 ± 0.8
C ₃₃	36.5 ± 1	S ₃₃	275 ± 10
C ₄₄	4.0 - 4.5	S ₄₄	2222 - 2500

Variation of the reciprocal Young's modulus with angle of miss-orientation between the c-axis and measurement axis



Variation of the reciprocal Shear modulus with angle of miss-orientation between the c-axis and measurement axis



Typical Young's Modulus increase with temperature for pitch-coke and petroleum coke synthetic graphite

0.60



Stress-strain behavior of synthetic graphite

There are two major factors that control the stressstrain behavior of synthetic graphite:

•The magnitude of the constant C_{44} , which dictates how the crystals respond to an applied stress,

•The defect/crack morphology and distribution, which controls the distribution of stresses within the body and thus the stress that each crystallite experiences.

Graphite Properties and Behavior

Strength and Fracture

Typical compressive stress-strain curve for medium-grain extruded graphite (WG)



Strain, %

Non-linear stress strain curve

Typical tensile stress-strain curves for medium-grain extruded graphite (WG)



Strain, %
The correlation between mean 3-pt flexure strength and fractional porosity for a wide range of synthetic graphite representing the variation of textures



The correlation between mean 3-pt flexure strength and mean filler coke particle size for a wide range of synthetic graphite representing the variation of textures



Crack Propagation in Synthetic Graphite



An optical photomicrograph of the microstructure of grade H-451 graphite revealing the presence of pores [P], coke filler particles [F] and cracks [C] which have propagated through the pores presumably under the influence of their stress fields

Burchell fracture model probability predictions for different graphite

Model Inputs:

- •Mean filler particle size
- •Particle K_{lc}
- Specimen breadth
- Stressed volume
- Pore size distribution mean and st. dev.
- •Density
- •Number of pores per unit volume

Graphite multiaxial strength behavior & model predictions



- Previous 1st and 2nd stress quadrant testing of H-451 & IG -110
- Extended to NBG-18 1st & 2nd stress quadrants
- NBG-18 modeled with Burchell model incorporating Shetty mixed mode fracture criterion
- NBG-18 3rd and 4th stress quadrant testing initiated at ORNL

Graphite thermal shock resistance

Thermal Shock FOM,
$$\Delta_{th} = \frac{K\sigma}{\alpha E(1-v)}$$

K is the thermal conductivity, σ_y the yield strength, α the thermal expansion coefficient, E the Young's modulus, and u is Poisson's ratio

Material	FOM
Graphite, AXF-5Q	124,904
Graphite, IG-110	84,844
Wrought beryllium	~1 x10⁴
Pure tungsten	~ 0.5x10⁵
Carbon-carbon composite	~1 x10 ⁶

Graphite does not melt but rather sublimes at T>3300K

Applications

- Metal processing
 - •
 - •
 - •
- Semiconductor manufacture
 - •
- Electrical and electronic
 - •
 - •
- Mechanical
 - •
- Aerospace
 - •
- Nuclear
 - •

Graphite flaw detection & NDE

- Ultrasonic inspection used in graphite manufacture for inspection after bake stage and after graphitization for dry core and gross flaw detection
- But, ultrasonic has limited usefulness/applicability
- Flaw resolution cannot exceed wavelength of signal, i.e., to resolve critical flaws need to use high frequency
- Attenuation increases (range decreases) as frequency increases
- Thus for engineering components may not have sufficient range or resolution, depending on structure/texture and critical defect size
- X-ray tomography promising technique for small artifacts
- Resolution down to micron level or better

Summary

- Synthetic graphite is a unique high temperature material
- Crystals have strong in-plane covalent bonds, weak van der Waal bond between planes
- Complicated processing route with many variables
- Properties are controlled by bond anisotropy, structure and texture
- Domain size (extended order) in filler coke and binder directly affects isotropy
- Manufacturing process imparts texture which influences
 isotropy
- Porosity controls fracture behavior & strength
- Phonon conductor of heat, electron conduction mechanism

Nuclear Graphite

Tim Burchell

Materials Science & Technology Division

Presented to

US Nuclear Regulatory Commission

January 12th 2011





Outline

Graphite

Role in HTGRs

Role of Graphite in a Nuclear Reactor

Neutron moderator (carbon & graphite)

Neutron reflector – returns neutrons to the active core

Graphite (nuclear grade) has a low neutron capture cross section

High temperature material

Role of Graphite in a Nuclear Reactor

Graphite is the reactor core structural material

HTGR cores are constructed from graphite blocks and do not form a pressure boundary

In prismatic cores the graphite fuel elements retain the nuclear fuel

In a pebble bed the graphite structure retains the fuel pebbles

The graphite reflector structure contains vertical penetrations for reactivity control

Reactivity control in also graphite fuel elements

Gas Turbine-Modular Helium Reactor (GT -MHR)



The GT-MHR Utilizes Ceramic Coated Particle Fuel

The TRISO fuel particles are formed into 12 mm diameter graphite (carbon) fuel sticks and inserted into graphite fuel blocks







Graphite Core Components – Pebble Type HTR (PBMR)



•NBG-18 Graphite blocks form the PBMR outer reflector

• Reflector penetrations are for the control rods and reserve shutdown system





The Pebble Type HTR Utilizes Ceramic Coated Particle Fuel

The TRISO fuel particles are combined into a graphite (carbon) fuel ball (pebble) 6 cm in diameter



UC₂ Kernel, 200-μm diam FEED PARTICLE

HTR-10 Graphite Reactor Internal Structures (Grade IG-110)



Top of the graphite core of HTR-10

Core bottom of the HTR-10 showing the fuel pebble collection area



Design of nuclear graphite for HTGRs

In The USA - AGOT Graphite



Very anisotropic irradiation induced dimensional changes

- Coarse texture
- •Anisotropic needle coke
- Extruded (faster, lower cost)
- High Purity (low Boron and Sulfur content)
- •Low Strength
- •Nuclear Graphite The First Years, W. P. Eatherly, J. Nucl. Mater. 100 (1981) 55 -63

Factors Controlling The Neutron Irradiation Damage Response Of Graphite

- Crystallinity (degree of graphitization): More graphitic crystals retain less displacement damage. Crystallinity is a function of precursor (pitch/coke) and graphitization temperature.
- Small crystallite sizes promotes higher strength and retardation of pore generation.
- Structural isotropy (both coke isotropy and final product isotropy). Isotropic irradiation behavior is much preferred. CTE ratio is used as an indication of isotropy. Higher coke CTE and graphite CTE preferred.
- Forming technique structural and property anisotropy is introduced by extrusion and molding. Isostatic molding produces an isotropic graphite.

Developments in Nuclear Graphite – Process Improvements

- Purity
 - Advent of in-graphitization furnace purification
- Crystallinity
 - High crystallinity retains less radiation damage
- Filler coke size
 - Small size preferable (stronger) but larger block sizes requires coarser particles size
- Forming method
 - Isostatic pressing & vibrational molding yields less anisotropy than extrusion or molding
- Higher strength
 - Resists pore generation
- Near-isotropic (isotropic filler coke and graphite artifact)
 - Minimizes crystal strains

What Was Learned Over The Years Flowed Down To Improved Graphites:-

- Halogen purification (allowed alternate feedstock sources)
- Understanding of damage mechanism and role of graphite crystallite size
- Need for isotropic cokes high CTE which yield isotropic properties in the final artifact
- Thus second generation graphites were born
 - USA, H-451 extruded, isotropic pet coke
 - UK, IM1-24 molded, Gilsonite coke

Near-isotropic Graphites – H-451



- Extruded, isotropic petroleum coke (NO LONGER AVAILABLE)
- 500 µm mean filler particle size
- •Near-isotropic physical properties
- High CTE & reasonable strength
- •Replaced H-327

Fuel elements & replaceable reflectors in the FSV HTGR (GA)

Near-isotropic Graphites – IM1-24 (UK)



•Molded, isotropic Gilsonite coke (NO LONGER AVAILABLE)

- •~500µm filler particle size
- Isotropic physical properties
- •High CTE and reasonable strength
- Replaced Pile Grade A (Magnox)

Advanced Gas-Cooled Reactor (CO₂ cooled) permanent core structure (lifetime component)

Developments In Nuclear Graphite-Near Isotropic Graphites

- Crystallinity
- Smaller particle size
- forming method (Isostatic molding)
- green coke technology
- high strength
- Isotropic
 - Properties
 - Irradiation induced dimensional change
- Third generation graphites are born

Developments in Nuclear Graphite -•Fine grain (~20 μm)

- High CTE 4-5 x 10⁻⁶ °C⁻¹
- High strength
- isotropic properties and irradiation response





High Temperature Test Reactor (Japan), Fuel Blocks and **Replaceable Reflector Blocks**

HTR-10 & HTR-PM, Permanent **Core Structure**

Developments in Nuclear Graphite isotropic graphites – NBG-18



- Vibrationally molded graphite
- Isotropic Pitch coke
- Medium grain (1.6 mm max)
- High CTE 5-5.5 x 10⁻⁶ °C⁻¹
- isotropic properties and irradiation response

Permanent and replaceable core structures in the Pebble Bed Modular Reactor

Graphite and graphite testing standards

ASTM Standard Specifications

• D7219-08 Standard Specification for Isotropic and Near-isotropic Nuclear graphites

 D7301-08 Standard Specification for Nuclear Graphite Suitable for Components Subjected to Low Neutron Irradiation Dose

What is Specified by The ASTM?

- Coke type and isotropy (CTE)
- Method of determining coke CTE
- Maximum filler particle size
- Green mix recycle
- Graphitization temperature (2700°C)
- Method of determining graphitization temperature
- Isotropy ratio and chemical purity
- Properties: density, strength (tensile, compressive, flexural), CTE, E
- Marking and traceability
- Quality assurance (NQA-1)

ASTM Standard Practices

- C625 Reporting Irradiation Results on Graphite
- C781 Testing Graphite and Boronated Graphite Materials for High-Temperature Gas-Cooled Nuclear Reactor Components

- C783 Core Sampling of Graphite Electrodes
- C709 Standard Terminology Relating to Manufactured Carbon and Graphite

ASTM Standard Test Methods

- C559 Bulk Density by Physical Measurement of Manufactures Carbon and Graphite Articles
- C560 Chemical Analysis of Graphite
- C561 Ash in a Graphite Sample
- C562 Moisture in a Graphite Sample
- C565 Tension testing of Carbon and Graphite Mechanical Materials
- C611 Electrical Resistivity of Manufactured Carbon and Graphite Articles at Room Temperature

ASTM Standard Test Methods (continued)

- C651 Flexural Strength of Manufactured Carbon and Graphite Articles Using Four-Point Loading at Room Temperature
- C695 Compressive Strength of Carbon and Graphite
- C714 Thermal Diffusivity of Carbon and Graphite by Thermal Pulse Method
- C747 Moduli of Elasticity and Fundamental Frequencies of Carbon and Graphite by Sonic Resonance
- C748 Rockwell Hardness of Graphite Materials

ASTM Standard Test Methods (continued)

- C749 Tensile Stress Strain of Carbon and Graphite
- C769 Sonic Velocity in Manufactured Carbon and Graphite for Use in Obtaining Young's Modulus
- C816 Sulfur in Graphite by Combustion-Iodometric Titration Method
- C838 Bulk Density of As-Manufactured Carbon and Graphite Shapes
- C886 Scleroscope Hardness Testing of Carbon and Graphite Materials
ASTM Standard Test Methods (continued)

- C1025 Modulus of Rupture in Bending of Electrode Graphite
- C1039 Apparent Porosity, Apparent Specific Gravity, and Bulk Density of Graphite Electrodes
- C1179 Oxidation Mass Loss of Manufactured Carbon and Graphite Materials in Air
- Dxxxx Oxidation Rate and Threshold Oxidation Temperature for Manufactured Carbon and Graphite in Air

New ASTM Test Methods Currently in Development

- ASTM D02.F on manufactured carbons and graphites has several test methods in development
 - Critical stress intensity factor
 - Shear modulus and Poisson's ratio from sonic velocity
 - Flexural strength by three point bend
 - Chemical purity by ICP- OES and GDMS
 - Small (irradiation) specimen best practice
 - Non-destructive test and evaluation
 - X-Ray diffraction analysis

Physical properties and irradiation effects

Neutron Irradiation Damage

- •Neutron irradiation causes •carbon atom displacement
 - Dimensional and physical property changes result
 - Damage mechanism well understood

• Key physical properties are: irradiation dimensional stability, strength, thermal expansion coefficient, thermal conductivity, radiation creep behavior, fracture behavior, oxidation behavior.

GRAPHITE CRYSTAL STRUCTURE



The Radiation Damage Mechanism In Graphite



CARBON ATOM BINDING ENERGY IN GRAPHITE LATTICE IS 7 eV

DISPLACEMENT ENERGY FOR CARBON ATOM IS APPROX. 30 eV

Low Temperature Stored Energy Release



Burchell T, Carbon Materials for Advanced Technologies, Chpt. 13 (1999) p. 429

Displacement Damage in Layered Graphitic Structures

2 nm



illustrating the formation rates of interlayer defects at different temperatures with the same time scale (0 to 220 seconds). (a) 93K, (b) 300K, (c) 573K, in double-wall carbon nanotubes.

Sequential HRTEM images

The arrows indicate possible interlayer defects.

Urita, K.; Suenaga, K.; Sugai, T.; Shinohara, H.; Iijima, S. Physical Review Letters **2005**, 94, 155502.

Displacement Damage in Layered Graphitic Structures



- Normalized formation rate of the clusters of *I-V* pair defects per unit area of bilayer estimated in HRTEM images recorded at different temperatures
- The dotted line shows the known temperature for Wignerenergy release (~473 K)

Urita, K.; Suenaga, K.; Sugai, T.; Shinohara, H.; lijima, S. *Physical Review* Letters **2005**, 94, 155502.

High Temperature Stored Energy Release

Stored Energy Release Curve for Graphite Irradiated at 30°C Compared with Unirradiated Graphite Cp Curve



Rappeneau et al, CARBON 9 (1966) 115-124

- A second release peak is observed at ~1400°C in graphite irradiated at LOW temperatures
- Associated with annealing of small interstitial clusters
- Immobile vacancies can coalesce at high temperature
- Release rates > Cp NOT seen in graphite irradiated at higher temperatures

High Temperature Stored Energy Release



- High temperature release is due to a separate mechanism
- Release rate does NOT exceed Cp

Radiation Damage In Graphite Is Temperature Dependent







INTERSTITIALS

Mobile at room temperature.

Above ~200°C form into clusters of 2 to 4 interstitials.

Above 300°C form new basal planes which continue to grow at temperatures up to 1400°C.

VACANCIES

Immobile below 300°C.

300-400°C formation of clusters of 2-4 vacancies which diffuse in the basal planes and can be annihilated at crystallite boundaries (function of lattice strain and crystal perfection).

Above 650°C formation of vacancy loops. Above 900°C loops induce collapsing vacancy lines.

The Creation of New Basal Planes in Layered Graphitic Structures



Banhart, F. Rep. Prog. Phys. 1999, 62, 1181–1221.

A high-resolution electron micrograph showing the basal planes of a graphitic nano-particle with an interstitial loop between two basal planes, the ends of the inserted plane are indicated with arrows.

The Influence of Crystallinity on the <a>-axis Shrinkage of Pyrolytic Graphite



Neutron Irradiation Induced Dimensional Change

- Graphite dimensional changes are a result of crystallite dimensional change and graphite texture.
- Swelling in c-direction is initially accommodated by aligned microcracks that form on cooling during manufacture.
- Therefore, the a-axis shrinkage initially dominates and the bulk graphite exhibits net volume shrinkage.
- With further irradiation, incompatibilities in crystallite strains causes the generation of new porosity and the volume shrinkage rate falls eventually reaching zero.

Neutron Irradiation Induced Dimensional Change (Continued)

- The graphite begins to swell at an increasing rate with increasing damage dose due to c-axis growth and new pore generation.
- The graphite thus exhibits volume "turnaround" behavior from initial shrinkage to growth.
- Eventually disintegration occurs due to excessive pore/crack generation.

Radiation Induced Dimensional Changes in H-451 (Effect of Temperature)



Radiation Induced Dimensional Changes in H-451 (Effect of Texture)



Radiation Induced Dimensional Changes in H-451 (Effect of Texture)



Neutron Irradiation Induced Changes in Fracture Strength



 Initial increase due to dislocation pinning

•Subsequent changes due to pore closure and new pore generation

•Critical flaw (unirradiated) approximately 1 mm

Neutron Irradiation Induced Changes in Young's Modulus



 Initial rise due to dislocation pinning

• Subsequent increase due to volume shrinkage (densification)

• Eventual turnover and reduction due to pore/crack generation and volume expansion

• σ α (**E**)^{1/2}

Graphite Thermal Conductivity is Temperature Dependent

H-451 Graphite



Phonon phonon scattering (Umklapp scattering) decreases Tc with increasing temperature

IG-110 Thermal Conductivity Changes



Irradiation Induced Dimensional Changes Result in Differential Strains

- Weaker graphites crack (pore generation)
- Stronger graphites resist pore generation and strains creep out (irradiation creep)
- Radiation creep is a two stage phenomena
- Primary (reversible) creep strain α (1/E₀)
- Secondary (irreversible) creep strain f(σ,γ,E₀)
- Mechanism of creep subject of disagreement
- Two effects must contribute
 - In-crystal deformation
 - Pore generation/pore re-orientation
- At high doses we must allow for structural changes
- Irradiation induced creep in graphite is the subject of a new IAEA Coordinated Research Project

International graphite irradiation programs

International Graphite Irradiation Programs

- European Framework (6th, 7th, 8th)
 - Comprehensive irradiation program of available candidate graphites
- South Africa
 - MTR program (conducted at ORNL) for NBG-18 covers relevant dose and temperature range to PBMR (ON HOLD)
- China
 - Plans an MTR Program relevant to HTR-DM (IG-110)
- USA (DOE)
 - NGNP Graphite irradiation program for candidate graphites (See Technology Development Plan)
- International data will become available through the Gen IV
 International Forum

Graphite oxidation and other chemical reactions

Radiolytic Oxidation is Not a Problem In He Cooled HTRs

- CO₂ + γ =CO₂*, an activated species that can gasify carbon at reactor temperatures
- Radiolytic weight loss can degrade physical properties
- Special measures include gaseous phase inhibitors
- Helium cooled reactors are immune from radiolytic oxidation
- Air/steam oxidation can occur in all graphite moderated reactors and will cause property degradation

Thermal oxidation (Air and Moisture)

- Air/steam oxidation can occur in all graphite moderated reactors and will cause property degradation
- Air ingress accident
 - $C+O_2 \rightarrow CO_2$
 - $\rm CO_2$ +C \rightarrow 2CO
- Moisture in Helium Coolant
 - $\text{ C + H}_2\text{O} \rightarrow \text{CO + H}_2$
 - $\text{ C} + 2\text{H}_2 \rightarrow \text{CH}_4$
- Oxidation = Loss of solid Carbon (Graphite)

Thermal oxidation (Air and Moisture)

- Properties degrade as a function of oxidative weight loss (burn-off)
- To predict burn-off we need to know:
 - Kinetics of oxidation reactions over the appropriate range of temperature and partial pressure (or concentration) of oxidizing species
 - Local partial pressure (or concentration) of oxidizing species within core/graphite block (Effective Diffusivity)
- Graphite purity also has an effect since some impurities act as oxidation catalysts

Erosion of graphite - tribology

Erosion of graphite - tribology

- Tribological data are needed to establish wear of components
- Friction Coefficients (in Helium, effect of pressure and temperature)
 - Graphite on graphite
 - Pebble on Pebble
 - Pebble on Graphite
- Wear rates need to be established
- Wear products (dust) are a fission product vector

Graphite Performance Modeling Requires:

- Whole core graphite behavioral model
 - How large are the stress?
- Fracture Model or Failure Theory
 - Do the stresses cause fracture?
- Assessment Criteria
 - What are the consequence of brick/block failure for core integrity?

- Whole core graphite behavioral model requires:
 - Stress analysis, constitutive equation
 - $-\varepsilon_{Total} = \varepsilon_e + \varepsilon_t + \varepsilon_d + \varepsilon_c$
 - Core temperature (T) and dose distribution (γ)
 - Dimensional change data and model
 - Creep data and model, f (T, γ , σ)
 - Property change data and models, Tc, CTE, E, σ as a f (T, γ)

- Fracture Model or Failure Theory
 - Weibull model
 - Burchell model
 - CARES model
 - Fracture Mechanics
 - Maximum Deformation Energy Theory (ASME)
 - Maximum Strain Energy Theory
 - Maximum Principal Stress
 - Etc.

- Assessment Criteria
 - Consequence of brick/block failure for core integrity
 - Core structural redundancy
 - Fitness for purpose
 - In core monitoring to confirm predictions and increase confidence in core integrity
 - Replaceable components
Graphite Performance Modeling

- Need to determine the effect of weight loss on property
- Need to predict extent of property degradation
- Work in hand at INL and ORNL to determine oxidation kinetics and effect of oxidation on properties for candidate graphites
- Oxidation is a potential FP transport mechanism

Regulatory challenges

Regulatory Challenges

- For detailed analysis see:
 - NRC Graphite PIRT
 - NRC Graphite Experts Panel Report & Recommendations
- Acceptance/Endorsement of ASME GCC Code
- Assimilating unirradiated baseline characterization data from DOE programs
- Assimilating irradiated properties data from DOE and international (GIF) programs
- HT Stored Energy Release (being addressed)
- Graphite oxidation (effective diffusivity of species)
- Irradiation induced creep, a full understanding (IAEA Coordinated Research Project)

Summary

- > 60 years experience with graphite as a solid moderator
- Mechanism of radiation damage well understood
- A few grey areas remain
 - High temp stored energy release
 - Whole core models (and material models)
 - Irradiation creep
 - Tribology & wear
 - Effective diffusivity (oxidative weight loss)

Bibliography

- Nuclear Graphite The First Years, W. P. Eatherly, J. Nucl. Mater. 100 (1981) 55-63
- Irradiation Behavior of Graphite at High Temperatures, G. B. Engle and W. P. Eatherly, High Temperatures-High Pressures, Vol. 4, pp.119-158 (1972)
- Radiation Damage in Graphite, J.H.W. Simmons, Pergamon Press (1965)
- Nuclear Graphite, R.E. Nightingale (Ed.), Academic Press (1962)
- Radiation Effects in Graphite and Carbon-Based Materials, T. D. Burchell. MRS Bulletin, Vol. XXII, No. 2, pp. 29-35 (1997)
- CARBON MATERIALS FOR ADVANCED TECHNOLOGIES, Edited by Timothy D. Burchell. Pub, Pergamon (Elsevier Science), 1999.
 - CHAPTER 13: FISSION REACTOR APPLICATIONS OF CARBON by Timothy D. Burchell
- Banhart, F. Irradiation effects in carbon nanostructures. *Rep. Prog. Phys.* 1999, 62, 1181–1221.
- Graphite for High Temperature Gas-Cooled Reactors, David Ball, ASME STP-NU-009 (2008)



NRO Intellectual Curiosity Series

Basis for NRC Requirements on Pressurized Thermal Shock

> 6th November 2013 Mark Kirk, RES/DE/CIB



- Properties of metals
- Nuclear reactors: designed against embrittlement
- Pressurized thermal shock (PTS)
 - What is it?
 - How is safety ensured?
 - Specifics of Regulations
- Status at Palisades



- Provide a perspective on vessel embrittlement and PTS, as regulated by the NRC for all PWRs
- Discuss embrittlement and PTS at the Palisades plant
- Answer questions from the public



Ductility & Embrittlement Definitions



Ductile metals bend (absorb energy) when pulled upon

Embrittlement

Embrittlement (a loss of ductility) reduces how much a metal can bend before it breaks

> NRC Regulations limit embrittlement to ensure safety



U.S.NRC Protecting People and the Environment Reactor Pressure Vessels (RPV) Designed Against Embrittlement

€ Pressure >

- The reactor coolant system produces forces on the RPV
 - Pressure
 - Thermal
- RPV designed to resist these forces, even after embrittlement
 - RPV steel has adequate toughness
 - Toughness measures ductility
- NRC screening criteria for embrittlement keeps the probability of fracture extremely low



<u>RPV</u>: Pressurized Cylinder

USANS DE CALLAR RECULATORY COMMISSION Protecting People and the Environment Toughness Always Greater

Before reactor operation force < toughness

After operation (& embrittlement) force (still) < toughness





Embrittlement is Measured NRC Requires: 10 CFR 50 Appendix H



Embrittlement monitored by surveillance programs & limited by regulations

Measured: Transition Temperature Shift Shift Toughness after Operation

Photo courtesy of J. May, AREVA NP GmbH

U.S.NRC INTED NATES NO LEAR RECIPEATORY COMMISSION Protecting People and the Environment

Palisades Surveillance Capsules

Purpose of surveillance

- Monitor embrittlement of specific steels in specific plants
- Provides *advance information* on pressure vessel condition
- Provides data for predictive models

Data sources for Palisades

- Initial program
 - 8 irradiation
 - 2 thermal
- Supplemental program
 - 2 irradiation
- Other Plants
 - Indian Point 2&3
 - H.B. Robinson 2







Palisades Surveillance

Data

- Palisades embrittlement known from 1st capsule pull in 1978
- Licensing dates lie well within data (no extrapolations)
- Data follows expected trends

Some Technical Details

- Program complies with ASTM-185(1966)
 - 10 CFR 50 Appendix H not in force when Palisades was licensed
 - Included high-Cu weld, but not exactly same as in Palisades pressure vessel
- Palisades supplemented surveillance program to get data on limiting weld
 - 2 capsules in Palisades
 - 8 capsules in other plants (HBR, IP)
- 4 capsules remain in Palisades. One more will be pulled before 2031.





Brittle (or Embrittled) Materials Used Safely

<u>Nuclear RPVs</u>

- Steel embrittles over time
- Embrittlement is
 - Understood
 - Measured
 - Limited
- NRC limits transition temperature shift so that toughness always exceeds force
 - Ensures safety

<u>Non-Nuclear Example</u>

- Aircraft landing gear
- Very high strength steels needed to resist landing forces
- High strength steels have lower toughness
 - Less ductile
 - More brittle
- Nuclear RPV toughness exceeds landing gear toughness (even after embrittlement)



Pressurized Thermal Shock

• A rare event

- Designed against
- Regulated for safety

More force applied to RPV during PTS

- Injection of cold water
- Rapid cooling

Even during PTS (& after embrittlement) *force (still) < toughness*



NRC PTS Rules Protecting People and the Environment

10 CFR 50.61 (1984)

- Significant conservatisms restrict operations with no safety benefit
- **Conservatisms include** \odot
 - Over-estimated force
 - Under-estimated toughness
- Conservatisms evidenced by
 - Additional toughness data
 - More realistic & thorough analyses
 - Scale model experiments that validate predictions

10 CFR 50.61a (2010)

- Considerations
 - Conservatisms in 50.61 limits will cause many plant -specific submittals
 - All submittals would address the same fundamental issues
- Alternative approaches
 - Many plant-specific assessments reviewed individually

Comprehensive reassessment of PTS risk Selected) performed proactively & with thorough review by technical experts



Alternative PTS Rule Rigorous Development Process

- Joint effort of NRC, national labs, universities, and industry (providing data & operating experience)
- Approximately 10 year project duration
- Many opportunities for public involvement
- Extensive expert technical reviews

 Advisory Committee for Reactor Safeguards
 Independent expert panel
- Full documentation available on NRC website



Alternative PTS Rule Technical Approach & Insights

Three analyses performed

Analysis		Purpose	
PRA	Probabilistic Risk Assessment	Establish events that cause rapid cooling. Assess human factors.	
TH	Thermal Hydraulics	Quantify force produced by rapid cooling	
PFM	Probabilistic Fracture Mechanics	Quantify resistance to rapid cooling, accounting for embrittlement.	

- Detailed assessments of three plants (Palisades, Beaver Valley, Oconee)
- Results generalized to all plants in USA
 - Only the most severe forces produce any risk
 - Similar across the fleet
 - Rapid cooldown to 200 °F below operating temperature needed to produce any risk
 - Operational controls limit the likelihood of such cooldowns occurring



Comparison of PTS Rules 10 CFR 50.61 & 10 CFR 50.61a

Aspect of Rule	10 CFR 50.61 REQUIRED	10 CFR 50.61a VOLUNTARY
Embrittlement Screening Criteria	More restrictive	Less restrictive
Plant-specific surveillance data check	Required: 1 test	Required: 3 tests
Plant specific inspection for flaws	Not required	Required

- 10 CFR 50.61a embrittlement limits are less restrictive than 10 CFR 50.61
 - Justification: More thorough, consistent, & realistic assessment
- 50.61a screening criteria can only be used when surveillance and inspection requirements are met
- Surveillance and inspection requirements ensure that key features of the 50.61a model apply to the plant being assessed
 - a. The embrittlement of specific RPV materials
 - b. The flaws in a specific RPV



Current Status at Palisades Relative to PTS Limits

<u>10 CFR 50.61</u>

- One of the most embrittled plants in USA
- Palisades operates in compliance
- Embrittlement screening criteria will be exceeded in 2017
- Palisades must
 - Make safety case in 2014 (2017 minus 3 years) for continued operation, or
 - Shut down in 2017
- Options for operation beyond
 2017
 - Annealing to reverse embrittlement,
 - Analysis and/or experiments to provide a plant specific safety justification, or
 - Use 10 CFR 50.61a

<u>10 CFR 50.61a</u>

- One option Palisades has to continue operation after 2017
- Would need to
 - Analyze data
 - Check embrittlement
 - Check flaws
- Generic analysis of US fleet in NUREG-1874 suggests this is a viable option for Palisades

J.S.NRC How Nature Net College and the Environment Palisades Summary

- Palisades continues to operate safely
- The vessel at Palisades is one of the most embrittled in the USA
- Palisades continues to operate as long as it demonstrates compliance with NRC regulations
- There are several options by which continued safe operation of the Palisades vessel after 2017 could be demonstrated
 - The licensee decides what option to take



United States Nuclear Regulatory Commission

Protecting People and the Environment

What's New in Valves and Pumps in New Reactors?

Thomas G. Scarbrough James M. Strnisha

Division of Engineering Office of New Reactors August 2013



Introduction

- Overview of pumps and valves for new reactors
- Lessons learned from operating experience
- ASME and industry activities
- New reactor pump and valve requirements
- Pump and valve qualification process
- Vendor inspection support
- NRC staff approach for evaluation of pumps and valves
- Regulatory Treatment of Non-Safety Systems (RTNSS)
- Small Modular Reactor (SMR) issues
- Close-out process for pump and valve functional qualification ITAAC
- Pump and valve inspections at Vogtle and Summer
- Future activities



Pumps and Valves in New Reactors

- Centrifugal and positive displacement pumps
- Gate, globe, butterfly, and ball valves
- Swing check valves and nozzle check valves
- Power-operated valves including motor, pneumatic, hydraulic, solenoid, and pyrotechnic (squib) operators
- New design squib valves
- Safety and relief valves
- Manual valves in safety applications





Centrifugal Pump (Wikipedia website)





Positive Displacement Pump (http://www.bing.com/images/search)



Gate Valve





Globe Valve





Symmetric Disc Butterfly Valve





Limitorque SMB-0







Electromatic Relief Valve



AP1000 Passive Design

- AP1000 passive pressurized water reactor designed to provide reactor core cooling in response to LOCA without operator action or pump operation for 72 hours
- Passive Core Cooling System (PCCS) uses high pressure Core Makeup Tanks (CMTs) and Accumulators for initial core cooling, and dc-powered motor-operated valves and squib valves to reduce RCS pressure and allow gravity-driven cooling water flow
- After 72 hours, containment makeup water might be needed from external sources



AP1000 PCCS

- PCCS has four passive injection sources:
 - 2 CMTs with borated water at RCS pressure
 - 2 Accumulators with borated water pressurized at 700 psig
 - In-Containment Refueling Water Storage Tank (IRWST) with borated water vented to atmosphere
 - Containment Sump allowing long-term recirculation
- PCCS uses 12 squib valves:
 - Four 14-inch Automatic Depressurization System (ADS)
 4th stage squib valves
 - Four 8-inch IRWST injection squib valves
 - Four 8-inch Containment Recirculation squib valves



AP1000 Squib Valves

- SPX Copes-Vulcan is valve manufacturer
- AP1000 squib valves are larger and more complex than current BWR squib valves in standby liquid control system
- SPX Copes-Vulcan squib valve designs are proprietary



Squib Valve Design and Qualification Issues

- Vendor inspections at Westinghouse, Copes Vulcan, and Wyle Laboratories for squib valve functional design and qualification process
- Several significant issues with squib valve explosive system
- Feb. 20, 2013, public meeting with Westinghouse to discuss need to implement systematic engineering design process sufficient to identify critical parameters of explosive system design and to establish acceptable tolerance ranges for each parameter


AP1000 Squib Valve Surveillance

- Vogtle/Summer FSARs specify that squib valve IST program will incorporate lessons learned from design and qualification process
- Vogtle/Summer COLs include license conditions for AP1000 squib valve surveillance
- License conditions specify preservice and inservice inspection and testing to verify external and internal component integrity, absence of degradation and foreign material, availability of electronic actuation circuitry, and explosive powder output capability



AP1000 Nozzle Check Valves

- AP1000 uses four 8-inch nozzle check valves in PCCS with open-close-open function in event of LOCA.
- AP1000 includes other nozzle check valves with standard open-close functions.
- Enertech is the valve manufacturer.
- Operating plants began using nozzle check valves in 1990s, but limited experience with open-close-open function.
- QME-1 qualification being performed at Enertech in CA and at Utah State University



Enertech website drawing



Pump Issues

- Mini-flow lines insufficient for pump testing
- Required Net Positive Suction Head (NPSHR) uncertainties
- GSI-191 LOCA Debris Issues
- AP1000 Reactor Coolant Pump impeller blade
- Pump Teflon Seal EQ



Valve Issues

- ASME MOV IST stroke-time test inadequate
- Underprediction of thrust and torque requirements for original gate, globe and butterfly valves
- Unpredictable behavior of original gate valves under high flow conditions
- Overprediction of motor actuator output with loading, degraded voltage, temperature, and stem friction
- Valve stem and actuator lubrication issues
- Pressure locking and thermal binding of gate valves
- Valve stem/disc separation
- MOV dead band zone
- Flow induced vibration



Regulatory Activities

- Extensive research program at Idaho National Laboratory on valve performance
- 10 CFR 50.55a revised to supplement ASME Code for MOV periodic design-basis capability
- Bulletin 85-03 and Generic Letters 89-10, 95-07, and 96-05
- Regulatory Issue Summaries 2000-03 and 2001-15
- Numerous Information Notices
- Reviews and inspections of MOV programs at current nuclear power plants
- SRP and inspection procedures updated



ASME Activities

- ASME Standard QME-1-2007 incorporates valve lessons learned with pump improvements being considered
- Subsection ISTF in ASME OM Code (2011 Addenda) for new reactors specifies comprehensive pump testing
- Preservice and inservice testing provisions for squib valves in new reactors specified in Subsection ISTC of ASME OM Code (2012 Edition)
- ASME task group preparing guidance for treatment of RTNSS pumps and valves
- ASME OM Code evaluating SMR pump and valve surveillance issues



Industry Activities

- Electric Power Research Institute developed test-based valve performance methodology
- Joint Owners Group (JOG) developed MOV dynamic testing program in response to GL 96-05 (Guidance in RIS 2011-13 for JOG Class D valves)
- ComEd White Paper 125 (Rev. 3, 2/8/99) provides methodology for sizing motor actuators
- BWROG developed updated methodology for DC MOV output and stroke time



Design Certification Application Requirements

- 10 CFR 52.47(a)(9) requires design certification applications to evaluate design against NRC Standard Review Plan in effect 6 months before docket date
- 10 CFR 52.47(a)(22) requires design certification applications to address operating experience



COL Application Requirements

- 10 CFR 52.79(a)(11) requires COL applicant to provide description of programs and their implementation necessary to ensure that systems and components meet ASME BPV Code and OM Code per 10 CFR 50.55a
- 10 CFR 52.79(a)(37) requires COL applications to include information necessary to demonstrate how operating experience has been incorporated into plant design
- 10 CFR 50.55a(f)(4)(i) requires initial IST program to meet ASME Code incorporated in 10 CFR 50.55a 12 months before fuel loading
- Guidance in RIS 2012-08, Rev. 1, "Developing Inservice Testing And Inservice Inspection Programs Under 10 CFR Part 52"



Pump and Valve Qualification Process

- ASME Standard QME-1-2007 provides specific criteria for qualification process for valve assemblies, extrapolation of qualification to other valve assemblies, testing of production valve assemblies, and post-installation testing
- QME-1 specifies requirements for Qualification Plan, Functional Qualification Report, and Application Report
- NRC accepted QME-1-2007 in Revision 3 to RG 1.100 with staff positions
- New reactor vendors requiring use of QME-1-2007 in design specifications



Vendor Inspection Support

- CIB is providing support for vendor inspections of pumps and valves for new reactors
- Squib valve inspections at Westinghouse, Copes-Vulcan, and Wyle Laboratories
- Check valve inspections at Enertech and Utah State
- Relief valve inspections at Pentair Valves
- Motor-operated valve review during Wyle inspection
- Limitorque MOV actuator inspection
- AP1000 RHR Pumps at Flowserve (post-inspection)



NRC Staff Evaluation of Pump and Valve Design and Qualification

- CIB verifies Design Certification application specifies ASME QME-1-2007 as accepted in RG 1.100 (Rev. 3)
- CIB audits design/procurement specifications in support of design certification and COL application review to confirm use of QME-1-2007
- CIB supports vendor inspections to verify that QME-1-2007 design/procurement specification requirements applied to qualification and testing procedures
- CIB will support operational program and ITAAC
 inspections to address pump and valve qualification



Regulatory Treatment of Non-Safety Systems (RTNSS)

- SECY-95-132 specifies policy and technical issues associated with RTNSS in passive plant designs
- Passive plants rely on active systems to avoid use of passive systems and to provide backup for passive features
- SECY-95-132 states that RTNSS systems do not need to meet safety -related criteria, but staff will expect a high level of confidence that active systems are available
- SECY-95-132 states that specific positions on IST requirements for RTNSS components will be determined as part of staff's review of plant-specific implementation
- No safety-related pumps in AP1000, but specific pumps are within the scope of RTNSS program



AP1000 RTNSS Systems

- Instrumentation Systems
 - DAS ATWS (Diverse Actuation System)
 - DAS ESF
- Plant Systems
 - RNS (Normal Residual Heat Removal System)
 - CCS (Component Cooling Water System)
 - SWS (Service Water System)
 - PCS Water Makeup (Passive Containment Cooling System)
 - MCR Cooling
 - I&C Room Cooling
 - Hydrogen Igniters
- Electrical Power Systems
 - AC Power Supplies
 - Non Class 1E DC and UPS (Uninterruptible Power Supply) System (EDS)



AP1000 DCD RTNSS Provisions

- DCD Tier 2, Section 3.2 provides general technical provisions for Class D SSCs (RTNSS), such as use of example industry standards
- Augmented QA provisions for RTNSS equipment described in DCD Tier 2, Section 17.3
- Each RTNSS component needs to be evaluated on a case-by-case basis for the technical standards and methods used to demonstrate its capability to perform the intended functions
- Specific ITAAC need to be satisfied for RTNSS equipment (such as RNS pumps)



Small Modular Reactor (SMR) Pump and Valve Issues

- Some passive SMR designs may include active systems as part of RTNSS program
- Some SMR designs have operating cycles longer than 2 years which affects relief valve testing frequency provisions and motor-operated valve lubrication basis
- Some SMR designs might use new valve combinations to minimize LOCA conditions
- Environmental qualification of valves and pumps might involve high temperature and radiation



Close-out Process for Pump and Valve ITAAC

- AP1000 DCD includes ITAAC for seismic, environmental, hydrostatic, and functional qualification of specific valves
- Licensee must complete ASME Boiler & Pressure Vessel Code and ASME Standard QME-1-2007 to support qualification testing and analysis
- Licensee will notify NRC staff of ITAAC completion
- NRC staff has identified targeted ITAAC for detailed verification of completion
- NRO projects and technical staff will need to work together to ensure that ITAAC are adequately closed



Pump and Valve Inspections at Vogtle and Summer

- Inspection Procedure IP 73758 describes evaluation of the functional design and qualification, preservice testing, and inservice testing of pumps, valves, and dynamic restraints in new reactors
- CIB will assist Region in evaluating implementation of DCD and FSAR provisions for functional design and qualification, PST, and IST at Vogtle and Summer
- NRC staff will discuss plans for pump and valve inspections with Vogtle and Summer COL licensees when IST program developed



Future Activities

- Support vendor inspections of pumps and valves
- Interact with Westinghouse to address squib valve issues
- Participate in ASME OM Code activities (including RTNSS treatment guidance)
- Interact with Vogtle and Summer COL licensees on IST operational program development
- Assist Region II on operational program and ITAAC inspections
- Work with NRO Projects to evaluate ITAAC closure notifications for pumps and valves

PWR STARTUP AND POWER OPERATION

Background and Disclaimers

- Background and area of focus is predominately primary side operation
- My operational experience includes reactor startup and operation in support of licensed RO and SRO's. Plant Certified at Palo Verde NPGS
- Will not provide detailed Technical Specifications LCOs as these can be plant specific
- Know little about secondary side chemistry and generator

Objective

Explain the basic steps of starting up a PWR reactor from refueling to full power

Typical 4-Loop PWR Primary Side



Typical PWR Modes of Operation

Mode	K _{eff}	Power	T _{cold}
1 - Power Operation	Greater than or equal to 0.99	Greater than 5% RTP	N/A
2 - Startup	Greater than or equal to 0.99	Less than or equal to 5% RTP	N/A
3 – Hot Standby	Less than 0.99	N/A	Greater or equal to 350 °F
4 – Hot Shutdown	Less than 0.99	N/A	200 °F to less than 350 °F
5 – Cold Shutdown	Less than 0.99	N/A	Less than or equal to 200 °F
6 - Refueling	N/A	N/A	N/A

Mode 6 - Refueling

- Fuel is in the reactor vessel
- If all fuel is off loaded to the spent fuel pool Operational Mode is defined as N/A
- Reactor head either removed or not fully tensioned
- Residual Heat Removal (RHR) or Shutdown Cooling (SDC) are in service removing decay heat
- Reactor coolant is highly borated to provide TS minimum shutdown margin
- Source range detectors monitor neutron count rates

Mode 6 – Refueling (cont)

- Fuel is typically loaded nearest the source range detectors first and then work outward
- Refueling pattern is tightly controlled to ensure
 - Assemblies are placed in the correct locations as determined by the core designer
 - Two or more separate "cores" are not formed which may lead to a local criticality

Mode 6 - Refueling (cont)



Mode 6 – Refueling (cont)

- After fuel load core upper internals are reinstalled
- Control Rod drives attached but de-energized
- Reactor head is installed and Mode 5 is entered upon last head bolt being fully tensioned
- "Typical" refueling time 2-3 days

Mode 5 – Cold Shutdown

- T_{cold} is less than ~ 200 °F , Pressure ~300 psia
- RCS is filled and vented using highly borated water from the CVCS system
- Pressurizer level above heater cutoff setpoint but below nominal value (typically ~30%)
- Steam bubble in pressurizer is formed using pressurizer heaters
- Pressure controlled by heaters and auxiliary spray from CVCS system
- Dilution water sources secured or continuously monitored
- LTOPS in service to prevent over pressurization of the RCS

Mode 5 – Cold Shutdown (cont)

- Primary side heat up to Mode 4 Hot Shutdown
 - Start one and then a second RCP to heatup the RCS. Typical RCP output is 4-7 MWs each
 - Control heatup rate using RHR (SDC) heat exchanger flow rate
 - No change in boron concentration and control rods still fully inserted
 - Enter Mode 4 (Hot Shutdown) on RHR or SDC

Mode 5 – Cold Shutdown (cont)

- Secondary side heat up to Mode 4 Hot Shutdown
 - Done in parallel with Mode 5 primary side actions
 - Start a condensate pump to clean up secondary side. Sometimes called long path recirculation.
 - Condensate flow is heated using auxiliary heaters
 - Warm up main feedwater (MFW) pump by using condensate flow through the MFW pump
 - Condenser vacuum is drawn by starting air removal pumps. Normally takes ~ 2hrs.

Mode 4 – Hot Shutdown

- Primary purpose is to transition from RHR (SDC) to steam generator (S/G) heat removal
- Auxiliary feedwater pump and steam generator blowdown lines used to maintain S/G level (~30-50% normal level)
- Turbine or Steam bypass put in service to control RCS temperature and heat up rate
- RHR or SDC heat exchanger bypass reduced; RCS heats up and turbine bypass system controls RCS temperature

Mode 4 – Hot Shutdown (cont)

- Start third RCP to establish a heatup rate
- LTOPS valve are isolated at a given RCS temperature (~300 °F); pressurizer safeties provide RCS over pressure protection
- Depending on SDM requirements some plants may dilute RCS with CVCS system to reduce startup time

Mode 3 – Hot Standby

- Purpose to heat RCS up to normal operating pressure and temperature (~550 °F and 2250 psia)
- Fourth RCP is started to provide additional heat input
- Turbine (steam) bypass controls RCS temperature
- Pressurizer level controlled by CVCS letdown and charging rates. Now at nominal value typically ~50%
- Pressure controlled by RCS temperature and normal pressurizer spray
- Control rod drives energized and rod drop testing occurs
- Dilute to estimated critical boron concentration if starting up using control rods
- Usually most of the startup time is spent in Mode 3

Mode 2 – Startup

- Purpose to achieve a self sustaining chain reaction, k_{eff} =1, and startup physics tests
- K_{eff} = Number of neutrons in generation N/Number of neutrons in generation N-1, including delayed neutrons
- Two methods of going critical
 - Withdrawal almost all control rods and dilute RCS using CVCS system
 - Withdrawal control rods holding boron concentration constant
- All Shutdown rod banks withdrawn then regulating or control rod banks
- Core k_{eff} monitored using source range detectors by a 1/M plot and startup rate meter (SUR)
- Mode 2 is inferred based on data provided by core design




- Measured critical position compared to predictions
- Criticality shall not be achieved with control rods below power dependent insertion limits (PDILs)
- Criticality declared when a sustained, positive startup rate (i.e., count rates increasing) is observed with no reactivity insertion
 - In other words, criticality is declared after the reactor is slightly supercritical
 - Operators insert negative reactivity to achieve $k_{\rm eff}$ equal to one

 HZP is k_{eff} = 1 and plant at standard operating temperature and pressure

- HZP ~ 1X10⁻⁵% power, neutron flux ~(10)⁴ n/cm²-sec

- k_{eff} has noting to do with core power under steady state conditions; core power is proportional to neutron flux level
- Control rods are withdrawn to create a positive SUR
- SUR of less than one decade per minute

- Point of adding heat (PAH) is found when reactivity feedbacks (negative ITC) limits power increase
- GDC 11 "...in the power operation range the net effect of the prompt inherent nuclear feedback characteristics tends to compensate for a rapid increase in reactivity."
- New equilibrium power (neutron flux) is reached additional positive reactivity must be added
- Additional control rod withdrawals add positive reactivity overcoming temperature defects and Xenon buildup

- Main feedwater pump brought online around 2% RTP (System 80 number)
- Mode 2 takes ~2-3 days including physics testing
- Mode 1 declared when core power is greater than 5% RTP

Mode 1 – Power > 5% RTP

Following is for typical System 80 plants

- Power increased to ~12% RTP using control rod withdrawals
- Turbine-Generator is put online ~12% RTP
 - Turbine bypass values close as turbine control valves open
 - Core power is now governed by steam demand
- Power is increased to ~20% RTP by increasing turbine load and withdrawing control rods to stay on the T_{avg} program
- Reactivity changes now affect reactor core temperature not reactor power (assuming quasi, steady-state operation)
- At 20% RTP incore flux maps are performed to check for misloaded or mis-manufactured fuel assemblies, or problems with reactor physics models
- Boron dilution, using the CVCS system, maintains the program average temperature as power increases



% RTP Power

- Normally measured T_{avg} is kept within 1 °F of programmed T_{avg} (T_{reff})
- Power is increased to 50-65% RTP and second feedwater pump is brought online (System 80 has two feed water pumps)
- Plant is stabilized at 70% RTP for additional incore flux maps and excore detector checks
- Power is increased to 90% RTP and held for final excore calibration to the secondary side calometric
- Power is increased to 100% RTP and final power ascension flux map is performed

- At 70 and 100% RTP measured peaking factors checked against predicted values for TS surveillance
 - Ensures DNBR margin is available for possible AOOs
- At 100% RTP neutron flux is ~(10)¹⁴ n/cm²-sec or 10 decades above HZP
- Boron is added or removed for minor power changes, fuel and burnable poison depletion

Thanks for your attention





Reactor Vessel and Internals: History, Issues & Resolution Neil Ray May 2, 2013



SCHEMATIC OF BWR PLANT



Reactor Vessel: Facts and Fictions

Operating the plant for years, why does it take more time to startup/shutdown now—did not modify the RV?

Plant is operating so long—how vessel material properties changed?

RV is the only component for which the plant was forced to shut down (which one?)

RV never repaired or replaced -yet

RV never annealed in USA; however it was done several times in Russia

"Pressurized Thermal Shock (PTS) is like pouring cold water in a hot glass"

Reactor Vessel

Back Ground : Reactor Vessel

Reactor vessel construction

- Vessels designed and built per ASME Section III (prior to Section III, some vessels were built per Section I and VIII)
- Major types of construction in existing plants
 - Steel plates formed and welded to produce vessel structure
 - Ring forging, eliminated the longitudinal welds

Reactor Vessel (Cont'd)

U.S. Reactor vessel manufacturer

- B & W and CE manufactured their own vessels
- Westinghouse used other manufacturers:
 - B & W
 - CE
 - Chicago Bridge and Iron
 - Roterdam Dockyard Co
 - Creusot-Loire
 - MHI

Reactor Vessel (Cont'd)

BWR vessel materials and manufacturer

• Most of the vessels were manufactured by B&W, CE, and Chicago Bridge and Iron

Stainless steel cladding was used on the inside surface of the vessel (PWRs and BWRs) to minimize general corrosion

Reactor Vessel (Cont'd)

Typical current vessel thickness/radius (at beltline)

- Westinghouse
 - 4 loop 8.625/86.5 in; 3 loop 7.88/78.5 in; 2 loop 6.5/66 in
 - Combustion Engineering: 8.5-8.62/86-86.8 ;System 80: 11.19/97.1
 - B & W: 8.44/85.5
 - GE : 90-140

AP1000: 8/78.6 EPR: 9.84/97.2 USAPWR: 8/79.5 ESBWR: 7.05/140 ABWR: 6.85/140

Issues Affecting Reactor Vessel Integrity

Fatigue Underclad cracking Radiation Embrittlement

- Pressurized Thermal Shock (PWRs)
- Heatup Cooldown Limits
- Hydrotest/Leak test
- Upper Shelf Energy

Radiation Embrittlement

- Displacements caused by high energy neutrons can change the metal microstructures
- Mechanical properties are affected by subtle changes in the microstructure
- Increase in yield strength can produce a shift in the ductile to brittle transition temperature (ΔTT)
- Embrittlement results in an increase in Charpy transition temperature and drop in upper-shelf energy (Δ USE)

Radiation Embrittlement In Pressure Vessel Steels (cont'd)

Effect of Radiation Embrittlement



Radiation Embrittlement In Pressure Vessel Steels (cont'd)

Code of Federal Regulation adopted 10CFR50, Appendices G and H requirements for fracture toughness and materials surveillance (1972)

NRC Regulatory Guide 1.99, Rev. 1 established embrittlement curve prediction method (1977)

Radiation Embrittlement In Pressure Vessel Steels (cont'd)

Reg. Guide 1.99, Rev. 2 updated trend curves to include copper and nickel predicting embrittlement in vessel materials (1988)

- Temperature dependant
- Material chemistry dependant
- High phosphorous RV cannot use Reg. 1.99, Rev 2 Reg. Guide 1.99, Rev. 3 currently under development

Pressure-Temperature Limits: Highlights

 $2 \text{ K}_{\text{IM}} + 1.0 \text{ K}_{\text{IT}} < \text{K}_{\text{Ic}}$

Other factors affecting composite curves:

- Boltup temperature
- IO CFR50 rule for closure flange regions: when pressure exceeds 20% of pre-service hydrostatic test pressure (621 psig for Westinghouse plants), temperature of closure flange regions must be >120°F plus initial reference temperature of material in those regions for normal operation and >90°F plus reference temperature for leak tests.
- **Criticality limits:** P-T limits for core operation are that the reactor vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40° F higher than the minimum permissible temperature in the corresponding P-T curve for heatup and cooldown.

Effects of Radiation Embrittlement on P-T limits



Reactor coolant temperature

Pressurized Thermal Shock: Definition

PTS

- An event or transient in PWRs causing severe overcooling (thermal shock) concurrent with or followed by significant pressure in the reactor vessel
- A PTS concern arises when
 - A PTS transient occurs on the beltline region of a reactor vessel
 - The beltline region has a reduced fracture resistance because of neutron radiation, and
 - A flaw exists near the inner surface of the vessel wall

Current PTS Rule

- Established RT_{PTS} screening criteria (measure of fracture resistance)
- 270° F for plates, forgings, axial welds
- 300° F for circumferential weld materials
- All plants submitted RT_{PTS} values for end-of-license
- Plant-specific analysis within 3 years of reaching screening criteria

Basis for PTS Rule

The current PTS rule attempts to minimize risk of vessel failure by limiting the level of vessel embrittlement using a single index

Screening criteria is a function of

- Materials
- Fluence
- Transients

PTS Status for Current Reactors

NRC currently estimates that following 10 CFR 50.61, following plants will exceed PTS screening criteria during extended life:

- Point Beach 2 (2017)
- Palisades (2017)
- Diablo Canyon 1 (2033)
- Indian Point 3 (2025)
- Beaver Valley 1 (2033)

It is expected these plants may be able to qualify PTS using 10 CFR 50.61a

All other existing PWRs will not have any PTS issue during extended life

PTS Status: New Reactors

Based on the projected material properties and the radiation embrittlement

• New PWRs currently under NRC review will not have any PTS issues using the current criteria (10 CFR50.61)

Upper Shelf Fracture Toughness

RV beltline materials must have Charpy uppershelf energy in the transverse direction for base material and along the weld for weld material of no less than 75 ft-lbs initially and must maintain no less than 50 ft-lbs unless it is demonstrated and accepted by the NRC (10 CFR Part 50, Appendix G)

For materials falling below 50 ft-lb, perform an equivalent margin fracture mechanics analysis

Addressing issues related to P-T, PTS, and USE: Current Reactors

P-T Limits

- Changed from $2K_{IM}+1.25K_{IT} < K_{IR}$ to $2K_{IM}+K_{IT} < K_{IC}$
- Reducing heatup/cooldown rates: longer time, cost money
- P-T, PTS, USE
 - Flux reduction: rearranging the burned fuel
 - Neutron shield: stainless steel shielding around the core
 - Annealing
 - Revisiting PTS rule: 10 CFR 50.61a published

Reactor Vessel Integrity: PWR Vs. BWR (cont'd)

BWR does not use boron for controlling reactivity except in emergency

Bottom head penetrations

- PWR
 - Westinghouse: yes
 - B & W: Yes
 - C E: No, except Palo Verde
- BWR: Yes (includes CRDM and BMI)

PWR vessels: cladding the entire vessels BWR vessels: No cladding in upper heads

Reactor Vessel Integrity: PWR Vs. BWR

- Because of BWR's higher vessel diameter and fuel design, it accumulates less EOL fluence.
- PTS is not a concern for BWR
- BWR hydro problematic with higher embrittlement of vessel

PWR: Can quickly heatup by using higher capacity reactor coolant pump, but limited by conflicting requirements (e.g., pump seal, NPSH, LTOP)
Addressing Issues: New Reactor Vessels

Radiation embrittlement

- Additional shielding to reduce cumulative fluence
- Reduced Cu/Ni content
- Eliminate beltline weld (AP1000 & ESBWR)
- Start with higher USE
- One P/T limit for 60 years
- PTS issues resolved (PWR only)

Reactor Vessel Internals



Ĉ

ĉ

3





PWR RVI Components/Susceptible Components

RVI components: (1) Plenum Assembly—top of the fuel assembly and supports the CRGT assembly and (2) Core Support Assembly which sits on top of core barrel assembly

Susceptible components—Baffle bolts, former bolts—Impacted by IASCC

Primary components

- core support shield (CSS) top flange, outlet nozzle, vent valve, upper and lower core barrel bolts—Impacted by SCC, wear, and thermal embrittleemnt in CASS valves
- core barrel assembly- baffle plates, baffle-to-former bolts, baffle-to-baffle bolts—Impacted by IASCC, neutron embrittlement, void swelling, irradiation-enhanced stress relaxation, fatigue and wear

Degradation Mechanisms: Internals

PWRs are exposed to higher neutron fluence than the BWRs During the license renewal period, the PWR RVI components are susceptible to IASCC, neutron embrittlement, void swelling and irradiation-enhanced stress relaxation

In BWRs predominant aging degradation mechanism is IGSCC and it is due to higher (than the PWRs) oxygen content in RCS water.

- BWR normal water chemistry—200 ppb dissolved oxygen, 10 ppb dissolved hydrogen
- BWR hydrogen water chemistry (HWC) 1 ppb dissolved oxygen, 300 ppb dissolved hydrogen
- BWR HWC + Noble Metal Chemical Addition (NMCA) 60 ppb dissolved oxygen, 30 ppb dissolved hydrogen-The exact water chemistries depend on the location inside the reactor vessel

Degradation Mechanisms: Internals

Predominant aging mechanism—IGSCC which occurs due to the presence of tensile stress, oxygenated water [normal water chemistry (NWC)]-- 200 ppb, and sensitized stainless steel—Cold work can enhance IGSCC even in 316L material—steam dryers

Addition of hydrogen ties up the oxygen and reduces IGSCC

Protection is achieved when hydrogen water chemistry (HWC) is available for 80% of the total time at power operations or hot standby conditions

Noble metal chemical addition (NMCA) + HWC will reduce the crack growth rates. HWC+NMCA will be effective only in water and they are least effective in steam phase or in duel phase(water and steam). HWC+NMCA should be present in RCS water at a minimum of 90% of the total time at power operations or hot standby conditions

Addressing Issues in New Reactor: Internals

Internals degradation

- Core barrel/core shroud
 - AP1000/EPR/USAPWR-reduced cumulative fluence
 - ESBWR- "L" grade austenitic stainless and Alloy 600
 - AP1000/EPR/USAPWR-"L" grade austenitic stainless steel
 - Significant change in design in all new reactors

Steam Dryer

- ESBWR/ABWR- avoid synchronized frequency
- Use of "L" grade austenitic stainless steel
- Support modified

Few words on SMRs

iPWRs: mPower, NuScale, Westinghouse

- NSSS is inside the RV
- NSSS is inside the RV: does it mean it is internal and no analysis needed?
- Neutron shield inside RV

HTGR: RV vessel is about twice the size of two AP1000 vessel

- Different environment
- High temperature issues

More Questions ?



Suggested Regulatory Modifications to

Effectively Regulate I&C Diversity

for Advanced Reactors

Ken Mott NRO / DE / ICE1 August 5th, 2010

Agenda

Anticipated Transient Without Scram System

- Regulations, Policy and Guidance
- Purpose for Implementation

Diverse Actuation System

-Regulations, Policy and Guidance

-Purpose for Implementation

Comparison of ATWS and DAS Systems

Suggested Regulatory Modifications for Diversity Evaluations

-10 CFR 50.62 and SRM to SECY-93-087

-NUREG/CR-6303 and NUREG/CR-7007

Anticipated Transient Without Scram Regulations and Guidance

Regulation

10 CFR 50.62, "Requirements for Reduction of Risk from Anticipated Transients Without Scram (ATWS) Events for Light-water-cooled Nuclear Power Plants

Each pressurized water reactor must have equipment ..., that is diverse from the reactor trip system, to automatically initiate the auxiliary (or emergency) feedwater system and initiate a turbine trip under conditions indicative of an ATWS.

Guidance

Standard Review Plan Section 7.8, Diverse Instrumentation and Control Systems

The objectives of this review are to assure that the ATWS mitigation systems and equipment are designed and installed in accordance with the requirements of 10 CFR 50.62.

Purpose for Implementation

Reduce the probability of unacceptable consequences following anticipated operational occurrences. [49FR26040]

Diverse Actuation System Regulations and Guidance

Regulations

10CFR Part 50, Appendix A, General Design Criterion 22, Protection System Independence.

The protection system shall be designed to assure that the effects of ... postulated accident conditions on redundant channels do not result in loss of the protection function.... Design techniques, such as functional diversity or diversity in component design and principles of operation, shall be used to the extent practical to prevent loss of the protection function.

<u>Policy</u>

SRM to SECY-93-087, Item II.Q, Defense Against Common-Mode failures in Digital Instrumentation and Control Systems

The vendor or applicant shall analyze **each** postulated common-mode failure for **each event** that is evaluated in the accident analysis section of the safety analysis report (SAR) using best-estimate methods. The vendor or applicant shall demonstrate adequate diversity within the design for each of these events

Purpose for Implementation

Defense Against Common-mode Failures in Digital Instrumentation and Control Systems

Comparison of ATWS and DAS Systems Functionality

Protection System

Reactor Trip Portion

Comparison of ATWS and DAS Systems continued

[covering PWRs only]

Initiate Turbine Trip

Initiate Auxiliary/Emergency Feedwater

Diverse Scram [for CE or B&W only] Initiate either the same protective function or a different function as failed protection system

Deterministic Analysis [10CFR100 limits]

Reactor Coolant System and/or Containment Integrity

Suggested Regulatory Modifications for Diversity Evaluations 10 CFR 50.62 and SRM to SECY-93-087

The DAS Policy, SRM to SECY-93-087, may supersedes the ATWS Rule, 10CFR50.62, for new generation plants

-The best estimate analysis covers postulated common-modefailures for SAR events which includes ATWS events

The SRM to SECY-93-087 is probably more significant to safety than 10CFR50.62

-Far greater purpose than ATWS Rule (10CFR50.62)

-PWR certification applicants are currently designing 60 year DAS systems against SRM to SECY-93-087 policy

CONCLUSION:

-SRM to SECY-93-087, Item II.Q, should be a Rule.

Suggested Regulatory Modifications for Diversity Evaluations NUREG/CR-6303 and NUREG/CR-7007

NUREG/CR-7007 Diversity Modifications to NUREG/CR-6303

NUREG/CR-6303 [1994]

Design diversity

Equipment diversity

Functional diversity

Human diversity

Signal diversity

Software diversity

NUREG/CR-7007 [2010]

Design diversity

Equipment manufacturer

Logic processing equipment

Functional diversity

Life-Cycle

Signal diversity

Logic diversity

Suggested Regulatory Modifications for Diversity Evaluations NUREG/CR-6303 and NUREG/CR-7007

NUREG/CR-6303, Method for Performing Diversity and Defense-in-Depth Analyses of Reactor Protection Systems [1994]

- -Does not provide the applicant with any certainty of having adequate and/or sufficient diversity within the proposed design
- -Design details for modern I&C component diversity evaluation are vague, lacking

NUREG/CR-7007, Diversity Strategies for Nuclear Power Plant Instrumentation and Control Systems [2010]

-Provides Modified Diversity attributes for modern I&C designs

-Provides Diversity Evaluation Tool (Excel spreadsheet based tool)

-Provides design threshold for diversity evaluation

CONCLUSION:

NUREG/CR-7007 should replace NUREG/CR-6303 with all pertinent information being incorporated into NUREG/CR-7007.

Summary of Suggested Diversity Modifications

SRM to SECY-93-087, Item II.Q, should be a Rule

NUREG/CR-7007 should replace NUREG/CR-6303 with all pertinent information being incorporated into NUREG/CR-7007.

Questions

REFERENCES

10 CFR Part 50

[http://www.nrc.gov/reading-rm/doc-collections/cfr/part050.html]

SRM to SECY-93-087, Item II.Q, Defense Against Common-Mode failures in Digital Instrumentation and Control Systems [ADAMS Accession No. ML003708056]

NUREG/CR-6303, Method for Performing Diversity and Defense-in-Depth Analyses of Reactor Protection Systems [ADAMS Accession No. ML071790509]

NUREG/CR-7007, Diversity Strategies for Nuclear Power Plant Instrumentation and Control Systems [ADAMS Accession No. ML100880143]

Generic Letter 85-06, Quality Assurance Guidance for ATWS Equipment that is not Safety-Related [ADAMS Accession No. ML031140390]

Branch Technical Position 7-19, Guidance for Evaluation of Diversity and Defense-indepth in Digital Computer-based Instrumentation and Control Systems

[ADAMS Accession No. ML070550072]

Station Blackout and Emergency Diesel Generator

Station Blackout: Amar Pal

Station Blackout and Fukushima Event: Roy Mathew

Emergency Diesel Generator Reliability and Testing: Om Chopra

STATION BLACKOUT AMAR N. PAL NRO/DE/ICE

Definition

Station Blackout means the complete loss of alternating current (ac) electric power to the essential and nonessential switchgear buses in a nuclear power plant (i.e., loss of offsite electric power system concurrent with turbine trip and unavailability of the onsite emergency ac power system). Station blackout does not include the loss of available ac power to buses fed by station batteries through inverters or by alternate ac sources.

Why concern for SBO

- Unacceptable consequences Ultimate Core Melt/ Containment Failure
- Many total and partial LOOPS have occurred.
- Many EDG failures.
- Risk Analysis showed SBO important Risk Contributor (WASH 1400-1975, NUREG- 1032)

Regulation

10 CFR 50.63, "Loss of All Alternating Current Power" (Station Blackout Rule) became effective July 1988. The regulation requires that each light-water-cooled nuclear power plant licensed to operate under 10 CFR Part 50, each light-water-cooled nuclear power plant licensed under subpart C of 10 CFR part 52 after the Commission makes the finding under § 52.103(g) of this chapter, and each design for a light-water-cooled nuclear power plant approved under a standard design approval, standard design certification, and manufacturing license under part 52 of this chapter must be able to withstand for a specified duration and recover from an SBO. Additionally, the reactor core and associated coolant, control, and protection systems, including station batteries and any other necessary support systems, must provide sufficient capacity and capability to ensure that the core is cooled and appropriate containment integrity is maintained in the event of an SBO for the specified duration.

The staff issued RG 1.155 to describe a method acceptable for complying with the Commission regulation.

The industry issued NUMARC 87-00 to provide guidance and methodologies for implementing SBO initiatives. The staff endorsed Rev. 0 of NUMARC 87-00.

Coping duration

Emergency ac power configuration group, EDG Reliability, Offsite power design characteristic group

Operating plants – 4 hours to 16 hours

New Plants

- Passive Design (Coping with battery for 72 hours)
- Non-Passive Design (8 hours)

Coping Method

Operating Plants

Battery - 41 Plants (23 PWRs and 18 BWRs)

Alternate ac (AAC) power source - 67 Plants (DG, CTG, GTG, Appendix R DG, Hydro Power, EDG Excess Capacity, EDG Excess Redundancy)

- Single Unit Site AAC must have capability for safe shutdown (Hot standby or hot shutdown) of the unit.
- Multi Unit Site
 - At multi-unit sites, where emergency ac is not shared, AAC must have capability for safe shutdown of any of the units. One unit will be in SBO condition.
 - At multi-unit sites, where emergency ac is shared, AAC must have capability for safe shutdown of all units. All units will be in SBO condition.

New Plants

Passive Design (battery)

Non-Passive Design (AAC power with diverse design per unit) (SECY-90-16 and 91-078)

<u>Alternate ac power source (NUMARC 87-00, Appendix B)</u>

AAC power source must meet NUMARC 87-00, Appendix B. These are:

Items B.1 and B.2 require that the AAC system need not be Class 1E or be protected against seismic events or failure or misoperation of other plant equipment.

Item B.2 requires that the AAC system be protected against likely weather related events.

Items B.4, B.5, B.6, and B.7 require that AAC source be physically and electrically separated (normally) from safety-related equipment or the preferred or onsite emergency ac power system so that it will not adversely impact this equipment or these systems.

Items B.8(a) through B.8(c) require that the AAC system have its own dc power source, air start system, fuel supply, and other support systems to minimize potential common cause failure of the AAC source and the onsite emergency ac power systems.

- Item B.8(d) requires that corrective action be taken for failures common to the AAC source and the onsite emergency ac power systems.
- Item B.8(e) requires that a likely weather related event or single failure would not simultaneously fail the AAC source and the preferred and onsite emergency power systems.
- Item B.8(g) requires that the AAC system be tested following maintenance activities.
- Item B.9 requires that the AAC source be tested to demonstrate that it has the capacity and capability to maintain acceptable voltage and frequency while powering the SBO loads.
- Item B.9 also states that the opposite unit of a multi-unit site may be used as AAC source provided it has sufficient excess capacity to simultaneously power the SBO loads of the blacked-out unit and the LOOP loads of the associated unit.
- Items B.10 through B.12 require that the AAC source initially tested, periodically tested including timed start test, and periodically surveyed and maintained.
- Item B.13 requires that the AAC source maintain a 95% reliability/availability

AAC Time Classification

Ten minute AAC – AAC must be connectable to SBO load buses within 10 minutes. Does not require powering the loads within 10 minutes.

One hour AAC – Can power SBO loads within one hour. An AAC source that can power the loads in less than one hour (i.e., 30 minutes) is classified as one hour AAC.

Coping Analysis

No coping analysis for 10 minute AAC plants

One hour coping analysis for AAC plants with greater than 10 minutes but less than one hour

Coping analysis for the coping duration for coping with battery.

SBO coping capability

- Condensate inventory for decay heat removal
- Class 1E battery capacity (load shedding after 30 minutes)
- Compressed air
- Effects of loss of ventilation
 - Control room and I&C cabinet room
 - Inverter room
- Containment isolation
- Reactor coolant inventory
- Communication and portable lighting

Procedures and Training (NUMARC 87-00)

(1) <u>SBO response guidelines</u>

- Actions necessary to restore offsite power
- Actions to assure shutdown equipment is operable
- Actions to assure operability of AFWS/HPCIS/HPCS/RCICS
- Actions to prevent reactor inventory loss
- Actions to establish a flow path from the CST and to transfer to alternate sources
- Identification and actions to strip dc loads
- Actions to permit appropriate containment isolation
- Actions to permit safe shutdown valve operations
- Identification of portable lighting
- Identification of effects of ac power loss on area access

- Actions to identify and mitigate effects of loss of ventilation:
 - Monitoring of room and cabinet temperatures
 - Actions to provide supplemental cooling
 - Actions to override HPCIS/RCICS on high temperature
 - Opening room and/or cabinet doors
 - Consideration of effects of high temperature on fire protection features
- Consideration of habitability requirements
- Actions to compensate for loss of heat tracing

(2) <u>AC power restoration</u>

- Alternate methods of restoring power to nuclear units
- High priority to restoring at least one transmission line
- Priority for necessary manpower, equipment and materials
- Actions to obtain portable ac generator and associated equipment
- Upon restoration of ac power, actions to connect restored ac power to shutdown equipment
(3) Severe weather guidelines

- (a) Preparation for a hurricane
 - Procedures should identify site-specific actions including following:
 - Identification and elimination of potential missiles
 - Assuring adequacy of site staff
 - Restoring out of service equipment to service
 - Warming and lubrication standby ac sources
 - Ensuring availability of AAC source (if available)
 - Increasing CST inventory
 - Placing battery charger in service
 - Testing EDGs
 - Procedures should provide for identification of and method of contacting additional support staff
 - Procedures should specify actions necessary to ensure equipment required for station blackout response is available.

- (b) Actions Prior to arrival of hurricane at site
 - Ensure that plant is in safe shutdown two hours prior to anticipated arrival of hurricane (wind speed > 73 mph)
 - Operator review of station blackout procedures
 - Operator review (if applicable) of procedures for switchyard spray down systems
- (c) Actions for a Tornado
 - Identification and elimination of potential missiles
 - Restoring out of service equipment to service

Challenges

10 minute clock

- NUMARC 87-00, Rev. 1, Appendix I, Response to Question 65 allow time to perform the immediate steps in the EOPs to verify scram, primary system parameters, etc., and attempt to restore offsite power and start EDGs from the control room. SBO clock starts after the failure of restoring offsite and onsite emergency ac power. Some plants took 15 minutes to perform above actions.
- 10 minute clock starts as soon as losses of offsite and onsite power occur.

SBO procedures for passive plants

- ESBWR DCD initially indicated that RG 1.155 is not applicable to passive design. In response to staff's RAI, the applicant revised DCD to include that RG 1.155 regarding SBO training and procedure is applicable to ESBWR design.
- AP 1000 COLA applicants provided SBO procedures in response to RAI.

Switchyard breakers dc power availability for offsite power restoration

- Switchyard breakers have one closing coil and two trip coils. Switchyard breakers are provided with redundant dc power supplies. ACRS members are concerned about availability of dc power with the failure of one dc power source for offsite power restoration.
- Additionally, switchyard battery duty cycle should be consistent with coping duration

AAC power source capacity for cold shutdown

- SECY-91-016 recommends that new plants should have an AAC power source of diverse design and should have sufficient capacity to operate the systems necessary for coping with an SBO for time necessary to bring and maintain the plant in a safe-shutdown condition including cold shutdown.
 - ABWR design- AAC source (GTG) has enough capacity to bring the reactor to cold shutdown condition, can be made available within 10 minutes and has 7-day supply of fuel.
 - USAPWR design AAC source (GTG) has enough capacity to bring the reactor to cold shutdown condition, can be made available within one hour and has 7 day supply of fuel.
 - EPR design AAC source (DG) does not have enough capacity to bring the reactor to cold shutdown condition and has 24-hour supply of fuel but can be made available within 10 minutes. The applicant follows the safe shutdown definition for SBO which means bringing the plant to hot standby.
- New reactor with passive designs have ancillary diesel generators, in addition to standby diesel generators, designed to provide the post 72-hour power requirements following an extended loss of all power sources. ESBWR design provides 7 days fuel capacity. AP1000 design provides 4 days fuel capacity.

<u>References</u>

- 10 CFR 50.63
- RG 1.155
- NUMARC 87-00
- SRP 8.4
- SECY-90-16
- SECY-91-078
- Temporary Instruction 2515/120
- WASH 1400-1975
- NUREG-1032
- NUREG- 1109

Station Blackout and Fukushima Event

Roy K. Mathew Electrical Engineering Branch Division of Engineering

Station Blackout Background

WASH-1400, "Reactor Safety Study," issued 1975, indicated that station blackout (SBO) could be an important contributor to the total risk from nuclear power plant accidents

In 1980, the Commission designated the issue of station SBO as Unresolved Safety Issue (USI) A-44, "Station Blackout" NRC issued the final SBO Rule (10 CFR 50.63) on June 21, 1988

NRC issued Regulatory Guide (RG) 1.155, "Station Blackout," on August 1988 and endorsed NUMARC 87-00 industry guidance to implement the SBO Rule

Station Blackout Requirements

U.S. Plants

Each light-water-cooled nuclear power plant be able to withstand and recover from a station blackout (i.e., loss of the offsite electric power system concurrent with reactor trip and unavailability of the onsite emergency ac electric power system) of a specified duration (two to sixteen hours). (10 CFR 50.63)

Japanese Plants

The nuclear power plant shall be provided with batteries that have capacity required to ensure that [they can] safely shutdown the reactor and cool it down after its shutdown even in the event of a loss of all alternating current (AC) power for a short period time. (Article 33)

The nuclear reactor facilities shall be so designed that safe shutdown and proper cooling of the reactor after shutting down can be ensured in case of a short-term total AC power loss. (Regulatory Guide - Guideline 27)

Fukushima Site





Fukushima Electrical System



25



Unit 5/6 during outage



27

Power supply of Unit 5/6 @ 1F



		Fukushima Daiichi											
		Unit 1		Unit 2		Unit 3		Unit 4		Unit 5		Unit 6	
		Equipment Name	Status	Equipment Name	S atus	Equipment Name	Status	Equipment Name	Status	Equipment Name	Status	Equipment Nome	Status
EDG (ac) = air cooled		EDG 1A	×	EDG 2A	×	ÉDG 3A	x	FDG 4A	x	EDG 5A	(2)	FDG 6A	(2)
		IDG 1B	×	EDG 2B (ac)	(1)	FDG 3B	×	EDG 4B (ac)	(1)	EDG 5B	(2)	EDG 6 8 (ac)	
]					i 				e.a	HPCS FDG	(2)
6.9 kV Electrical Distribution	Vital	17/010	×	M/C 2C	×	M/C 3C	×	M/C 4C	×	M/C SC	×	M/C 6C	2
		L 1/C 1D	x	M/C 2D	×	M/C 3D	×	M/C 40	x	M/C 5D	×	M/C 6D	5
				M/C 2E	x			M/C 4F	x			HPCS M/C	۰ ۲
	Non-Vital	ri/cita		M/C 2A	×	M/C 3A	×	M/C 4A	×	M/C 5A	×	M/⊂ 6A-1	; X
												M/C 6A-2	<u>×</u>
		17/C 1B	х	M/C 2B	×	M/C 3B	×	M/C 4B	x	M/C SB	×	M/C 68-1	x
												M/C 68-2	<u>×</u>
		17/C 15	x	M/C 25A	× ×	M/C 35A	×			M/C 55A 1	×		
										M/C 55A-2	×		
				M/C 25B	x	M/C 358	×			M/C 558-1			
										M/C 558-2	×		
480V Power Centers (P/C)	Vtal	7C 1C	×	P/C 2C	<u> </u>	P/C 3C	×	P/C 4C	0	P/C 5C	×	P/C 6C	5
		/C 10	- ×	P/C 2D		Р/СВР	×	P/C 4D	0	P/C 50	×	P/C 6D	0
				P/C 2F	× ×			P/C 4E	x			P/C 6E	0
	Aor Vda	°/⊂ 1A	×	P/C 2A		P/C 3A	×	P/C 4A	0	P/C 5A	x	P/C 6A-1	×
				P/C 2A-1	×			-		P/C SA-1	Ð	P/C 6A-2	×
		*/C 18	×	P/C 28	<u> </u>	P/C 3B	×	P/C 48	<u> </u>	P/C 58	x	P/C 6B-1	×
			L							P/C 58-1	o	P/C 66-2	×
		2/C 1S	×			P/C 3SA	×		l	P/C SSA	8	•-	
]		ĺ					••	P/C 55A-1	×		
				P/C 25B	x	P/C BSB	×			P/C SSB	x		
Di Pawa	17W	C C 125V m ain bus A	× .	DC 125V P/C 2A	×	DC 125V main bus 3A	o	DC 125V main bus 4A	×	DC 125V P/C 5A	Ċ	DC 125V 6A	Ð
		C C 125V main bus B	×	DC 125V P/C 28	×	DC 125V main bus 3B	o	DC 125V main bus 48	×	DC 125V P/C 5B	o	DC 125V 6B	0
SHN		sw	×	RHR-S A	×	RHR-S A	×	RHR-S A	x	RHR S A	x	RHRSA	×
				RHR-S B	×	R∺R-S B	<u>x</u>	RHR-S B	x	RHR-5 B	×	RHRSE	×

Status:

x: damaged

o: available

Key:

White background: Not damaged by the earthquake or tsunami

Blue background: Damaged or flooded by tsunami

Gray background: Support systems damaged or flooded by tsunami

(1): electrical distribution damaged or flooded

(2): ultimate hat sink damaged or flooded

Figure 7.4-7 Fukushima Daiichi Electrical Distribution Damage¹²

¹² "Overview of Accident at TEPCO Fukushima Nuclear Power Stations," July 22, 2011 - Tokyo Electric Power Company Co.

NRC ACTIONS - FUKUSHIMA EVENT

The Near Term Task Force (NTTF) issued Report on July 12, 2011

Recommended the Commission use orders to ensure that licensees take Near-Term Actions until requirements associated with future rulemakings can be implemented. Examples include:

✓ to reevaluate the seismic and flooding hazards at their sites

- to perform seismic and flood protection walkdowns to identify and address plant-specific vulnerabilities
- ✓ to provide reasonable protection for equipment currently provided pursuant to 10 CFR 50.54(hh)(2)
- vto provide safety-related ac electrical power for the spent fuel pool makeup system.

Recommended the Commission strengthen SBO mitigation capability for design-basis and beyond design basis external events through amending the existing rule (10 CFR 50 63)

Status of SBO Rulemaking (Cont.)

Commission directed the staff in SRM SECY-11-0124 dated October 18, 2011, to implement the lessons learned from the Fukushima accident within five years - by 2016

- Initiate the SBO rulemaking as an Advanced Notice of Public Rulemaking (ANPR)
- Designate the SBO rulemaking as a high-priority rulemaking with a goal for completion within 24-30 months

Monitor nuclear industry efforts to strengthen coping times and consider any interim controls required

Status of SBO Rulemaking (Cont.)

The staff is currently developing the ANPR package

<u>Schedule</u>

- □ Issue ANPR By April 2012
- □ Conduct Public Meetings 2012
- Address External Stakeholders Comments 2012
- □ Proposed Rule to Commission April 2013
- □ Final Rule to Commission April 2014

Emergency Diesel Generator Reliability and Testing Om Chopra ICE/DE/NRO

Emergency Diesel Generator (EDG) Reliability and Testing

EDG Testing

- Qualification testing
- Preoperational testing
- Periodic testing
 EDG Reliability
 EDG Unavailability

EDG Qualification Testing

Branch Technical Position ICSB-2(PSB) 11/24/1975 NUREG - 75/087

Demonstrate start and load reliability of prototype EDG a 0.99 reliability by performing:

- Prior to fuel load two margin tests with some margin in excess of design requirement
- 300 valid start and load tests with no more than three failures allowed

At least 90% of the tests should be performed from design cold ambient conditions (design hot conditions if standby temperature control system is provided)

10% from design hot equilibrium temperature conditions

Loading to at least 50% of the continuous rating

EDG Qualification Testing

This Branch Technical Position was subsequently superseded by IEEE-387 which requires a total of 100 valid start and load tests with no failures allowed. These tests will be conducted as follows:

- At least 90% of the tests should be performed from warm standby conditions
- 10% from design hot equilibrium temperature conditions
- Loading to at least 50% of the continuous rating
- Shall accept a single step load 50% of the continuous rating

EDG Pre-operational Testing

Preoperational testing per RG 1.108

• 69 consecutive valid start and load tests without any failures, with a minimum of 69/n test per EDG where n equals to the number of EDGs at a plant

The above requirements were subsequently superseded by RG 1.9 Rev. 3 which recommends a minimum of 25 valid start and-load demands without failure on each installed emergency diesel generator unit

EDG Periodic Testing

Periodic testing

- Monthly testing at least once in 31 days to ensure that EDG reliability is maintained at an acceptable level
- 6-monthly testing to demonstrate the capability of the EDG to start from standby and provide the necessary power to mitigate the loss-of-coolant accident coincident with loss of offsite power
- 24 months testing to demonstrate overall EDG unit design capability
- 10-year testing to demonstrate that the trains of standby electric power are independent

Reliability of EDG was identified as being one of the main factors affecting the risk from SBO. Thus, attaining and maintaining high reliability of EDGs was a necessary input to the resolution of USI A-44.

- In 1977 Generic Safety Issue B-56 (Diesel Reliability) was initiated based on examination of LERs which indicated EDG reliability of .94 as compared to goals of .99
- NRR rewarded a contract to University of Dayton Research Institute to identify more significant causes of EDG failures (reported in NUREG/CR-0660)
- In 1980 NRR recommended back fitting of RG 1.108 EDG testing frequency and associated failure reporting requirements to all operating plants as well as the implementation of the NUREG/CR-0660 recommended remedial actions at all operating plants as a final action to resolve GSI B-56

As a result, Tables 4.8.1.1.3, "Reports," and 4.8-1, "Diesel generator Test Schedule," were added to the TS. The test schedule was as follows:

- if the number of failures in the last 20 tests were one or less then the test frequency should be once per 31 days
- If the number of failures in the last 20 tests were two or more then the test frequency should be reduced to 7days
- this test frequency will be maintained until 7 consecutive failures in the last twenty tests have been reduced to one or less
- In 1982, DST (Systems Technology) with the assistance of DSI, DL and IE prepared an interim diesel generator reliability program for operating plants which established a reliability of .95 as a minimum desired reliability and .9 as the minimum acceptable level of reliability and required additional actions based on number of failures in the last 20 test etc.

In 1984, as part of the technical evaluation of USI A-44,the staff issued Generic letter 84-15 and provided an example of EDG performance TS. The following items were requested from the licensees:

- To describe current program to avoid fast cold starts and reduce unnecessary testing
- Furnish current EDG reliability data
- Description of EDG reliability program

Until 1986 the reliability was calculated as a point estimate (number of failures/total number of starts) per RG 1.108

Per NSAC/108 the reliability was redefined as:

• EDG reliability=start reliability x load run reliability

Where Start reliability=number of successful starts/total number of valid demands and Load run reliability=number of successful load runs/total number of load runs

The SBO rule was issued in 1988

In the implementation of SBO rule, the licensees were given the option to pick EDG reliability of .95 or .975. However, the SBO rule did not require the licensees to monitor and maintain these reliability values

The staff felt there was no realistic possibility of demonstrating that it had or it had not been met for any plant's EDG with the current failure rate data at that time

GSI B-56 was still not resolved

To resolve GSI B-56, the staff proposed generic letter 10 CFR 50.54(f) and revision to RG 1.9

The proposed revision to RG 1.9 would consolidate guidance on EDGs previously provided in RG.1.9, Rev. 2, and GL 84-15 in to a single guide. In addition, the guide added sections on EDG reliability monitoring including elements of EDG reliability program as well as the trigger values at which the action must be taken by the licensees.

In SECY-90-340 (1991) the commission disapproved the generic letter and the provisions of 10 CFR 50.54(f) as a vehicle for imposing requirements or securing enforceable commitments from licensees to address GSI B-56 and stated that this issue should be addressed thru rulemaking The Commission endorsed a results oriented approach

consistent with the MR and directed the staff to amend the SBO rule 50.63 and revise RG 1.9

The staff prepared the package which contained the revised rule that discusses the monitoring of EDG performance and related enforcement action

EDG Reliability -- Monitoring Approach_

Early warning report (3 failures in the last 20 demands) – Notify the NRC in writing Problem EDG (4 failures in the last 25 demands) – Notify NRC and subject the EDG to accelerated testing until 7 consecutive failure free tests are achieved Double trigger (5/50 and 8/100 demands for .95 target, 4/50 and 5/100 for .975 target) occurrence is evidence of not meeting SBO selected EDG reliability target and the licensee is in noncompliance with 50.63. The Commission also asked the staff to describe the enforcement actions that the staff would take. The staff proposed the following.

Upon occurrence of the double trigger the licensee will:

- Implement appropriate corrective action
- Notify NRC operations center within 24 hours
- If restoration of EDG has not been restored within 30 days send a written report for this condition, the basis on which the EDG is operable and a description and schedule for corrective action to restore EDG reliability to assumed values

As a consequence of continuing ACRS concerns on the use of trigger values, in a letter to the Chairman, ACRS argued that the proposed rule amendment was unnecessary to ensure adequate EDG reliability and that the EDG reliability was generally good

Some members of ACRS disagreed and recommended that SBO rule should be issued for public comments

In 1990s the reliability of EDG significantly improved Finally in SECY-93-044 (1993) the Commission stated that in view of the industry-wide average reliability EDG of .98, the Commission believed a rule was not necessary As part of the resolution of GSI B-56, the Commission approved Option 4 as recommended by the staff In Option 4, the staff recommended that licensee adopt the accelerated testing provisions of Improved Technical Specifications with an option to relocate accelerated testing requirements for EDGs from TS to the maintenance program after the maintenance rule (MR) goes in to effect in 1996After further consideration, the staff decided that it was not necessary to await the effective date of the MR and to relocate the accelerated testing requirements to the maintenance program

The staff issued GL 94-01 with guidance for implementing a line – item TS improvement to remove accelerated testing and special reporting requirements for EDGs from the plant TSs or from docketed commitments. However, the licensees would continue to comply with the provisions of 10 CFR 50.72 and 50.73 to notify NRC and report EDG failures.

The staff's approval of this option was contingent upon a commitment to implement within 90 days of a license amendment a maintenance program for monitoring and maintaining EDG performance in accordance with the provisions of 50.65 and the guidance of RG 1.160, "Monitoring the Effectiveness of Maintenance at nuclear power Plants."

Subsequently, utilities docketed commitments to maintain their selected target reliability values (.95 or .975). Those values are being used as a goal or as a performance criterion for EDG reliability under 4 the MR

EDGs are required to be handled under 10 CFR 50.65(a)(1) where they are subject to monitoring against licensee-established goals or under 10 CFR 50.65(a)(2) where they are subject to monitoring against licensee-established performance criteria All EDGs under 10 CFR 50.65(a)(1) and (a)(2)) are subject to the requirements of 10 CFR 50.65(a)(3), including (1) periodic evaluation, (2) balancing reliability and unavailability, and (3) assessing the impact on plant safety of taking equipment out of service

EDG Unavailability

When SBO rule was developed in 1980s, EDG unavailability was estimated to be 0.007 which was significantly less than the EDG failure rates. Therefore, the SBO rule did not explicitly addressed maintenance unavailability, but emphasized the importance of reliable EDGs.

The operating data then showed an improvement in EDG reliability but an increase in unavailability due to maintenance, a significant portion of which due to routinely schedule maintenance

In 1991, the NRC staff reviewed EDG performance during actual demands. They found that in 5 of 128 demands the EDG did not function because it was out of service for maintenance. This value of 5/128 demands represents an unavailability due to time out-of-service for maintenance of .04 versus .007 previously used in developing the SBO rule.

EDG unavailability due to testing and maintenance was also estimated using out-of-service data over two years from June 1990 to May 1992, provided by NRC regional offices which reported EDG unavailability due to maintenance and testing of .017 during operation and 0.12 during shutdown
EDG Unavailability

EDG unavailability is also being monitored under the MR Section (a)(3) of the MR rule requires that licensees make adjustments where necessary to ensure that the objective of preventing failures thru maintenance is appropriately balanced against the objective of minimizing unavailability due to monitoring or preventive maintenance i.e., licensees must periodically balance unavailability and reliability of the EDGs and assess the impact of removing EDGs from service on overall plant safety must also be performed.

Therefore, plant specific EDG unavailability should be monitored as goals under 10 CFR 50.65(a)(1) or established as performance criteria under the plant's preventive maintenance program under 10 CFR 50.639a)(2) taking in to the objective of 10 CFR 50.65(a)(3)

Emergency diesel generator unavailability values that were assumed in plantspecific individual plant examination (IPE) analyses should be compared to the plant-specific emergency diesel generator unavailability data regularly monitored and reported as industry-wide plant performance information. These values could also be used as the basis for a goal or performance criterion under the maintenance rule.

EDG ALLOWED OUTAGE TIME (AOT) EXTENSION

The NRC has been granting AOT extensions for EDGs to perform on-line preventive maintenance. This provides the licensees flexibility for performing various EDG maintenance and repair activities during power operation. it also reduces plant refueling outage duration. However, the AOT extensions for EDGs are granted to those licensees who have installed a qualified alternate ac (AAC) source credited for station blackout events which can be substituted for an inoperable EDG in the event of a loss of offsite power (LOOP).

The staff has also allowed BWR licensees to use the Division III diesel generator (high pressure core spray pump (HPCS) diesel generator) as an AAC power source to power safe shutdown loads if a cross-connect capability is provided so that the HPCS diesel generator can be cross-connected to either Division I or Division II ac buses to provide power in the event of a LOOP when one EDG is in the extended outage and the other EDG becomes unavailable. This cross-connection is generally accomplished within two hours.

The staff has required that in order for a HPCS diesel generator to be qualified as an AAC source, it must be free from other required safety functions (should not be relied upon as an station blackout mitigation system).

EDG ALLOWED OUTAGE TIME (AOT) EXTENSION

Some licensees have installed a commercial-grade diesel generator capable of supplying power to, as a minimum, the required safe-shutdown loads on the EDG train removed from service for the maintenance outage.

The staff evaluates each licensee's request for EDG AOT extension from a deterministic and probabilistic risk assessment (PRA) aspect. From a PRA perspective the licensee must demonstrate that the plant risk is low. From a deterministic perspective, the following compensatory measures are required to be implemented before entering the extended outage (after the august 14, 2003, grid event, the staff has required that all compensatory measures be included as regulatory commitments):

- The AAC power source or equivalent will be available as a backup to the inoperable EDG. After entering the extended AOT, the AAC source will be verified available every 8 hours and treated as protected equipment.
- The scheduling of EDG preplanned maintenance will be avoided during severe weather (tornado, thunderstorm, or ice storm conditions) or if grid stress conditions are high or forecasted to be high.
- F The system load dispatcher will be contacted once per day to ensure no significant grid perturbations are expected during the extended. the system load dispatcher should inform the plant operator if conditions change during extended AOT such that unacceptable voltage would occur following a unit trip.

EDG ALLOWED OUTAGE TIME (AOT) EXTENSION

 Component testing or maintenance of safety systems and important nonsafety equipment Including offsite power systems (auxiliary and startup transformers) that increases the likelihood of a plant transient or loop will be avoided. In addition, no discretionary switchyard maintenance will be allowed.

Technical specification requirements of verification that the required systems, subsystems, trains, components, and devices that depend on the remaining EDG(s) are operable and positive measures will be provided to preclude subsequent testing or maintenance activities on these systems, subsystems, trains, components, and devices.

Steam-driven emergency feed-water pump will be controlled as protected equipment.

More Questions!!

EISMIC DESIGN OF DULAR REACTORS

budhi and Rich Morante ven National Laboratory January 19, 2011



a passion for discovery





Page 0826 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0827 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0828 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0829 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0830 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0831 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0832 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0833 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0834 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0835 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0836 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0837 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0838 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0839 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0840 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0841 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0842 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0843 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0844 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0845 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0846 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0847 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0848 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0849 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0850 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0851 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0852 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0853 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0854 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0855 of 1020

Withheld pursuant to exemption

(b)(4)
Page 0856 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0857 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0858 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0859 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0860 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0861 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0862 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0863 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0864 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0865 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0866 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0867 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0868 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0869 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0870 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0871 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0872 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0873 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0874 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0875 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0876 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0877 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0878 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0879 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0880 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0881 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0882 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0883 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0884 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0885 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0886 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0887 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0888 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0889 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0890 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0891 of 1020

Withheld pursuant to exemption

(b)(4)
Page 0892 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0893 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0894 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0895 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0896 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0897 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0898 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0899 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0900 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0901 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0902 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0903 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0904 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0905 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0906 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0907 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0908 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0909 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0910 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0911 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0912 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0913 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0914 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0915 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0916 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0917 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0918 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0919 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0920 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0921 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0922 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0923 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0924 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0925 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0926 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0927 of 1020

Withheld pursuant to exemption

(b)(4)
Page 0928 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0929 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0930 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0931 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0932 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0933 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0934 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0935 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0936 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0937 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0938 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0939 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0940 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0941 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0942 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0943 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0944 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0945 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0946 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0947 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0948 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0949 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0950 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0951 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0952 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0953 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0954 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0955 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0956 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0957 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0958 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0959 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0960 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0961 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0962 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0963 of 1020

Withheld pursuant to exemption

(b)(4)
Page 0964 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0965 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0966 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0967 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0968 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0969 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0970 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0971 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0972 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0973 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0974 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0975 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0976 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0977 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0978 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0979 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0980 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0981 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0982 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0983 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0984 of 1020

Withheld pursuant to exemption

(b)(4)

Page 0985 of 1020

Withheld pursuant to exemption

(b)(4)



Protecting People and the Environment

Turbine Missiles – Explained

George Georgiev, Sr. Materials Engineer Component Integrity, Performance and Testing Branch 2 Division of Engineering Office of New Reactors

Turbine Generator (TG) System Description

- The TG does not perform or support any safety-related function, and thus, has no safety design basis.
- The TG is, however, a potential source of high energy missiles that could damage safety-related equipment or structures.
- Therefore, the turbine needs to be designed to minimize the possibility of failure of a turbine blade or rotor.





United States Nuclear Regulatory Commission

Regulatory Basis

- General Design Criterion (GDC) 4 states that structures, systems and components (SSCs) important to safety shall be appropriately protected against environmental and dynamic effects, including the effects of missiles, that may result from equipment failure.
- Turbine rotors have large masses, rotate at relatively high speeds during operation and, therefore, failure of a rotor may result in the generation of high-energy missiles which may inflict damage on SSCs.
- To satisfy GDC 4, turbine rotor integrity must be maintained to minimize the probability of turbine rotor failure.





United States Nuclear Regulatory Commission

NRC Guidance and Review Documents

Regulatory Guide (RG) 1.115, "Protection Against Low-Trajectory Turbine Missiles," and Standard Review Plan (SRP) Section 3.5.1.3, "Turbine Missiles," guide the evaluation of the effect of turbine missiles on public health and safety. SRP Section 10.2.3, Revision 2, "Turbine Rotor Integrity," provides guidance to achieve integrity of the turbine rotor and ensure that the turbine rotor materials have acceptable fracture toughness and elevated temperature properties to minimize the potential for failure.





United States Nuclear Regulatory Commission

Probability of Damage from Turbine Missiles

- The probability of unacceptable damage from turbine missiles is expressed as the product of: The probability of turbine missile generation resulting in the ejection of turbine blades (or internal structure) fragments through the turbine casing, (P_1)
- The probability of ejected missiles perforating intervening barriers and striking safety-related SSCs, (P_2)
- The probability of impacted SSCs failing to perform their safety functions, (P_3) .





United States Nuclear Regulatory Commission

Probability of Damage from Turbine Missiles (cont.)

Upon review of the operating experience of turbines and the NRC safety objectives in 1986, the NRC staff shifted its emphasis in the review of turbine missile issues from missile generation, strike, and damage probability, $P_1 \times P_2 \times P_3$, to the missile generation probability, P_1 .

The minimum recommended reliability values of P₁ are less than 10⁻⁴ per reactor-year for favorably oriented turbines, and less than 10⁻⁵ per reactor-year for unfavorably oriented turbines.







See Figure 1.1-1 for nonsenclature

Figure 3.5-2. ESBWR Standard Plant Low-Trajectory Turbine Missile Strike Zone

TABLE 3.5.1.3-1

E COBABILITY OF TURBINE FAILURE RESULTING IN THE EJECTION OF TURBINE ROTOR (OR INTERNAL STRUCTURE) FRAGMENTS THROUGH THE TURBING F CASING (P.) AND RECOMMENDED LICENSEE ACTIONS

Case	PROBABILITY PER YEAR FOR A FAVORABLY ORIENTED TURBINE	PROBABIL 117 PER YEAR FOR AN UNFAVORABLY ORIENTED TURBINE	RECOMMENDED LICENSEE ACTION
Â	⊐ < •g	P < 10 °	This condition represents the general minimum reliability requirement for load by the turbine and bringing the system for light
Б	1⊴* < P. < 131	10° < 2. < 10 ⁻	If this condition is reached during operation, the turbine may be kept in service until the next scheduled outage, at which time the licensee must take autom to reduce P, to meet the appropriate Case A criterion before returning the turbine to service
	*) <⊃ < *)) ²	10 ⁴ < P < 10 ⁴	If this condition is reached during operation, the turbine must be isolated: from the steam supply within 60 hays lat which time the Leensee must take a loc to reduce P, to meet the appropriate Gase A criterion before returning the turbine ro- service.
C:	(); < P	10` <p.< td=""><td>If this condition is reached during operation, the turbine must be isolated from the steam supply within 6 days lat which time the licensee must take action to reduce P, to meet the appropriate Case A criterion before returning the turbine to service</td></p.<>	If this condition is reached during operation, the turbine must be isolated from the steam supply within 6 days lat which time the licensee must take action to reduce P, to meet the appropriate Case A criterion before returning the turbine to service

Turbine Manufacturers in USA

- There are relatively few manufacturers that have supplied turbines to the nuclear power plant owners
- Westinghouse has the most turbines installed followed by General Electric
- Siemens and Alstom had refurbished lowpressure rotors in several nuclear power plants in USA





Turbine Designs employed

- In most of US operating plants the shrunk-on disk rotor were initially installed
- For new plants all DCD applicants except ARIVA have proposed to use an integral forging rotor design
- ARIVA has proposed to use an unique welded rotor design that Alstom employs in the fabrication of its turbines





United States Nuclear Regulatory Commission



Steam Turbine Supervisory Instruments System



COMPONENTES



ROTORS

A <u>typical</u> rotor assembly consists of a shaft, wheels, buckets and couplings which transform the energy of the steam into rotating, mechanical energy.








WHEELS Wheel dovetails

Machined surfaces of the outer circumference of a wheel to which buckets are securely fastened.







SECTION A - A

Figure 3-1. Schematic drawings of keyway design used by Westinghouse in shrunk-on disks of low-pressure rotors. (Source: EPRI NP-2429-LD, Vol. 6)







Figure 3-3. Schematic drawing of Westinghouse Model X-3 lowpressure rotor. All disks are shrunk on and the number of blade rows per disk is as indicated. Last-stage blades are 112 cm (44 in.) long. (Source: EPRI NP-2429-LD, Vol. 6)





Figure 3-8. Schematic drawing of keyway design reportedly used by General Electric in shrunk on disks of low-pressure rotors.











How Ejection of Turbine Missiles Prevented

The ejection of turbine is prevented by following the turbine manufacturer's recommendations specified in the Turbine Maintenance Program

The NRC staff requires that the Turbine Maintenance program is submitted to the staff's review within three years after the plant is placed in operation





United States Nuclear Regulatory Commission

How Ejection of Turbine Missiles Prevented (Cont.)

- The turbine maintenance program specifies periodic in-service inspection of turbine subcomponents including rotors
- The in-service inspection recommendations are based on actual as-build rotor material properties and actual preservice inspection results performed on the rotor prior to shipment to the site





Information included in the Turbine Maintenance Program

Probabilistic approach to evaluating P₁ that includes information on critical crack size, crack growth rate, rotor operating temperature and applied stress used in the evaluation model

Numerical approach such as Monte-Carlo simulations and number of iterations required for reliable probability estimate





Information included in the Turbine Maintenance Program (Cont.)

- Results of the preservice non-destructive examinations
- Rotor material mechanical test results including FATT and Charpy tests results Recommended turbine valve testing intervals Recommended in-service inspection intervals In general every 10 to 13 years in-service inspection is recommended for the rotor





United States Nuclear Regulatory Commission

Status of Turbine Missile Generation Issue for New Reactors

The NRC staff had specified that a bounding analysis report exist assessing the probability of turbine missiles prior to approving COL application, if not the DCD applicant needs to provide an ITAAC requiring that the COL submit to the staff its Turbine Maintenance Program for review and approval prior to fuel load.

This process was communicated in two public meetings with the industry and other stake holders



United States Nuclear Regulatory Commission

Status of Turbine Missile Generation Issue for New Reactors

- All DCD applicants have provided the NRC staff with bounding analysis reports showing that they can meet the NRC recommended values for P_1
- The bounding analysis reports also include assessment of various modes of failures such as ductile burst from destructive overspeed, high and low cycle fatigue and failure due to stress corrosion cracking





United States Nuclear Regulatory Commission

Conclusion

Because all DCD applicants have provided bounding analysis reports showing that their turbines will meet the NRC requirements for P_1 , it can be concluded that the turbine probability issue will not result in open items or otherwise impact the project licensing schedules





United States Nuclear Regulatory Commission

Backup Slides

Illustrations for Cracks and Examples of evaluation methods

Monte Carlo Variables





Figure 5-15 Schematic of Yankee Rowe LP rotor; arrows point out failed No.1 disks [8]



Figure 5-16 Diagram of Yankee Rowe failed generator-end no.1 disk (largest bore crack, 1.94" deep x 1.62" long, is at segments 5/6) [8]



The basic edge-crack model is modified for use in the Westinghouse analysis to incorporate a flaw geometry factor, G, which accounts for both the gross shape of the flaw as well as the beneficial effects of crack branching and irregularities in the shape local to the crack tip. The resulting crack model is given in Equation 2-1 below.

$$a_{er} = \frac{1}{1.21\pi} \left(\frac{K_{1C}}{\sigma}\right)^2$$

Equation 2-1

where:

 a_{α} is the nominal critical crack size accounting for shape parameter or branching factor

 $a_{ci} = G(a_{ci})$ is a larger, effective critical crack size that includes shape parameter and branching factor

K_{tc} is the material toughness

and, σ is the applied stress



Disks 8 and 9 These are Ni-Cr-Mo-V disks, with FATT values in the -135° F to 0°F range (Table 2). Therefore for normal operation these disks are in the upper shelf region. The following *Rolfe-Novak* upper-shelf relationship was used [8]:

$$e\frac{K_{h}}{\sigma_{h}}\vec{f} = 5e\frac{CVN}{\sigma_{h}} - 0.05$$
(7)

A lower bound $K_{\rm h}$ value of 181 ksrvinch was estimated for the minimum reported CVN value of 70 fi-lbs and an average yield strength of 101 ksr (see Table 2)



Inputs for Monte Carlo variables

- 1. Scale factor for load/stresses (normal distribution)
- 2. Overspeed level (normal distribution)
- 3. Rotor startup temperature (normal distribution)
- 4. Rotor operating temperature (normal distribution)
- 5. Crack depth (normal distribution)
- 6. Crack ratio depth/length (normal distribution)
- 7. Yield strength (normal distribution)
- 8. Lower bound Fracture (normal distribution)
- 9. FATT (normal distribution)
- 10. Fracture Toughness (normal distribution)
- 11. Crack Initiation time (user-defined)
- 12. SCC Growth Rate Constant
- 13. SCC Growth Threshold (normal distribution)